

Vander Mynsbrugge Jorrit

From: noreply@elia.be
Sent: woensdag 28 augustus 2019 18:21
To: Vander Mynsbrugge Jorrit; Pirlot Yunus
Subject: Strategic Reserve: input data for determining the volume for winter 2020-2021

A new answer to consultation "Strategic Reserve: input data for determining the volume for winter 2020-2021" has been submitted on our website.

First Name: guy

Name : willemot

e-mail : guy.willemot@emgb.eu

Organization : EM Generation Brussels

Comments : ISO conditions of the gas turbine (based on recent figures) is 255 MW. The data refers to 265 MW.

Upload :

Confidentiality : No