



Public consultation on the methodology, hypotheses and data sources for the dimensioning of the volumes of strategic reserve needed for winter 2020-2021

**Consultation period:
From 26/04/2019 to 24/05/2019**

Contents

1	Introduction	4
1.1	Structure of this document	4
1.2	Timing.....	4
1.3	Subsequent consultations	4
2	Methodology.....	5
2.1	Improvements.....	5
2.1.1	Flow-Based modelling	5
2.1.2	Total Demand Growth	5
2.1.3	Demand profiles for all European countries.....	5
2.1.4	Market Response.....	5
2.1.5	Forced outage rates and longer unavailabilities	6
2.1.6	Planned outages for production units in Belgium	6
2.2	General methodology	6
3	Hypotheses and data sources.....	7
3.1	General hypotheses and data sources	7
3.1.1	Simulation perimeter	7
3.1.2	Climatological data	8
3.1.3	Analysed timeframe.....	8
3.1.4	Variable costs of production units	9
3.1.5	Base case and sensitivities	9
3.2	Hypotheses and data sources for Belgium.....	9
3.2.1	Hypotheses on the Belgian electricity supply.....	9
3.2.2	Hypotheses on the Belgian electricity demand.....	12
3.2.3	Demand response	14
3.3	Hypotheses for the other simulated countries.....	15
3.3.1	France	15
3.3.2	The Netherlands.....	15
3.3.3	Germany.....	15
3.3.4	Great-Britain	15
3.3.5	Luxembourg	15
3.3.6	Other countries modelled	16
3.4	Hypotheses for interconnectors	17
3.4.1	Flow-based domains for the CWE region.....	17
3.4.2	FB domain impact related to the evolution of the 380kV grid in Belgium.....	18
3.4.3	HVDC outages.....	19
3.4.4	Fixed commercial exchange capacity on the borders of the countries outside the CWE region	20
	Appendix A Legal framework and process	21
A.1	Process	21
A.2	Legal notice period for production facility closure.....	22
A.3	Adequacy criteria.....	23
	Appendix B Proposed methodology	25
B.1	Definition of future states	25
B.1.1	Random variables and time series	25
B.1.2	'Monte Carlo' sampling and composition of climate years.....	26
B.1.3	Number of future states	28
B.2	Identification of periods with structural shortage	28
B.2.1	Input and output of the market model	29
B.2.2	Model used to simulate the electricity market	30
B.3	Evaluation of the strategic reserve volume or margin	33
	Appendix C Flow-based method applied for the CWE-zone.....	34
C.1	Why use a flow-based methodology?.....	34

C.2	How are flow-based domains established?	36
C.2.1	Selection of typical days.....	36
C.2.2	Modification of the input hypotheses for the typical days to account for new grid & market configurations.....	36
C.2.3	Calculation of the new flow-based domains.....	37
C.2.4	Approximating the domains for computational efficiency	37
C.2.5	Incorporating multiple flow-based domains into the adequacy assessment	37
Appendix D	Integration of the Market Response in Belgium	39
D.1	Aggregated curves analysis: global volume estimation	39
D.1.1	Demand decrease.....	40
D.1.2	Offer increase	40
D.2	“Objective qualitative Q&A”: qualitative content to complement the aggregated curves analysis	41
D.3	Global sanity check	42
D.4	Integration in the adequacy assessment.....	42
References	43

1 Introduction

This public consultation is held in the context of the yearly process of the volume determination of strategic reserve, as described in the Article 7bis of the Law of 29 April 1999 concerning the organisation of the electricity market ('Electricity Act' – for more information on the legal framework see Appendix A). The analysis by Elia concerns the need for the winter 2020-21 and an indication for the winters 2021-22 and 2022-23.

Elia wants to provide the market parties a full understanding of the methodology and data for the calculation of the necessary volume of strategic reserve. The market parties will be able to submit their comments and suggestions through various interactions.

1.1 Structure of this document

This document aims to provide an overview of the methodology and references to the main data sources to be used for the calculation of the necessary volume of strategic reserve. For this consultation no specific questions are provided, but these can be formulated in any way desired through comments or suggestions on the provided consultation documents.

As this is the seventh iteration of the strategic volume need determination, both law and methodology have been refined and become stable. Therefore, this document has been restructured, moving more general descriptions to the appendices whilst focussing on changes & improvements in the main text.

This main text is divided into two parts:

- The first describes the methodological changes;
- The second provides an overview of the main hypotheses and data sources that are proposed to be used for the analysis.

1.2 Timing

This document is published on Elia's website from **April 26, 2019** onwards. The different reactions from stakeholders should be sent via email to the following address: usersgroup@elia.be.

Stakeholders have a period of four weeks to provide their various comments. The reactions should be sent at the latest by **May 24, 2019 at 18h00**.

After this period, Elia will consolidate the various comments and suggestions from stakeholders and these will be published on the Elia website. The answer of Elia to the comments will be published via a consultation report and will also be explained in the Task Force "Implementation of Strategic Reserve".

It is important to note that all comments received will be published at the end of the consultation, unless confidentiality constraints are explicitly communicated towards Elia.

1.3 Subsequent consultations

Later this year, when the various data sets will be available to Elia (between mid-August to mid-September), a second interaction will be organized with the market parties on the precise data that will be used for the calculations.

Comments relating to changes in the law or other issues that are not within the competence of Elia are therefore not part of the consultations organized by Elia.

2 Methodology

2.1 Improvements

Elia is committed to continuously develop both the modelling methodology and the underlying data assumptions in order to increase the accuracy of its adequacy assessments. As this concerns the seventh iteration of the volume determination, the model has become very stable, and efforts this time will be focused on improving model efficiency.

Nevertheless, some methodological improvements in the assessment for winter 2020-21, compared to the assessment performed for winter 2019-20 are foreseen. Below we include an overview:

2.1.1 Flow-Based modelling

Elia will update the typical days used, with the ones of the latest SPAIC process performed by the CWE flow-based expert group, provided that they are available in time.

These domains will be corrected for historical grid outages, and incorporate most recent grid conditions, notably the effect of NEMO and ALEGrO, and market configuration changes (DE/AT split).

The same systematic approach as used in previous assessments will be followed, linking specific combinations of climate conditions for wind and load with the representative flow-based domains to be considered in the simulations.

For a more in depth explanation on flow-based modelling, please refer to Appendix C.

2.1.2 Total Demand Growth

Over the past few years, Elia has worked with the IHS MARKIT consultancy bureau as the data provider for the domestic demand growth rate. Last year, following questions raised by stakeholders, IHS was asked by Elia to provide more details on their framework, which were subsequently published in the methodology consultation. Additionally, after discussing with IHS, a choice for the Rivalry scenario was made as the reference scenario for short term forecasts. Elia is confident that this approach remains valid for this year's volume assessment.

However, Elia has also, very recently, started building its own demand forecasting framework. If by this summer the framework shows enough promise, Elia will evaluate whether to apply it to this year's strategic reserve volume determination. Prior to the volume determination, the total demand assumption will be published in the second consultation, i.e. the consultation on input hypotheses, at the end of august.

2.1.3 Demand profiles for all European countries

At ENTSO-E, a new tool for creating load profiles for the various climatic years for all European countries has been developed. This new piece of software is called TRAPUNTA. In order to keep consistency with the European adequacy assessments, Elia will incorporate it into this analysis, provided this method is tried & tested in due time. At the time of writing TSO feedback is being collected by ENTSO-E before the go-live.

2.1.4 Market Response

In the context of the strategic volume determination analysis for winter 2018-19, key market stakeholders agreed upon a design for the most adequate methodology to determine the volumes

of Market Response in Belgium. This methodology will be deployed for the third time, considering new available data from April 2018 until end of March 2019, in order to calculate updated figures of the new estimates for Market Response.

For a more in depth explanation on the market response evaluation, please refer to Appendix D.

2.1.5 Forced outage rates and longer unavailabilities

The forced outage rates of power plants used by Elia in its analysis are based on the historical official communications available from the power plant owners. This analysis will again be updated this year to include the most recent available data.

Long term outages of nuclear units are taken into account using a sensitivity, named 'low probability high impact' hereafter. This approach has been agreed upon by the EC (DG competition [1])

2.1.6 Planned outages for production units in Belgium

As was done last year, the latest available data on planned outages from the transparency websites of the generation unit owners will be taken into account for Belgium. Additionally, and following some stakeholder comments, Elia will investigate whether sufficient high quality data is available to make a statistical modelling of the planned outages for nuclear units. This way, if certain patterns (e.g. systematic over- or underestimation) are discovered, these will be accounted for.

2.2 General methodology

The current methodology, based around unit commitment and economic dispatch, combined with a Monte-Carlo approach to deal with uncertainty has been tried and tested, not only by Elia, but also by other European TSO's as a whole.

A brief introduction to the methodology can be found in Appendix B.

A more extensive description of the different elements can be found in the report of November 2018 for the volume determination of strategic reserve for winter 2019-20[2].

3 Hypotheses and data sources

In this section, we describe in detail the hypotheses and data sources that will be used for the determination of the volume of strategic reserve for the winter 2020-21. Section 3.1 focuses on the general hypotheses and data sources, while section 3.2 provides the details for Belgium in specific. The hypotheses and data sources for the other countries considered in the analysis are given in section 3.3.

3.1 General hypotheses and data sources

3.1.1 Simulation perimeter

Given the high amount of possible energy exchanges between countries, accurate modelling of the foreign countries is crucial in order to quantify structural shortage hours in Belgium. The simulated perimeter, consisting of 20 different countries, is shown in Figure 1.



Figure 1

The **Central Western Europe (CWE) zone** is comprised of Germany (DE), France (DE), Belgium (BE), The Netherlands (NL), Luxembourg (LU) and Austria (AT).

Besides the CWE zone, the following other areas are modelled: Spain (ES), Portugal (PT), Great-Britain (GB), Ireland (IE), Northern Ireland (NI), Switzerland (CH), Slovenia (SI), Czech Republic (CZ), Slovakia (SK), Hungary (HU), Norway (NO), Denmark (DK), Sweden (SE) and Poland (PL).

3.1.2 Climatological data

Climatic variability is modelled using historical climate data of 33 historical winters. The concerned winters are those between 1982 and 2015. The following data sources are used:

- The data for **hydro power** production are obtained from the ENTSO-E data portal. These sources are available for the period 1991-2015 and for years before 1991 the data is reconstructed based on historical precipitation¹ data from the NCDC² [3].
- As discussed in section 2.1 a new tool has been developed in the context of ENTSO-E, which generates **load time series** taking into account the temperature sensitivity of each country.
- Production data in the form of time series for onshore and offshore **wind and solar** power are procured in the context of ENTSO-E from the Technical University of Denmark (DTU). These production data are constructed based on amongst others historical wind and radiation data.

Table 1 summarizes the different climate data used, together with the data granularity and source.

Data type	Granularity	Source
Temperature	Daily	Procured in the context of ENTSO-E.
Onshore and offshore wind production	Hourly	Procured in the context of ENTSO-E, distributed in the form of the Pan-European climate database.
Solar power production	Hourly	Procured in the context of ENTSO-E, distributed in the form of the Pan-European climate database.
Hydro power production	Monthly	ENTSO-E data portal, combined with extrapolation based on historical precipitation (NCDC).

Table 1

3.1.3 Analysed timeframe

The analysed timeframe is the winter period as indicated in article 2, 51° of the Law of 29 April 1999 concerning the organisation of the electricity market [4]('Electricity Act', translated from Dutch):

"Winter period": *period from November 1 until 31 March.*

The report will provide a probabilistic assessment of Belgium's security of supply and the need for strategic reserve for the upcoming winter, i.e. 2020-21. On top of the assessment for the upcoming winter, Elia will as well provide an indication on the need for the two following winters, i.e. 2021-22 and 2022-23. The different indicators will be calculated for these periods.

¹ Data of different meteorological stations per country

² NCDC: National Climatic Data Center

3.1.4 Variable costs of production units

Variable costs of production units do not influence the volume determination of the strategic reserve as such. These costs are taken into account in order to obtain a more realistic economic dispatch of the production units.

3.1.5 Base case and sensitivities

The base case will be developed with the hypotheses and data sources as they are described in this document. For the sensitivity Elia will again use a “low probability – high impact” scenario, as agreed upon by the European Commission [1]. Analysis will determine the amount of generation volume that should be considered unavailable in Belgium & France.

3.2 Hypotheses and data sources for Belgium

This section elaborates on the data sources and the modelling techniques used in the analysis for Belgium. In **section 3.2.1**, the data sources and modelling techniques used with regard to **Belgian electricity supply** are detailed. Next, **section 3.2.2** elaborates on the **Belgian electricity demand** and the way its specifics are incorporated in the model.

In line with Article 7bis of the Electricity Law, Elia will receive input from the Directorate-General of Energy of the Federal Public Service (FPS) Economy prior to 15 October 2019. The information received from the FPS Economy will be integrated in the report and will be taken into account in the analysis.

3.2.1 Hypotheses on the Belgian electricity supply

3.2.1.1 Onshore wind, offshore wind and solar power

The FPS Economy will consult the three Belgian communities to obtain forecasts for the installed capacity of onshore wind and photovoltaic production. Elia bases itself on the latest information available to consolidate a forecast of the installed capacity of offshore wind. The forecasts for installed capacity are combined with the historical production profiles to obtain 33 different time series for the winter period and for onshore wind, offshore wind and photovoltaic production separately. This process is illustrated in Figure 2.



Figure 2

3.2.1.2 Biomass, waste, combined heat & power facilities and small production units

Installed capacity consolidation

In the same way as for onshore wind and PV, the FPS Economy will consolidate a forecast for the installed **biomass** production capacity after consultation with the regions.

For **CHP, waste**, and smaller production units the forecast of the installed capacity will be based on the information available in the Elia production database. Only projects communicated to Elia that are in a sufficiently advanced phase in their development will be taken into account in the analysis.

Elia production database

Elia maintains a database with information on both centralised and decentralised production units. This database is kept up to date on a monthly basis through exchanges with the distribution system operators and direct clients of Elia. Both units subject to a CIPU³ contract, as well as units for whom such a contract does not apply are present in the database.

When the unit is subject to a CIPU contract, its owner has the obligation to notify Elia about the availability of the unit. The producer has to provide Elia with availability forecasts for both the long term (one year) and the short term (one day). In general, units for which no CIPU contract applies have a smaller installed capacity. It is agreed with the distribution system operator that all units with an installed capacity bigger than 0.4 MW have to be reported to Elia for inclusion in the database. In practice, often units with an installed capacity smaller than 0.4 MW are also reported, either individually or aggregated. The database contains both information concerning units that are in service, but also projects that are currently under development.

Modelling approach

In the ANTARES model, production units subject to a CIPU contract are modelled differently from those for which no CIPU contract applies.

The thermal production units with a CIPU contract are discussed more in detail in section 3.2.1.3.

For non-CIPU thermal production, last year, an extensive analysis was done to identify the main drivers for their production profile. It was shown that the output of these units (green house CHP's, public building heating CHP, process heating ...) was closely correlated to the outside temperature. Additionally, very little difference in behaviour was found when looking at fuel type (biomass, waste, gas ...). Therefore, these units were combined into a single, more resilient, category with a temperature-dependant production profile. For this year's analysis, the same approach will be applied for the non-CIPU thermal units.

3.2.1.3 Thermal production with a CIPU contract

Installed capacity of the thermal production with a CIPU contract

The installed capacity of the Belgian thermal production fleet with a CIPU contract will be consolidated by Elia and the FPS Economy based on the information provided by the producers to the Federal Minister of Energy, the FPS Economy, the CREG, and Elia as prescribed by the law.

The hypothesis used with regards to installed capacity of **nuclear** electricity production will be aligned with the law accepted by the Belgian government concerning the nuclear phase out (latest version).

³ CIPU: Contract for the injection of Production Units. The signatory of the CIPU contract is the single point of contact at Elia for aspects of the management of the production unit injecting electricity into the high-voltage grid. The CIPU contract serves as the basis for the provision of other reserve power and the activation by Elia of such reserve power.

In line with the modified Belgian law on the nuclear phase out, it is assumed that all seven nuclear reactors (5919 MW) are operational for the whole length of the studied horizon.

Modelling approach

Thermal units under CIPU contract are modelled as individually dispatchable units. Additionally, more complex technical characteristics, such as outage rates, must run obligations, minimum up & down times are taken into account.

Availability of the thermal production with a CIPU contract

The individual availability of each CIPU unit is determined by a probabilistic draw for each 'Monte Carlo' year, based on historical availability rates. This way, a very high set of different availabilities can be drawn for each unit to be used in the simulations.

The analysis takes into account two types of unavailability for the CIPU production units:

- **Planned unavailability**

For 2020, a maintenance planning will be available at the start of the analysis. This will be incorporated into the model for winter 2020-21. For the subsequent winters 2021-22 and 2022-23, no planned outages information is available, therefore, no maintenance will be considered in the course of those winters.

- **Unplanned unavailability**

On top of the planned unavailability this study will take into account unplanned or forced unavailability. Each year, the analysis is updated for each production type (e.g. CCGT, gas turbine, turbojet...), based on the historical unplanned unavailability incorporating the latest data. These updated unplanned unavailability rates will be communicated in the input consultation of this summer.

In previous analysis, the frequency at which unplanned outages happen was also studied. For unavailability with a limited duration (i.e. intra-day outages), the balancing reserves can be used. Therefore, these outages do not have to be taken into account in the calculation of the necessary volume of strategic reserve.

Furthermore, "low probability, high impact events", as observed during the last winters, need to be considered as a sensitivity on Belgian and French nuclear availability for the entire winter in Belgium.

3.2.1.4 Hydroelectric power stations

The Belgian power system has two types of hydroelectric power stations:

- Pumped-storage units;
- Run-of-river units.

Belgium has ten **pumped-storage** units, six at the Coe power station and four at the La Plate Taille power station. The total installed turbinning capacity amounts to 1308 MW, with the combined storage capacity equalling approximately 5800 MWh. Pumped-storage units are typically used to provide ancillary services, and notably the Black-start service. Therefore, the total reservoir capacity used for economic dispatch in this analysis is de-rated by 500 MWh. The available reservoir capacity for economic dispatch is therefore equal to 5300 MWh.

In the ANTARES model, the ten Belgian pumped-storage units will be modelled individually which allows taking into account planned and forced outages on these units. The model determines the dispatching of the units using a daily cycle, taking into account the hourly electricity price. When the model encounters periods of structural supply shortage (with prices reaching up to 3000 €/MWh), the pumped-storage units will be used at maximum capacity. In case the supply shortage lasts for longer periods of time, the model will dispatch the pumped-storage units in order to flatten peaks in the electricity use.

Run-of-river will be taken into account in the model by using 33 historical profiles relevant for the winter period. Elia will update the installed capacity of the run-of-river power stations taking into account the information received from the FPS Economy.

3.2.1.5 Balancing reserves

In the context of its legal obligations, Elia is obliged to contract ancillary services to ensure a secure, reliable and efficient electricity grid [5]. As part of the ancillary services, the balancing reserves are agreements with certain producers and consumers to increase or decrease production or demand of certain sites when needed. Using the balancing reserves, Elia can restore the balance between production and demand when an imbalance occurs. Such imbalances can be caused for example by the unforeseen loss of a production unit or renewable forecasting errors.

Since it has to be possible to deploy the balancing reserves to restore deviations independently from the strategic reserve, the volume contracted on production capacity for frequency containment reserves and frequency restoration reserves is taken into account in the simulations as a reduction of available capacity to cope with adequacy (the reserve requirements for BRPs that have production units which a capacity larger than the standard production unit capacity is also included). Based on the latest available volume report of the balancing reserves, an update of the required amount of reserves to be used in the context of this study will be included.

3.2.2 Hypotheses on the Belgian electricity demand

3.2.2.1 Process for constructing demand curves

The hourly total electrical load is forecasted for the next three winters. This is done for all the simulated countries. The construction process can be divided in 3 steps as shown in Figure 3.




Figure 3

What is the total electrical consumption ('Total load')?

The total electrical consumption takes into account all the loads on the Elia grid and all the loads on the distribution grid (including losses). Given the fact that quarter-hourly measurements are rare on the distribution grids, this load is estimated with a combination of computations, measurements and extrapolations.

What are the differences with the Elia consumption ('Elia grid load')?

The Elia-grid load is a calculation based on injections of electrical energy into the Elia grid. It incorporates the measured net generation of the (local) power stations that inject power into the grid at a voltage of at least 30 kV and the balance of imports and exports. Generation facilities that are connected at a voltage of less than 30 kV in the distribution networks are only included if a net injection into the Elia grid is being measured. The energy needed to pump water into the storage tanks of the pumped-storage power stations connected to the Elia grid is deducted from the total.

Decentralised generation that injects power at a voltage less than 30 kV into the distribution networks is not entirely included in the Elia-grid load. The significance of this last segment has steadily increased during the last years. Therefore Elia decided to complete its publication with a forecast of the total Belgian electrical load.

The Elia-grid comprises networks of at least 30 kV in Belgium plus the Sotel/Twinerg grid in the south of Luxembourg.

How is the consumption of the Sotel/Twinerg in Luxembourg taken into account?

The Elia grid includes grids with voltages of at least 30kV in Belgium but also in the grid of Sotel/Twinerg in the South of the Grand Duchy of Luxembourg. In this study the total load of Belgium excludes the consumption of the Sotel/Twinerg grid. This consumption is modelled as a separate load connected to Belgium. More information can be found in section 3.3.5.

What is published on Elia's website?

Two load metrics can be found on Elia's website: Elia grid load and Total load.

The Elia grid load and the total load as published on Elia's website include the load of the Sotel/Twinerg grid (this is not the case for the total load calculated in this study). The full explanation can be found on the website [6]

3.2.2.2 Growth in total Belgian load

The first step consists in forecasting the yearly total electrical demand for a given country. After the normalisation of the total demand for temperature, an estimation of the growth of the total demand is taken. Yearly normalised demand fluctuations are mainly due to economic indicators (GDP, growth of population, industry...), energy efficiency improvements and electrification (new usage of electricity, switching between energy sources). Over the past few years, Elia has worked with the IHS MARKIT consultancy bureau as the data provider for the domestic demand growth rate. Elia is confident that this approach remains valid for this year's volume assessment.

However, Elia has also, very recently, started building its own demand forecasting framework. If by this summer the framework shows enough promise, Elia will hold a workshop at the end of August with the stakeholders and will evaluate whether to apply it to this year's strategic reserve volume determination.

Overview of the methodology applied by IHS MARKIT

IHS MARKIT's electricity demand outlooks are built on a combination of historical data, weather correction factors, IHS Markit long term demand (hourly shape) and pe0ak demand outlooks and forecast daily temperature profiles. Total final demand is divided into five sectors: residential, commercial, industry, transport and agriculture. Each sector is modelled separately. When a sector has weak link between economic performance and its energy demand, a bottom-up approach is used. For example, in the residential sector sales of heat pumps, refurbishment rates of existing homes, energy efficiency gain in electrical appliances, are all taken into account to construct an extrapolated future demand profile. When the sector has a strong link between economic performance and its demand, multi dimension regression analysis is used. Here, the demand is compared to GDP, employment rates, sector output ...

The modelling for electricity demand is undertaken as part of an energy wide forecasting model that explicitly takes into account the competition between different energy sources. Always an important feature of demand modelling, this cross-fuel approach is expected to become even more relevant in the future as Europe's climate targets increase electrification of end-use demand. A large share of this electrification is expected to come from substitution of other fuels with electricity.

When comparing the results of the IHS demand growth forecast with other organisations like the IEA or the European commission, it is clear that IHS predicts lower compound annual growth rates in the long term. In the short term IHS Markit growth rates are very similar to the EC 2016 reference scenario prediction [7].

3.2.2.3 Load profile normalized for temperature

Once the total yearly normalised demand is forecasted for the future years, an hourly consumption profile can be constructed. In order to compute it, a normalised profile of the Belgian consumption is taken.

This so-called "normalized profile for temperature" should be understood as the typical profile of the expected demand for every hour of the year, corresponding to temperatures in normal climate conditions, so-called "normal" temperatures. Normalized profiles are constructed by statistical analysis of historical data on demand and on the average historical temperatures observed.

The growth identified in step 1 is applied to this normalised profile in order to match the total demand forecasted. The hourly normalised profile used for the analysis of winter 2017-18 is shown in Figure 4 by means of example.




Figure 4

From Figure 4 one can clearly see the effects of week/weekend and the holiday effect (around New Year) on the consumption. Based on that profile, the peak demand is observed the second week of January. This peak demand is only valid for a normalised temperature. Applying temperature sensitivity to this profile will lead to very different hourly profiles with higher peak consumptions in case of lower temperatures.

The consumption of pumped-storage units is not taken into account in this profile. The dispatching of these units is optimised by the model, and their consumption comes on top of this profile.

3.2.2.4 Sensitivity of the load to temperature

The last step consists in applying the temperature sensitivity to the hourly normalised profile. For each of the 34 historical climate years, an hourly profile for consumption is created. This will allow the analysis to be carried out using 33 different hourly load profiles for the analysed winters.

Up until today, this operation was performed using an application developed by ENTSO-E. This application, applied in many studies such as MAF, PLEF, etc., uses a cubic relationship between temperature and load, in contrast to older, linear models.

Recently, ENTSO-E has developed, a new way of creating the final load profiles for the various climatic years for all European countries. This new piece of software is called TRAPUNTA. In order to keep consistency with the European adequacy assessments, Elia will incorporate it into this analysis, provided this method is tried & tested in due time. At the time of writing TSO feedback is being collected by ENTSO-E before the go-live.

3.2.3 Demand response

As agreed in the context of the "Implementation Strategic Reserve" task force during 2017, and to take into account the future evolutions of the Market Response volumes, quantification of the

volume will be updated yearly, in order to obtain most 'up-to-date' representative results every year. This assessment will therefore be rerun, this time including EPEX spot data from the past winter, as well as the most recent ancillary services volumes. [8]

For a more in depth explanation on the market response evaluation, please refer to Appendix D.

3.3 Hypotheses for the other simulated countries

This section elaborates on the hypotheses that will be used for the other simulated countries. For France, The Netherlands, Germany, Great Britain and Luxembourg these assumptions are constructed through detailed analysis and bilateral contacts. Consistency with European adequacy studies [9] is ensured as well.

3.3.1 France

The hypotheses for France that will be used in this study will be based on the most recent adequacy report [10] issued by the French transmission system operator (RTE). RTE uses the same probabilistic method as well as the same tool (ANTARES) to simulate the European electricity market. As the French adequacy is of the uttermost importance to the results of this analysis, assumptions and methods are aligned through frequent bilateral contacts between Elia and RTE.

3.3.2 The Netherlands

The assumptions that will be used in this study for the Netherlands will be collected through bilateral contacts with the Dutch TSO TenneT. They will be in line with those used in the latest Dutch national adequacy study [11].

3.3.3 Germany

The assumptions that will be used in this study for Germany are a compilation of bilateral contacts with German TSOs, market data from transparency platforms (EEX, ENTSO-E), adequacy studies performed by the German regulator [12] and other various data (e.g. NEP).

3.3.4 Great-Britain

For Great-Britain, the assumptions that will be used in this study will be based on the 2018 version of the Future Energy Scenarios [13]. The FES are constructed on a yearly basis by the British TSO National Grid, describing a set of scenarios up to 2050. These scenarios are subject to a wide stakeholder consultation, and are used amongst others in the National Grid Electricity Capacity Report (ECR) and the National Grid Network Options Assessment (NOA).

One of the four FES 2018 scenarios will be chosen to be used in this analysis upon the publication of the FES documents. For the period 2020-21 up to 2022-23 however, the variations amongst scenarios might be relatively small. Therefore the choice of this scenario will not be very impacting on the results of this analysis.

3.3.5 Luxembourg

The modelling of Luxembourg is important for Belgium as a part of the country is included in the Belgian control area (this is indicated as the 'LUB' zone in Figure 5). The 'LUB' zone includes only consumption which is taken into account as part of Belgian load. The 2 other electrical zones of Luxembourg are:

- a part connected to France (LUF in Figure 5) that only contains load;
- a part connected to Germany. This zone includes all the hydro, wind, PV as well as the remaining load of the country;




Figure 5

3.3.6 Other countries modelled

In total twenty countries will be modelled in this study. For each country, hypotheses will be made in terms of non-renewable generation facilities, demand and renewables. Most of these hypotheses will be taken from pan-European adequacy studies such as the 'Mid Term Adequacy' forecast, ENTSO-E transparency platform, ENTSO-E statistics, bilateral contacts, PLEF adequacy study, national reports and other statistics.

3.4 Hypotheses for interconnectors

In the latest adequacy studies performed by Elia, the interconnections have been modelled as they are used in the day-ahead market coupling mechanism. France, Netherlands, Germany, Austria, and Belgium are therefore modelled using the flow-based (FB) methodology. Thanks to the more detailed description of the network within the flow-based methodology, use of the interconnections and price convergence can be improved without compromising the level of security of supply.

For countries outside of the CWE FB zone, the interconnectors will be modelled on the basis of values of the bilateral commercial exchange capacity between countries. The import and export capacity available for commercial exchanges, also referred as Net Transfer Capacity (NTC), is calculated by the Transmission System Operators (TSOs). The NTC values are calculated based on the technical characteristics of the lines and the internal limitations of each TSO.



Figure 6

3.4.1 Flow-based domains for the CWE region

Belgium is currently electrically interconnected to France, the Netherlands, Great-Britain (through Nemo Link®) and Luxembourg (part of the Elia control zone for the Sotel/Twinerg grid).

By winter 2020-21 also the ALEGrO HVDC interconnector with Germany will be operational.

Furthermore, the domains are impacted by the bidding zone configuration. This was recently modified following the DE/AT split.

To fully assess the adequacy situation of Belgium, given these changes, a short-term flow-based modelling process has been set up, which is described more in detail in Appendix C. Since flow-based is a European matter, this framework is operated by the CWE flow-based expert group.

Provided that new SPAIC domains are released in due time, Elia will incorporate these new domains into this year's assessment.

Additionally, the same systematic approach as used in previous assessments will be followed, linking specific combinations of climate conditions for wind and load with the representative flow-based domains to be considered in the simulations.

3.4.2 FB domain impact related to the evolution of the 380kV grid in Belgium

The following considerations regarding upcoming investments in Belgium's 380kV grid will be taken into account in the assessment of the volume for strategic reserve:

3.4.2.1 NEMO

The Nemo Link® HVDC connection came online early 2019. As was done last year, this interconnector with Great Britain will be taken into account for all winters in the assessment. This interconnector will be modelled as an NTC link.

ALEGrO


The planned HVDC interconnection with Germany (ALEGrO project [14]) has a target commissioning date in 2020.

Elia will be performing tests on the correct integration of the ALEGrO interconnector in its adequacy assessments. Implementation of ALEGrO in the FB domains requires addition of virtual HUBs in the PTDF – RAM calculation.⁴

Inclusion of ALEGrO in the FB modelling

Horizon 2020-21 & 2021-22

- Implementation of ALEGrO in FB domains requires addition of 2 virtual HUBs ALBE and ALDE in the PTDF – RAM calculation



3.4.2.2 IC BeDeLux project

The technical trial phase was performed to gain experience and to assess whether a significant adjustment of the technical parameters could be envisaged. Based on the results of the trial

⁴ PTDF – Power Transfer Distribution Factors; RAM – Remaining Available Margin

phase, projects partners concluded that these results do not allow significant adaptation of the technical parameters. Moreover as the previous SPAIC study showed a neutral impact on the regional welfare due to limited use of the interconnector, the project parties have decided that there will be no commercialisation of the interconnector [15].

3.4.2.3 AT-DE BZ split

Following a decision by the German and Austrian regulators, the split of the combined German – Austrian bidding zone into two different bidding zones took place in October 2018.

Since then historical domains are available for the CWE FB group to work with. Given that the SPAIC process delivers in time, Elia will incorporate the effect of the DE/AT split through the new domains into its adequacy assessment.

3.4.2.4 Evolution simultaneous import capacity restriction

From winter 2020-21 onwards, taking into account NEMO & ALEGrO and the additional realized investment in some specific reactive control means (capacitor banks), a simultaneous import capacity restriction of 6500 MW over all Belgian borders is defined and applied in capacity calculation. This limitation is applied to ensure adequate voltage regulation capability of the Belgian system at high import levels.

It is important to note that adequacy-related issues in Belgium mainly arise when both Belgium & France are in simultaneous scarcity. In these situations, the import levels that Belgium can obtain in the market do not reach 6500 MW. In other words, generally the binding CNEC in adequacy stress situations is not the external constraint.

3.4.2.5 HTLS upgrades (Avelin-Avelgem-Horta & Horta-Mercator)

The classic AMS conductors (Aluminium-Magnesium-Silicon) will be replaced by high-performance HTLS conductors (High Temperature Low Sag) for these parts of the 380kV grid. The latter type has a higher transport capacity and sags less. Evolutions of the HTLS deployment will be followed in the assessment for each of the considered winters. Changes to the historical domains will be applied when relevant in order to consider the increase in capacity that these upgrades will bring.

3.4.3 HVDC outages

Availability of the HVDC system elements will be included in the simulation as random outages.

Random outages are represented by the parameter Outages Rate (OR), which in this case defines the annual rate of outage occurrences of HVDC lines. Those situations are simulated by random occurrences of outages within the probabilistic Monte Carlo scheme, while respecting the annual rate defined.

An unavailability rate for each HVDC interconnector of 6% will be used as benchmark value, following the ENTSO-E's MAF report. It is noted that 6% is only the average value, but assuming the same unavailability for each interconnector is a pragmatic approach and would not overestimate the unavailability of HVDC links. It should be noted that this value includes both unexpected outages of HVDC lines as well as planned outages of interconnectors. This assumption is relevant for the adequacy assessment, since the focus is on considering the impact of availability (planned or unplanned) of interconnectors on adequacy.

Additionally, it should be noted that new assets do not necessarily show lower outage rates. A good example of this is bathtub curve, which is widely used in reliability engineering as a model for asset reliability by age. This curve starts off with an early failure section.

3.4.4 Fixed commercial exchange capacity on the borders of the countries outside the CWE region

Assumptions

Countries outside the CWE region and the interconnections between the countries of the CWE region and the rest of Europe are modelled using a commercial exchange capacity also referred to as Net Transfer Capacities (NTC). These values are from studies conducted within ENTSO-E and from bilateral and multilateral contacts and take into account grid investments planned for future winters.

The NTC's also vary from day to day depending on the conditions of the network, availability of lines and other network elements. As such they are provided by TSOs on annual and monthly values and are regularly updated on weekly and daily basis. In this study, a single reference is used for a particular interconnection in a certain direction throughout the simulated period.

Historical exchange capacities can be found on the respective TSOs website and transparency platform of ENTSO-E [16].

Exchange with the non-modelled countries

No exchanges between the countries that are modelled and those that are not modelled are considered. This is a conservative assumption because these exchanges do exist and could contribute to power supply of the CWE region. The modelled countries besides the CWE countries⁵ are: Spain (ES), Portugal (PT), Great-Britain (GB), Ireland (IE), Northern Ireland (NI), Switzerland (CH), Slovenia (SI), Czech Republic (CZ), Slovakia (SK), Hungary (HU), Norway (NO), Denmark (DK), Sweden (SE) and Poland (PL).

Since the geographical perimeter considered around Belgium is significant, the effect of the above mentioned assumption has little impact on the adequacy situation in Belgium.

⁵ Germany (DE), France (FR), Belgium (BE), The Netherlands (NL), Luxembourg (LU) and Austria (AT)

Appendix A Legal framework and process

A.1 Process

Article 7bis of the Law of 29 April 1999 concerning the organisation of the electricity market ('Electricity Act') includes the following timetable for determining the volume of the strategic reserve (also see Figure 7):

The following text is a translation from the Electricity Act (only available in French and Dutch). Elia assumes no responsibility for the accuracy of the translation of these legal articles and, in case of any doubt, the original text prevails over these translations. This applies also to other translations from the Electricity Act further in this report.



Art.7bis – 7quater

- **Before 15 October:** DG Energy⁶ provides the grid operator with any relevant information for the probabilistic assessment.
- **By 15 November:** the grid operator carries out a probabilistic assessment which is submitted to DG Energy.
- **By 15 December:** DG Energy provides the Minister with an opinion on the need to constitute a strategic reserve for the following winter. If the opinion concludes that such a need exists, a volume for this reserve is suggested, expressed in MW. As the case may be, DG Energy may issue an opinion recommending the constitution of such a reserve for up to three consecutive winters. If the suggested volumes relate to two or three consecutive winters, this proposal will determine for the last (two) winter(s) the minimum required levels, which may then be revised upwards in the subsequent annual procedures.
- **One month after receiving DG Energy's opinion:** the Minister may instruct the grid operator to constitute a strategic reserve for a period of one to three years starting from the first day of the next winter period and determines the size of this reserve in MW. The Minister notifies CREG of this decision. The decision, the grid operator's assessment and DG Energy's opinion are published on DG Energy's website.




Figure 7

The Electricity Act also includes the following **aspects** that need to be borne in mind for the **probabilistic assessment** regarding the security of Belgium's supply for the winter ahead:

⁶ Directorate-General for Energy of the Federal Public Service (FPS) Economy



Art.7 bis §4

- the level of security of supply that needs to be achieved;
- the generation and storage capacities that will be available in the Belgian control area, based on such factors as planned cases of decommissioning in the development plan referred to in Article 13, and the communications received pursuant to Article 4bis;
- electricity consumption forecasts;
- the possibilities for importing electricity, given the capacities of the interconnectors available to Belgium, and, as the case may be, an assessment of the availability of electricity in the Central West European electricity market;
- The grid operator may, subject to appropriate justification, complement this list with any other item deemed useful.

A.2 Legal notice period for production facility closure

In Article 4bis of the Electricity Act, the ultimate date is set by which a production facility can announce its temporary or permanent closure. This date is set to 31 July of the year preceding the effective date of the temporary or permanent closure.



Art.4bis, §1

Legal notice period for production facility closure according to Article 4bis (translation)

'Art. 4bis. § 1. In order to ensure the electricity security of supply and the safety of the grid, the unscheduled permanent or temporary closure of an electricity generation facility must be reported to the Minister, to the commission and to the transmission system operator by 31 July of the year preceding the effective date of the temporary or permanent closure. A temporary closure can only occur after 31 March of the year following the notification referred to in paragraph 1.

A permanent closure can only occur after 30 September of the year following the notification referred to in paragraph 1. A notice of closure is required for each installation for power generation connected to the transmission grid, whether a prior individual authorization in accordance with Article 4 was given or not.

§ 2. On the recommendation of the commission and of the transmission system operator, the King may determine the notification procedure in § 1, in particular as regards the form and modalities of the notice.

§ 3. No permanent or temporary closure, regardless of whether it is scheduled or not, may take place during the winter period.

§ 4. The provisions of this Article shall not apply to the units mentioned in the Act of 31 January 2003 on the gradual exit from nuclear energy for purposes of industrial electricity generation.'

A.3 Adequacy criteria

The Electricity Act describes the level of security of supply (adequacy) that needs to be achieved for Belgium. In the absence of harmonised European or regional standards, this level is determined by a **two-part Loss of Load Expectation (LOLE)** criterion (see Figure 8). The model Elia uses for the probabilistic assessment enables the calculation of both indicators.

LOLE < 3 hours

LOLE95 < 20 hours

Figure 8

- **"LOLE⁷"**: statistical calculation used as a basis for determining the anticipated number of hours during which it will not be possible for all the generation resources available to the Belgian electricity grid to cover the load⁸, even taking into account interconnectors, for a statistically normal year.
- **"LOLE95"**: statistical calculation used as a basis for determining the anticipated number of hours during which it will not be possible for all the generation resources available to the Belgian electricity grid to cover the load, even taking account of interconnectors, for a statistically abnormal year⁹.

In addition to the above indicators, which only pay attention to the number of hours when a full energy supply cannot be provided, the model used by Elia also gives an indication of the scale of the energy shortage (Energy Not Supplied or 'ENS') during these hours and the probability of a loss of load situation occurring (Loss Of Load Probability or 'LOLP'):

- **"ENS"**: the volume of energy that cannot be supplied during the LOLE hours. This yields ENS (for a statistically normal year) and ENS95 (for a statistically abnormal year), expressed in GWh per year.
- **"LOLP"**: the probability that at a given time a loss of load situation will occur, expressed in %.

The needed strategic reserve capacity is calculated based upon the assumption of 100% availability in order to fulfil the legal criteria in terms of security of supply. No distinction is made between demand reduction (SDR¹⁰) and generation capacity (SGR¹¹):

- In the case of **SGR**, 100% availability assumption means that the strategic reserve will never be under maintenance during the winter, nor will it incur an unplanned outage. This differs from the modelling of the units available in the market (see section 2.1.1).

⁷ LOLE: Loss Of Load Expectation

⁸ Load: Demand for electricity

⁹ The probability of occurrence of a statistically abnormal year is 1 in 20 (95th percentile).

¹⁰ SDR: Strategic Demand Reserve

¹¹ SGR: Strategic Generation Reserve

- In the case of **SDR**, 100% availability assumption means that the strategic reserve can be called upon at any time throughout the winter, without any restriction in terms of number or length of activation.

The assumption of 100% availability of the SGR is an important one, especially in the case of large volumes, given that a cold spell (when the need for strategic reserve is at its greatest) may result in start-up problems for old units. The assumption of 100% availability of the SDR is also an important one as restrictions on the number and the length of activations are included in the contracts.

Appendix B Proposed methodology

The volume of strategic reserve is determined in three steps. The **first step** in determining the strategic reserve volume for a given winter consists of **establishing various future states** in which there is uncertainty surrounding the generation facilities and the demand for electricity. Each future state is established based on historical data regarding meteorological conditions (wind, sun, temperature, precipitation) and power plants' unavailability.

The **second step** involves **identifying periods of structural shortage**, i.e. times when the generation of electricity is insufficient to meet demand. To this end, an hourly market simulation is carried out using a market model for the winter period (from November until March inclusive). The market simulation is done for every future state established in the first step. This model is also used by RTE¹² in its adequacy studies for France, by other TSOs in the PLEF regional adequacy studies and in the ENTSO-E Mid-Term Adequacy Forecast report.

The **last step** is to determine the strategic reserve volume considered necessary to **meet the legal adequacy criteria**. An iterative process is used to determine the total strategic reserve volume.

This chapter takes an in-depth look at the various steps and the tools that are used.



Figure 9

B.1 Definition of future states

A probabilistic risk analysis requires extrapolation of a large number of future states. Each of these states gives rise to an assessment of the number of hours of structural shortage. These various states make it possible to evaluate the adequacy indicators.

B.1.1 Random variables and time series

The key variables in this study can be subdivided into two categories: climatic variables and the availability of the generation facilities.

There are mutual correlations between the **climatic variables**. These correlations are captured by use of synchronized hourly time series, namely:

- hourly time series for **wind energy generation**;
- hourly time series for **PV¹³ solar generation**;
- daily time series for **temperature** (these can be used to calculate hourly time series of **temperature sensitive electricity consumption**);
- monthly time series for **hydroelectric power generation**.

¹² RTE: Réseau de Transport d'Electricité, the French transmission system operator

¹³ PV: photovoltaic

However, the above mentioned variables are assumed not to be correlated with the others, namely:

- Parameters relating to the **availability of the thermal generation facilities and relevant HVDC interconnectors** on the basis of which samples can be taken regarding power plants' and HVDC' unavailability, due to forced outages.
- Seasonal constrains of forced outages or maintenance schedules are considered but no explicit correlation is assigned of these schedules and the climatic variables above mentioned.




Figure 10

The simulations performed in this study disregard the following events which may have an impact on generation adequacy (this list is not meant to be exhaustive):

- long-term power plant unavailability (sabotage, political decisions, strikes, maintenance due to inspections, bankruptcy, terrorist attacks, etc.). Those events if quantified are considered via sensitivities;
- interruption of the fuel supply for the power plants;
- extreme cold freezing water courses used for plant cooling;
- natural disasters (tornadoes, floods, etc.).

B.1.2 'Monte Carlo' sampling and composition of climate years

These variables are combined so that the correlation between the various renewable energy sources (wind, solar, hydroelectric) and the temperature remains. They are both **geographically correlated** and **time-correlated**.

Therefore, the climatic data relating to a given variable for a specific year will always be combined with data from the same climatic year for all other variables, with this applying to all the countries involved.

In contrast, for **power plant availability, random samples** are taken by the model, by considering the parameters of probability and length of unavailability (in accordance with the 'Monte Carlo' method). This results in various time series for the availability of the thermal facilities for each country. This availability differs in each future state.



Figure 11

The Monte Carlo method

The '**Monte Carlo**' method is used in various domains, among them **probabilistic assessments of risks**. The name of this quantitative technique comes from the casino games in Monaco, where the outcomes for each game were plotted in order to forecast their possible results following a probability distribution translating the probability of winning.

In this same way, when a forecasting model is built, different assumptions are made translating the **projections** of the future system states for which expected values have to be determined. In order to do this, the parameters linked to the system state, characterised by inherent **uncertainty**, are determined and for each of these an associated range of values through a specific distribution function is defined.

The **deterministic approach** considers that a unique state is associated with each system input. This means that the same output will provide independently the number of times the simulation is performed since the same input is used.




Figure 12

B.1.3 Number of future states


The number of future states that need to be calculated by the model to ensure the convergence of the results depends, among other things, on the variables, the simulated perimeter and the variability of the generation facilities. For the volume determination of strategic reserve the focus is on the two indicators determined by law, namely the average LOLE and the 95th percentile for the LOLE (LOLE95). The quantification of these two parameters has to converge to a desired level of accuracy which guarantees reliable results. *Convergence refers to the fact that average LOLE and LOLE95 settle into a value which does not change significantly when the number of N future states considered is further increased.* Depending on the scenario and level of adequacy lower or higher amount of 'Monte Carlo' years can be simulated.

Between 400 and 800 future states are required to achieve convergence of the indicators. This means that all 33 climatic winters will be simulated the necessary amount of times, with the availability of the thermal facilities being different in each of the simulated future states.

Combining the results of all these future states yields the distribution of the number of hours of structural shortage.

B.2 Identification of periods with structural shortage

Each future state is assessed on an hour-by-hour basis by simulating the European electricity market. The periods of structural shortage are the hours when there is insufficient generation capacity to cover a country's consumption. Figure 13 gives an example of how consumption is covered by the available generation and import facilities for every hour of the week. If, for a given hour, generation and import capacity falls even by only 1 MW short of the capacity required to meet demand, this corresponds to one hour of structural shortage. Figure 13 also presents the energy that cannot be supplied by the generation facilities.



Note that this example is only illustrative. Furthermore:

- The operational reserve was subtracted from the gas units
- The market response (decrease in demand by consumers in response to market prices) is not considered in this example

Figure 13

B.2.1 Input and output of the market model

To simulate the European electricity market, a number of assumptions and parameters have to be established.

The **key input data** for each country are:

- the hourly **consumption profile** and associated **thermosensitivity**;
- the installed capacity of the **thermal generation facilities** and the **availability parameters**;
- the installed **PV, wind** and **hydroelectric capacity** and associated **hourly production profiles based on the climate years**;
- the **interconnections** (by using the flow-based methodology or fixed exchange capacity between countries (NTC method)).

These data are introduced by means of hourly or monthly time series or are established for a whole year.

The power plants' economic dispatch is of little importance to the adequacy assessment: in periods of structural shortage, all of the available generation facilities will be taken into account, operating at their maximum capacity. However, the assessment also takes into consideration the power plants' marginal costs (see Figure 14). Using the economic dispatch enables the pumped-storage power plants and hydroelectric reservoirs to be appropriately modelled (see section 3.2.1.4).

Economic availability depends on the generation capacity available for the hour in question. The price in any given hour is determined by the intersection between the curve for supply (ranking of the power plants) and demand. The demand is considered inelastic in this context, at first. Additionally, market response to high prices is also taken into consideration.




Figure 14

The **output of the model** that is assessed in this study consists of hourly time series showing the **energy shortage** for each country. These series can be used to deduce various indicators:

- the number of hours of structural shortage;
- the capacity surplus or shortage;
- the number of activations of the strategic reserve;
- Energy Not Served (ENS).

Figure 15 represents a schematic overview of the model's input and output.




Figure 15

B.2.2 Model used to simulate the electricity market

The market simulator used in the scope of this study is ANTARES¹⁴, a sequential 'Monte Carlo' multi-area simulator developed by RTE whose purpose is to assess generation adequacy problems and economic efficiency issues. This power system analysis software is characterised by these following specifications:

- representation of several interconnected power systems through simplified equivalent models. The European electrical network can be modelled with up to a few hundred of region-sized or country-sized nodes, tied together by edges whose characteristics summarise those of the underlying physical components;
- sequential simulation with a time span of one year and a time resolution of one hour;
- 8760 hourly time series based on historical/forecasted time series or on stochastic ANTARES generated times-series;
- for hydro power, a definition of local heuristic water management strategies at monthly and annual scales;
- a daily or weekly economic optimization with hourly resolution

This tool has been designed to address:

- 1) generation/load balance studies (adequacy);
- 2) economic assessment of generation projects;
- 3) economic assessment of transmission projects.

A large number of possible future states can be extrapolated by working with historical or simulated time series, on which random samples are carried out in accordance with the 'Monte Carlo' method. The main process behind ANTARES is summarised in Figure 16.

¹⁴ ANTARES: A New Tool for Adequacy Reporting of Electric Systems




Figure 16

The model is used in many European projects and national assessments such as the PLEF adequacy study, the RTE French Generation Adequacy Report, the TwenTies project, e-Highway2050, ENTSO-E's TYNDP¹⁵, ENTSO-E's MAF and many more;

Unit commitment (UC) and economic dispatch based on short run marginal costs

For each 'Monte Carlo' year, ANTARES calculates the most-economic unit commitment and generation dispatch, *i.e.* the one that minimises the generation costs while respecting the technical constraints of each generation unit. The dispatchable generation (including thermal and hydro generation) and the interconnection flows constitute the decision variables of an optimization problem whose objective function is the minimization of the total operational costs of the system. The optimization problems are solved with an hourly time step and a weekly time-frame, making the assumption of perfect information at this horizon but assuming that the evolution of load and RES is not known beyond. 52 weekly optimization problems are therefore solved in a row for each 'Monte Carlo' year. The modelling adopted for the different assets of the system is briefly described below.



Grid topology

The topology of the network is described with areas and links. (In this study, one area represents a country). It is assumed that there is no network congestion inside an area and that the load of an area can be satisfied by any

¹⁵ TYNDP: Ten Year Network Development Plan

local power plant.

Each link represents a set of interconnections between two areas. The power flow on each link is bounded between two Net Transmission Capacity (NTC), one for each direction.

Moreover, in ANTARES, some binding constraints on power flows can be introduced. They are in the form of equalities or inequalities on a linear combination of flows. They will for instance be used to model flow-based domains in the CWE market-coupling area.



Wind and solar generation

Wind and solar generation are considered as non-dispatchable and come first in the merit order. More precisely, as other non-dispatchable generation, they are subtracted to the load to obtain a net load. Then, ANTARES calculates which dispatchable units (thermal and hydraulic) can supply this net load at a minimal cost.



Thermal generation

For each node, thermal production can be divided into clusters. A cluster is a single or a group of power plants with similar characteristics. For each cluster, besides the time series of available capacity, some parameters necessary for the unit commitment and dispatch calculation will be taken into account by ANTARES:

- the number of units and the nominal capacities, defining the installed capacities;
- the cost, including marginal and start-up cost;
- the technical constraints for minimum stable power, must-run, minimum up and down durations.

Concerning the technical constraint for must-run, 2 values can be put: a value considered only if the plant is switched on (minimum stable power) and a value that, if higher than 0, forbids the plant to be switched off in the dispatch (must-run). The latter one is given on an hourly step time base, whereas the first one is a single value for the whole simulation.



Hydro generation

Three categories of hydro plants can be used:

- **Run-of-river (RoR)** plants which are non-dispatchable and whose power depends only on hydrological inflows;
- **Storage plants** which possesses a **reservoir** to store and control the use of water and whose generation depends on inflows and economic data;
- **Pumped-storage station (PSP)** whose power depends only on economic data.

Run-of-river generation is considered as **non-dispatchable** and comes first in the merit order, alongside with wind and solar generation.

For storage plants, the annual or monthly inflows are first split into weekly amounts of energy. The use of this energy is then optimised over the week alongside the other dispatchable units. Each hydro unit can generate up to its

maximum capacity.

Pumped-storage plants have the possibility to pump water which will be stored and turbined later on. It is operated on a daily or weekly basis, depending on the size of its reservoir. ANTARES optimises the operation of PSP alongside the other dispatchable units while making sure that the amount of energy stored (taking into account the efficiency ratio of the PSP) equals the amount of energy generated during the day/week.



Demand response

One way of modelling **demand response** in the tool is by using very expensive generation units. Those will only be activated when prices are very high (and therefore used only after all the other available conventional generation capacity is dispatched). This is the way this study aims to replicate the impact of market response. Limitations on the number and duration of the activations per day and week of such demand response can be set on this capacity.

B.3 Evaluation of the strategic reserve volume or margin

If the legal criteria are not met following evaluation of the considered 'Monte Carlo' years, extra volume of capacity is needed. On the other hand, if the simulation without additional volume is already compliant with the legal criteria, the margin on the system will be reported.

An iterative process will be used to evaluate the total strategic reserve volume or margin (see Figure 17). The extra volume or margin will be increased in blocks of 100 MW until the legal criteria are met. After each increase, the market model repeats the simulation of 400 to 800 future states.




Figure 17

Appendix C Flow-based method applied for the CWE-zone

C.1 Why use a flow-based methodology?

To date, most market simulations that calculate the economically optimal energy dispatch ensuring the balance of the demand and supply in interconnected systems, are mainly based on fixed values of commercial exchange capacities at the borders.

Market simulation tools and methods are being developed to allow for various distribution factors and integration of various flow-based domains for each hour of the year, which makes it possible to achieve market modelling results closer to the ones observed in flow-based market coupling.

As Belgium is in the centre of the CWE zone, the country's import and export capabilities at the day-ahead timeframe are currently entirely defined by the flow-based methodology used at regional level for the day-ahead markets. Belgium's net position is therefore linked to the net position of the other countries in the CWE zone and to the flow-based domain defining the possibilities of energy exchange between those countries. It is therefore critical to replicate market operation in order to quantify the country's loss of load expectation.

The flow-based method allows to properly take into account interactions between market outcomes and the transmission grid. For instance, at moments when both France and Belgium are in structural shortage, the `import saldo` of Belgium can be significantly reduced if large flows are running through Belgium towards France. The use of the flow-based method in this assessment makes it possible to calculate the likelihood and impact of a reduced `import saldo` on adequacy as a result of market conditions in neighbouring countries.

Figure 18 shows the flows between four fictitious zones when 100 MW is exchanged from zone A to zone D. The resulting flows follow the path of least impedance. This will result in flows between zones not participating in this energy exchange (zones B and C for example).




Figure 18 Example: Commercial exchanges between two countries can generate physical flows through other borders (resulting physical flows from an energy exchange of 100 MW between 2 zones).

Interconnection capacity, import capacity, `import saldo` and net position

Available interconnection capacity considers a safe state (N-1) of the network in real operating conditions. Consequently, not all capacity can be released in advance.

This does not necessarily mean that maximum import capacity will be available in all cases as it is linked to total availability of the grid and without taking into account market conditions. If there are restrictions on the domestic or foreign grids or if the physical flows resulting from market conditions imply export at one of the borders or if energy abroad is not available, the maximum capacity might not be used fully. The actual usable capacity is called the **`import saldo`**.

Since exchanges are determined by market conditions (demand and supply in each country), Belgium's actual import depends on the situation of the European market. The country's net position is the sum of exports minus imports that are determined by market conditions (based on demand and supply curves).

Belgium is in the heart of the interconnected European grid. It is surrounded by France, the Netherlands, Great-Britain and Germany, which, depending on the situation of their respective grids and markets, can each import or export large amounts of electricity. Given the fact that the European electricity grid is meshed (like a spider web composed of many loops where electricity can flow via different paths), any transaction between two countries will flow partially through the grid of neighbouring countries and generate so-called 'non nominated physical flows'. For Elia, those flows are an uncertainty factor in the computation of the commercial exchange capacity with its neighbours. With the massive rise of renewable energy, mainly in Germany, this variability has increased significantly in the last years.

The flow-based methodology allows to better take into account the impact of trade exchanges between countries.

Maximum simultaneous import capacity on the AC grid

The simultaneous maximum import capacity of Belgium is the maximum power that the country can import under normal grid operation conditions, meaning without either planned or forced outages of the grid infrastructure (in Belgium and in the neighbouring countries) and without knowing the electricity flows in advance. This capacity depends on available resources for voltage regulation, short-circuit power, and inertia that are normally offered by the countries' internal production. It is an input into the flow-based domain calculation. In practice, the maximum possible simultaneous import capacity for Belgium as determined by the flow-based domain will also depend on seasonal effects, availability of the grid in Belgium and neighbouring countries, and market conditions. Due to unknown events that can take place at any moment, this capacity is given to the market with yearly, monthly, day-ahead and intraday portions.

For the analysis of winter 2020-21, a maximum import capacity via the AC grid will be considered in the simulations by considering the effect of the current planned investments, past observations and considerations regarding the operation of the Belgian grid.

In the future, reinforcements of the Belgian backbone grid and cross-border lines are planned as detailed in the latest Federal Network Development Plan 2020-2030.

The actual `import saldo` availability is subject to two essential conditions:

- market conditions must be favourable for import;
- network operating conditions must be in a normal state.

Regarding the specific market conditions, international flows may imply that the available import balance will be significantly lower than average in some hours. The flow-based modelling approach makes possible to take these effects into account.

C.2 How are flow-based domains established?

To fully assess the adequacy situation of Belgium, whilst taking into account the most recent knowledge about the grid & market structure, a short-term flow-based modelling process has been established. The steps of this process are discussed in the subsections below.

C.2.1 Selection of typical days

In the context of the SPAIC CWE flow-based expert group, a statistical analysis of the geometrical shapes of historical flow-based domains is performed. This data is taken from the FB CWE operational tool.

The historical days are clustered in families defined by the size of their 24 hourly domains, *i.e.* typically “large”, “medium” and “small” families of domains are clustered. Each typical day consists of 24 hourly domains (one for each hour).

- Small domains correspond to situations with a highly congested network and therefore with small values for the maximum power exchanges possible between the different market areas considered by the given domain (related to the small volume inside the domain).
- Large domains correspond to situations with a less congested network and therefore relatively higher values of maximum possible power exchanges between the market nodes considered by the given domain (larger volume).
- Then a typical day is the historical day within a given family or cluster of domains which provides the best representation of all the other days in the cluster.
- Flow-based domains being hourly, this typical day is selected by comparing its domain at every hour to the other day’s equivalent domain (at the same hour).

The result of this typical day selection process is a set of 12 typical days. These can be divided in 3 groups per season (summer, winter, midseason) each consisting of 4 typical days. These 4 are further divided into 1 representing the weekend- & holidays, and 3 representing the weekdays.

C.2.2 Modification of the input hypotheses for the typical days to account for new grid & market configurations

As a next step, and also in the context of the SPAIC CWE flow-based expert group, the data from the operational framework is then manually modified to account for changes in grid topology or market rules.

The flow-based domains considered are computed with the current operational rules and include an N-state and N-1 state computation. The starting N-state taken into account for this computation is the one of the historical day. Therefore maintenance or outages known when the domains were computed as well as the topology of the grid are taken from the historical days.

Furthermore FB domains considered in Step 1 could also be adapted according to planned grid outages, should they be planned in the relevant period for the assessment. Changes to the historical domains might be thus applied in some cases, in order to match the conditions of the grid. Furthermore, all nuclear units will be set to maximum output in the historical day files that are used to construct the flow-based domains.

Finally, a minimum Remaining Available Margin (RAM) of 20% of the Maximum Flow (Fmax) will be also considered for each Critical Network Element and Contingency (CNEC), when assessing the FB domains to be used in the assessment.

C.2.3 Calculation of the new flow-based domains

When the modification of the D2CF input files is ready, the operational flow-based calculation process is mimicked, to compute new flow-based domains that are compatible with the new grid & market rules.

C.2.4 Approximating the domains for computational efficiency

In general, the amount of CNEC's from the real world operational framework domains are too high to be of practical use in market simulations. If a four dimensional flow-based domain is reduced to a three dimensional domain using the zero sum constraint, then it is possible to approximate a 3-dimensional typical day domain with a regular polyhedron. This is called the Bucky ball approach. As the Bucky ball can be described with 36 inequality constraints the flow-based problem size remains manageable. In case the flow-based domains are of higher dimensionality a presolve of the typical day domains can be performed. The amount of constraints after presolve will be related to the number of typical domains so a tradeoff has to be made between domain resolution and computational efficiency.

C.2.5 Incorporating multiple flow-based domains into the adequacy assessment

Building on the experience of previous assessments, starting with the assessment for winter 2016-17, multiple flow-based domains are used to approximate the hourly changing domains. Indeed, Elia's adequacy assessment does not take a worst case approach by selecting only the smallest of the calculated domains as the reference domain for the simulation.

Instead a correlation between the typical days and specific climatic conditions is examined. For this purpose, a probability matrix is calculated as a function of daily energy ranges (high/medium/low) of wind and load. This calculation provides the correlation of each typical day (24 hourly domains) to given climatic combinations (eg. low wind, high load).

Based on this correlation an assignment of the flow-based domains to the hourly market simulation, which respects these probabilities is found.

- The typical days for winter of Step 1 are used as *proxies* for the relevant domains expected during next winter 2020-21 and will be assigned to hourly simulations by the correlation found in Step2.
- Each hourly simulation of the interconnected power system presents different expected climatic, generation and demand situations during next winter.
- Such systematic approach allows to link specific combinations of climate conditions expected next winter e.g. high /low wind infeed in Germany, high /low temperature and demand in France and Belgium etc..., with representative domains for these conditions.

The adequacy patch

The CWE flow-based algorithm includes a so-called adequacy patch defining rules for sharing energy exchanges in scarcity situations.

If a country has a structural deficit (day-ahead price reaches the day-ahead price cap (3000 €/MWh) in that country) the maximum import capacity will be allocated to that country independently from the market conditions in the other countries.

When two or more countries simultaneously have a structural deficit, imports will be allocated to those countries in proportion to their respective needs, on the basis of a quadratic function defined in the Euphemia market coupling algorithm [17].

For the purposes of the adequacy study, the adequacy patch is taken into account in the results from ANTARES in post-processing.

The method sketched above and to be used in the determination of the volumes of strategic reserve needed is consistent with the method used in recent Bilan Prévisionnel and PLEF studies.

Appendix D Integration of the Market Response in Belgium

Market Response is a crucial market dynamic during difficult situations on the electricity grid, especially in tough conditions, when adequacy problems arise. European (2009/72/CE and 2012/27/CE) and national policy makers as well as regulators are pushing for an increased development of Demand Side Response (DSR) and Market Response (MR)¹⁶. This effort is mirrored by market stakeholders' demands (FRP, BRP, producers, suppliers, third party aggregators and customers) to fine-tune the methodology used to identify the volume of Market Response in Belgium in the context of the volume determination of strategic reserve.

In 2017, key stakeholders on the market have expressed their willingness to be involved with the development of a new methodology to determine Market Response in Belgium in the scope of the volume determination of strategic reserve. In the context of the "Implementation Strategic Reserve" task force, a subgroup "Demand Response Study" was created in January 2017 to design the most adequate methodology for determining these volumes of Market Response. The methodology was designed based on interactions with stakeholders, over the course of four workshops and bilateral interviews.

Market Response, as used in the context of the volume determination of strategic reserve, encompasses all market reaction in the energy-only market to extraordinarily high prices. Market reaction in normal price conditions (prices < 150€/MWh) is already considered in the normalized load profile constructed by Elia for its adequacy study. The newly developed methodology allows determining the volume of Market Response that is available when extraordinarily high prices (> 150€/MWh) occur. It was concluded that the method can estimate the market response across all different consumer segments.

Based on close workshops and input of consultants, it was concluded that all available Market Response can be taken into account with the following three-fold approach: 1) the global market response volumes will be estimated based on the analysis of the aggregated demand and supply curve of the day-ahead market of EPEX Belgium. 2) This analysis is to be complemented with a set of defined the activation details. 3) These results then undergo a sanity check for verification purposes.

As agreed in the context of the "Implementation Strategic Reserve" task force during 2017, and to take into account the future evolutions of the Market Response volumes, the implementation of the methodology defined in 2017 will be updated yearly, in order to obtain most 'up-to-date' representative results every year.

Below, an overview of the methodology defined in 2017 is given for the sake of completeness.

D.1 Aggregated curves analysis: global volume estimation

The aggregated curves methodology enables to estimate the total volume of Market Response for the contract based, price based MR and voluntary MR categories. In the aggregated curves, Market Response volumes can be valued as a demand decrease or as an offer increase. These two elements are discussed in the following paragraphs.

¹⁶ In general, DSR is seen as the reduction of consumption (not including generation or storage technologies), while MR should be understood in a broader sense making abstraction of the technology (including generation or storage technologies).

D.1.1 Demand decrease

The demand decrease due to a price increase is directly present in the aggregated curves by studying the volume decrease associated to the price increase from 150€/MWh (bottom price limit of the market response volumes) to 3000€/MWh (maximum day-ahead price). Since, the aggregated curves are provided for each hour, this volume comparison is computed hourly.




Figure 19: market response in the demand curve

On the demand side, the output is the volume of market response for each given hour.

As an example, if 400 MW are above the limit of 150€/MWh, the estimated volume of market response for that particular hour is estimated to be 400MW.

D.1.2 Offer increase

Instead of a demand decrease, suppliers can value market response as a new offer in the market. This volume would appear in the supply curve. These curves cannot be analyzed as such since they may not only integrate only demand behaviors. Indeed, contrary to demand curves where the presence of bids representing generation is very limited above 150€/MWh, the supply curves can integrate this type of bids. Indeed, generation bids higher than 150€/MWh can be justified by extraordinary variable costs like, for example, a foreign sourcing.

To refine the analysis of the supply curve, we consider two price thresholds:

- **150€/MWh:** it is generally considered as the limit bid for generation assets, even if some generation assets can justify higher bids in specific cases
- **500€/MWh:** Above this value, it is considered very difficult to justify the price, and we can consider that only demand response bids appear in the curves

The analysis of the supply aggregated curves indeed provides us a range with:

- **a low estimation** of the offer side: this estimation doesn't take into account the potential value under 500€/MWh but definitely excludes generation
- **a high estimation:** this estimation integrates the adequate market response perimeter but possibly takes into account additional volumes of generation assets




Figure 20: analysis of the supply aggregated curve

In the aggregated curves, the smart orders¹⁷ are not taken into account. This reduces the total volume estimated. However, the volumes of Market Response smart orders are very limited, most of it being from generation assets. The impact for the Market Response volumes assessment is very limited.

The OTC bids are implicitly taken into account in the curves. If not in the curves, it would correspond to irrational behavior of the stakeholders, which is not to be taken into account in this study.

As an example, if the volume above 150€/MWh is 150MW and the volume above 500 €/MWh is 100MW, it can be considered that the volumes of Market Response valued in the supply curve will be in the range [100-150] MW.

The output volume of the methodology will indeed correspond to the adapted perimeter for the contract based and price based MR categories, but also the voluntary MR foreseen by the BRPs. Indeed, if there are some volumes in the voluntary MR category, the BRPs will anticipate such events. In theory, their anticipation will be reflected in their bidding behaviors if they are considered as firm by the BRPs, voluntary MR being then implicitly taken into account in this methodology.

D.2 “Objective qualitative Q&A”: qualitative content to complement the aggregated curves analysis

The aggregated curves analysis provides a capacity estimation and not an hourly volume to integrate in the model. For the integration into the adequacy assessment of Elia, it is required to obtain the number of activations per week and the maximum activation duration.

¹⁷ Smart orders are linked block orders (one block is executed if the other is also) or exclusive block orders




Figure 21: integration of the methodology into the adequacy assessment

The details on the activation were obtained by means of a Q&A. This questionnaire was **objective**, to avoid unrealistic and non-answerable questions. It was also **qualitative**, focused on gathering the required information on the activation in order to establish a correct link between the adequacy and the methodology, i.e. the activation details.

According to the discussion conducted with the stakeholders, the Q&A was designed to be simple, intuitive, and have questions anchored in the reality. Its main objective was to obtain qualitative information to complement the aggregated curves methodology. The key information being the number of possible activation per week and the duration of the activation.

A specific questionnaire was developed for each type of player (suppliers, aggregators and customers), in order to take their specificities into account. The questionnaire was developed in close cooperation with the respondents so as to ensure useful answers.

D.3 Global sanity check

To conduct a sanity check, the questionnaire provided an estimation of the volumes currently valued. This enabled Elia to avoid the main limit of the questionnaire raised by the stakeholders: the hypothetical situation description.

An international comparison point has also been formalized, putting the market response volumes in proportion of the maximum peak load in the electric system.

The volumes resulting from the above described method are to be compared to those of the questionnaire as well as the international comparison point and the findings of last year so as to assess the global coherence of the volumes.

D.4 Integration in the adequacy assessment

The output of the aggregated curve analysis will be hourly values of Market Response volumes. To integrate the results in a pertinent manner into the adequacy assessment, the statistical distribution of the results will be analyzed to provide confidence intervals and go beyond a simple average calculation. The impact of different parameters will also be assessed to reveal specific patterns, if present. The impactful parameters could be the day types (week day vs weekend), the time (peak hours), the temperature or the season. If specific patterns appear, they will be taken into account when integrating the results in the adequacy assessment.

Also, the methodology should provide volumes estimation for the three following winters. The output of the methodology, valid for next winter, will indeed be extrapolated based on the evolution of Market Response volumes during the previous years, provided by the aggregated curves analysis. Also, a correction will be applied to account for the volumes of ancillary services. This correction will be based on the projections of ancillary services needs, conducted by Elia and on the historic MR contribution.

The methodology will then provide a volume estimation of Market Response for the three following winters.

References

- [1] http://ec.europa.eu/competition/state_aid/cases/272020/272020_1964726_118_2.pdf
- [2] http://www.elia.be/~media/files/Elia/Products-and-services/Strategic-Reserve/2018/20181128_Adequacy-study.pdf
- [3] <http://www.ncdc.noaa.gov/>
- [4] http://www.ejustice.just.fgov.be/cgi_loi/change_lg.pl?language=nl&la=N&cn=2014032607&table_name=wet
- [5] <http://www.creg.info/pdf/Decisions/B1423FR.pdf>
- [6] <http://www.Elia.be/en/grid-data/Load-and-Load-Forecasts>
- [7] <https://ec.europa.eu/energy/en/news/reference-scenario-energy>
- [8] <http://www.elia.be/en/products-and-services/Strategic-Reserve/Information-produit>
- [9] <https://www.entsoe.eu/outlooks/maf/Pages/default.aspx>
- [10] <http://www.rte-france.com/fr/article/bilan-previsionnel>
- [11] https://www.tennet.eu/fileadmin/user_upload/Company/Publications/Technical_Publications/Dutch/Rapport_Monitoring_Leveringszekerheid_2017_web.pdf
- [12] https://www.bundesnetzagentur.de/DE/Sachgebiete/ElektrizitaetundGas/Unternehmen_Institutionen/Versorgungssicherheit/Netzreserve/netzreserve-node.html
- [13] <https://www.nationalgrid.com/uk/publications/future-energy-scenarios-fes>
- [14] <http://www.elia.be/en/projects/grid-projects/ALEGrO>
- [15] http://www.elia.be/en/about-elia/newsroom/news/2019/20190329_Update-on-the-interconnector-between-Elia-and-Creos-ICBedelux
- [16] <http://transparency.entsoe.eu/>
- [17] <http://www.elia.be/en/products-and-services/cross-border-mechanisms/transmission-capacity-at-borders/flow-based-marktkoppeling-centr-w-europa>