



## 20190902 Formal public consultation on the CRM design notes Part II

Name	Jonas Boury
Email	<a href="mailto:jonas@yuso.be">jonas@yuso.be</a>
Organization	Yuso
Comments/suggestions to the consultation	<p>With respect to the calculation of the derating factors for energy limited technologies we believe it is not correct to consider that all SLA can only be activated 1 time per day.</p> <p>In case of batteries for example it is realistic to assume that 2 to 3 cycles are possible in case of near scarcity events.</p> <p>We would therefor propose to also define multiple levels of activation limits in the SLA categories or at least evaluate the impact of increasing the number of activation on the calculation method.</p>
Answer confidential ?	No