



The need for a **Strategic Reserve** for winter 2019-20

and winter outlook for 2020-21 and 2021-22

Foreword

Dear reader,

Every year in November, Elia delivers a probabilistic analysis of Belgium's adequacy for the following winter. As defined in the Electricity Act, we assess the need for a strategic reserve. In this report, the security of supply for the next winter 2019-20 was analysed, while giving preliminary indications on the need during the winter periods 2020-21 and 2021-22.

This report is being published at a time when the Belgian electricity system is experiencing one of the most serious crises in its history. The additional, and unexpected unavailability of multiple nuclear power plants for the winter 2018-19 is unprecedented. It happened a few weeks before the start of the winter and after the analysis of the need for strategic reserves had been completed. Elia immediately calculated that the legal criteria for security of supply would not be met. In consultation with the Federal Minister for Energy and various market parties, all possible options have been examined that could have a positive impact on security of supply.

At the moment this report appears, the situation remains critical for January and February 2019. Every additional megawatt is welcome. Elia calls on all market players and suppliers to take their legal responsibility and ensure that their portfolio is in balance at all times.

Therefore, it is important to mention that the assumptions in this report regarding the planned unavailability of the Belgian generation fleet for winter 2019-20 are based on the latest information available on the relevant market transparency channels (REMIT). This approach was confirmed by the nuclear generation facility owner. It is known that the availability of nuclear power plants has a significant impact on the adequacy in Belgium as they make up a significant share of the energy mix.

Regarding the specific long-lasting outages of certain nuclear generation units over the last years, Elia adopted a sensitivity approach in order to capture low probability, high impact events. For Belgium, this leads to a reduction of 1.5 GW of Belgian nuclear generation capacity for the entire winter on top of the maintenance planning already considered in the 'base case' scenario and the simulated Forced Outages. This approach was approved by the Federal Minister for Energy.

When applying this high-impact, low-probability sensitivity, the analysis does not identify a need to constitute a strategic reserve for the winter 2019-20 in order to meet the legal criteria. Elia recommends considering this scenario but wishes to emphasise that the conclusions in this report are inseparable from the assumptions taken into account.

The Federal Minister for Energy will now use this analysis as one of the elements to decide on the need for a strategic reserve during winter 2019-20, a decision to be made before 15 January 2019.

With kind regards,

Chris Peeters

Contents

1	Introduction	20
1.1.	Roles and responsibilities.....	22
1.2.	Legal framework and process	23
1.3.	Adequacy criteria	25
1.4.	General background information on the strategic reserve	28
1.5.	History and current situation of strategic reserve constitution	31
1.6.	Public consultations regarding strategic reserve volume calculations.....	32
1.7.	Methodology and modelling improvements from the previous assessment ..	35
1.8.	Other adequacy studies with results relevant to Belgium.....	36
1.9.	Disclaimer	40
2	Methodology.....	41
2.1	Probabilistic simulation of the Western-European electricity market.....	43
2.2	Identifying periods of structural shortage.....	46
3	Assumptions about the power supply and electricity consumption in Belgium	47
3.1	The electricity supply in Belgium	48
3.2	Electricity consumption in Belgium	68
3.3	Market Response in Belgium.....	73
3.4	Summary of electricity supply and demand in Belgium.....	81
4	Assumptions for neighbouring countries.....	83
4.1	France.....	84
4.2	The Netherlands.....	90
4.3	Germany	93
4.4	Great Britain	97
4.5	Luxembourg	102
4.6	Other countries modelled	103
5	Interconnection modelling and assumptions.....	104
5.1	Flow-based methodology applied to the CWE zone	106
5.2	Commercial exchange capacities within CWE.....	117
6	Results.....	120
6.1	Assumptions for winter 2019-20	121
6.2	Results for winter 2019-20 ‘base case’	123
6.3	The ‘low probability – high impact’ sensitivity on nuclear availability.....	129

6.4	Results for winter 2020-21 and 2021-22.....	134
7	Conclusions	145
7.1	'Base case' scenario	146
7.2	'Sensitivity to the Belgian and French nuclear availability'	147
7.3	Overview of results.....	149
8	Appendices.....	150
8.1	Appendix 1: Simulation of the Western-European electricity market.....	151
8.2	Appendix 2: Adequacy parameters.....	176
9	Abbreviations	181
10	Sources.....	184

Executive Summary

In accordance with the Belgian Electricity Law, Elia must submit a probabilistic analysis of Belgium's security of supply for the following winter by 15 November of each year. This analysis is an important element that the Federal Minister for Energy takes into account when deciding on the needed volumes for the strategic reserve. The decision for next winter (2019-20) has to be taken on 15 January 2019 at the latest.

This report provides a probabilistic assessment of Belgium's security of supply for next winter (2019-20) under several hypotheses. Besides the 'base case' scenario, we also performed sensitivity analyses and evaluated the corresponding need for a strategic reserve. This report also gives a preliminary outlook on the need for strategic reserve for subsequent winters in 2020-21 and 2021-22

'Base case' Scenario

Assumptions

The 'base case' scenario includes the following assumptions (only the main drivers for Belgium are listed below):

- a relatively limited growth of 0.6 % per year in Belgium's total electricity demand;
- the latest public information (REMIT) regarding the planned outages of the nuclear units (as provided on the transparency websites of the nuclear units' owners dd. 8 November 2018) for Belgium and France. On top of any planned outages, the 'base case' scenario takes into account a normal Forced Outage rate. 'Exceptional' outages are not covered by this normal Forced Outage rate, but are treated separately in the low probability, high impact scenario described below;
- installed capacity forecasts for photovoltaic and onshore wind generation based on the latest data from the regions, combined with a best estimate made by Elia and FPS Economy about offshore wind generation;
- commercial exchanges between Belgium and the other CWE countries are modelled using available flow-based domains, modified to take into account full grid availability in Belgium and adding the effect of the so-called 20% minimum Remaining Available Margin (minRAM20%);
- the availability of the new interconnector with Great Britain (Nemo Link[®]) with a capacity of 1000 MW from the winter 2019-20 onwards;
- a maximum global simultaneous import capacity of 5500 MW for Belgium for winter 2019-20. This limit is not affected by the go-live of Nemo Link[®], and applies to the sum of the imports from CWE and the flow on the Nemo Link[®] interconnector;
- a stable trend in the installed thermal generation facilities in Belgium between winter 2018-19 and winter 2019-20, with the Seraing power plant having returned to the market as CCGT and the operation mode of the Drogenbos power plant as CCGT during the entire winter 2019-20. Furthermore, the most 'up-to-date' information is considered regarding the maintenance planning of the thermal

generation fleet, as provided on the transparency websites of the thermal units' owners (dd. 8 November 2018).

Belgium remains dependent on imports for its electricity supply. Therefore, any change in the assumptions for neighbouring countries – related to their exporting capabilities or importing needs – has a potential impact on Belgium and on the associated strategic reserve volume.

The maximum availability of domestic generation during the winter period is crucial for Belgium to maintain its adequacy. Therefore, Elia urges the generation units' owners to avoid any planned maintenance of their units during the winter period.

Conclusion

The 'base case' scenario in this probabilistic assessment for next winter (2019-20) leads to a margin of 3300 MW, with an average LOLE close to zero. Under the assumptions made in the 'base case' scenario, the analysis does not identify a need to contract a strategic reserve for winter 2019-20 in order to meet the legal criteria.

'Low Probability, High Impact' Scenario

The availability of nuclear power plants has a significant impact on adequacy because they make up a significant share of the Belgian energy mix. The Forced Outage rates used in our calculations are based on historical unplanned unavailability during the last 10 years. Exceptional, long-lasting outages that occurred between 2014 and 2019 are not included in the Forced Outage rates in the 'base case' scenario, because of their unusual nature.

Additional sensitivity

Given the significant impact on adequacy, however, it is important to analyse such a 'Low Probability, High Impact' scenario. To that end, a detailed comparison between the modelled availability in the 'base case' and the real Belgian nuclear availability observed over the last seven winters has been analysed.

As a result, it is concluded that 'Low Probability, High Impact' events - as observed during the last seven winters - could be captured by considering a sensitivity with an additional 1.5 GW of nuclear generation capacity out of service in Belgium. This capacity is considered to be out of service for the entire winter on top of the maintenance planning already considered in the 'base case' and the simulated Forced Outages.

Situation in France

Likewise, the unavailability of the French nuclear generation fleet has an important impact on the adequacy situation in Belgium, as seen in the winter of 2016-17 when multiple nuclear units were temporarily out of service at the request of the French nuclear safety authority. Therefore, the same analysis applied to Belgium was conducted for the French nuclear availability.

When comparing the modelled French nuclear availability in the 'base case' scenario with the real French nuclear availability over the last seven winters, the sensitivity results in a capacity of 3.6 GW of nuclear generation capacity considered out of service in France for

the entire winter. This capacity is considered to be out of service for the entire winter on top of the maintenance planning and the Forced Outages already considered in the 'base case' for France.

Conclusion

When applying this sensitivity analysis in order to capture low probability, high impact events, the analysis does not identify a need to contract a strategic reserve for the winter 2019-20 in order to meet the legal criteria. The 'low probability - high impact' scenario in the study leads to a margin of 400 MW.



Recommendation to the Minister

To decide on the volume need for the strategic reserve for next winter (2019-20), Elia recommends taking into account the scenario incorporating low-probability events with a high impact on Belgian adequacy.

This scenario includes a reduction of nuclear unavailability during the entire winter of 1.5 GW in Belgium and 3.6 GW in France; in addition to the planned unavailability communicated by the generation units' owners in Belgium and France and the statistically determined Forced Outages.

Concretely, Elia's recommended scenario incorporating low-probability events with a high impact, leads to a margin of 400 MW for Belgium for next winter (2019-20). Therefore, this scenario does not induce a need for constituting a strategic reserve for winter 2019-20. This recommendation reflects the improvement of the situation for Belgium compared to the situation considered in the November 2017 strategic reserve volume report for winter 2018-19, with the return to the market of the Seraing CCGT unit, the commissioning of the Nemo Link® interconnector and the minRAM20% rule.

However, this result is inseparable from the hypotheses considered, for Belgium as well as for the neighbouring countries.

Specifically regarding the Belgian nuclear generation units, it is important to note that:

- the assumptions taken regarding the planned unavailability of the Belgian generation fleet are based on the latest information on the relevant market transparency channels (REMIT). This approach was finally confirmed by the relevant nuclear generation facility owner (letter received October 23rd, 2018).
- regarding the specific long-lasting outages of certain nuclear generation units over the last years, Elia adopted a sensitivity approach. For Belgium this leads to an additional reduction of 1.5 GW of Belgian nuclear generation capacity. This approach was confirmed by the Federal Minister of Energy (letter received October 22nd, 2018).

The retained scenario results in a nuclear generation fleet for Belgium for which:

- up to 2 GW is unavailable due to planned maintenance in November 2019;
- 1.5 GW is additionally taken out of service for the complete winter 2019-20;
- Additionally, Forced Outages of the remaining nuclear units are statistically simulated at a rate of 3.5%, which is based on historical unplanned unavailability during the last 10 years, excluding long-lasting outages which are covered by the previous bullet.

A buffer of more than three months between the end of the last maintenance period before winter, as planned today by the generation units' owners, and the start of the upcoming winter 2019-20, exists. Furthermore, in the case of an extension of the ca. 2 GW of nuclear generation that will be in planned maintenance at the start of winter 2019-20, this should – all other things remaining equal – be covered by the considered sensitivity and the remaining margin of 400 MW.

Needless to say that realised situations that go even beyond the hypotheses considered might lead to an adequacy issue for Belgium and a corresponding need for a Strategic Reserve. For example, the situation for the winter 2018-19, detected in September 2018, would probably call for additional measures again should it reoccur in the winter 2019-20.

A look forward

Concerning the outlook for the winters 2020-21 and winter 2021-22 and under the current assumptions, we estimate that the margin on the Belgian system for the 'low probability-high impact' scenario will increase to around **800 MW** for winter 2020-21 and to **1000 MW** for winter 2021-22. These results are based on i) the contribution of the new interconnector with Germany ALEGrO and ii) an increase of the installed generation capacity in Belgium (renewables) and abroad. While sufficient generation and import capacity should ensure the adequacy of the Belgian system for the next winter periods, it remains important to look ahead at the medium and longer term.

The execution of the Belgian nuclear phaseout from October 2022 onwards will certainly have a significant impact on the Belgian electricity system. Additionally, and given Belgium's dependence on imports, the future exporting capabilities of our neighbouring countries will also have a key impact on the expected adequacy situation and the need for domestic generation in Belgium.

For the above mentioned reasons, and given its goal of providing a sustainable and adequate electricity system with prices that are competitive compared to our neighbouring countries, Elia continues to stress the importance of the ongoing activities related to the introduction of a Capacity Remuneration Mechanism for Belgium, in order to ensure the adequacy of the Belgian electricity system in the medium term.

Elia wishes to emphasise that the conclusions of this report are inseparable from the assumptions mentioned in the report. Elia cannot guarantee that these assumptions will actually materialise. In most cases, these are developments beyond the direct control or responsibility of the system operator.

Executive Summary (NL)

Zoals voorzien in de elektriciteitswet moet Elia tegen 15 november van elk jaar een probabilistische studie indienen van de Belgische bevoorradingzekerheid voor de volgende winter. Deze analyse is een belangrijk element dat in rekening wordt genomen door de Federale minister van Energie bij het maken van een beslissing over de nood van het aanleggen van een strategische reserve. De deadline voor deze beslissing voor winter 2019-20 is 15 januari 2019.

Dit rapport bevat een probabilistische evaluatie van de Belgische bevoorradingzekerheid voor de komende winter (2019-20) onder verschillende hypothesen. Naast een 'base case' scenario voerden we ook een sensitiviteitsanalyse uit en analyseerden we de impact op de nood aan strategische reserve. Dit rapport biedt ook een vooruitblik op de nood van het aanleggen van een strategische reserve voor de winters 2020-21 en 2021-22.

'Base case' Scenario

Hypothesen

Het 'base case' scenario bevat volgende hypothesen (enkel de voornaamste elementen voor België zijn hieronder opgesomd):

- een relatief beperkte groei van 0,6% van de totale jaarlijkse vraag naar elektriciteit in België;
- zowel voor België als voor Frankrijk werd de laatste publieke informatie (REMIT) over de toekomstige onderhoudsplanning van de nucleaire productie-eenheden in rekening gebracht, zoals aangeleverd op de transparantie websites van de eigenaars van de betrokken centrales (d.d. 8 november 2018). Bovenop de voorziene stops neemt de 'base case' ook de gemiddelde onvoorziene uitval (*forced outage*) in rekening. Uitzonderlijke stops worden niet gedekt door het gemiddelde gedwongen uitvalratio maar worden apart behandeld in een 'lage waarschijnlijkheid, hoge impact' sensitiviteit, die hieronder wordt beschreven;
- geïnstalleerde capaciteit voor fotovoltaïsche en onshore windproductie gebaseerd op de laatste informatie van de regio's, gecombineerd met de beste inschatting gemaakt door Elia en de FOD Economie voor de offshore windproductie;
- commerciële uitwisselingen tussen België en andere CWE landen worden gemodelleerd door gebruik te maken van historische flow-based domeinen, aangepast om de 'full-grid' beschikbaarheid in België in rekening te brengen en aangepast om de zogenaamde '20% minimum Remaining Available Margin (*minRAM20%*)' toe te voegen;
- de beschikbaarheid van de nieuwe interconnector met Groot-Brittannië (Nemo Link®) met een capaciteit van 1000MW vanaf de winter van 2019-20 en volgende;
- een maximum simultane importcapaciteit van 5500MW voor België voor de winter 2019-20 wordt beschouwd. Deze limiet bestaat uit zowel de import in de CWE regio als de flux op de Nemo Link® interconnector tussen België en Groot-Brittannië
- een stabiele trend in de resterende geïnstalleerde thermische productiecapaciteit in België tussen winter 2018-19 en winter 2019-20, met de terugkeer van de

STEG centrale van Seraing in de markt, en de uitbating van de STEG van Drogenbos in gecombineerde cyclus gedurende de hele winter 2019-20. Bovendien werd ook de meest recente informatie betreffende de onderhoudsplanning van alle niet-nucleaire thermische eenheden, zoals voorzien op de transparantie websites van de respectievelijke eigenaars (d.d. 8 november 2018), in rekening gebracht.

België blijft afhankelijk van import voor zijn elektriciteitsvoorziening. Daarom heeft elke verandering in de aangenomen hypothesen voor de naburige landen een mogelijke impact op de situatie in België en op de nood aan een strategisch reserve volume.

De maximum beschikbaarheid van de binnenlandse productie gedurende de winterperiode is cruciaal voor België om zijn bevoorradingszekerheid te garanderen. Daarom zet Elia de eigenaars van productiecentrales er toe aan om maximaal de geplande onderhouden in de winterperiodes te vermijden.

Conclusie

Het 'base case' scenario in deze probabilistische studie voor winter 2019-20 geeft aanleiding tot een marge van 3300 MW, met een gemiddelde LOLE dicht bij nul. Onder de hypothesen gemaakt in de 'base case' identificeert de analyse geen nood om een strategische reserve te contracteren voor winter 2019-20 om de wettelijke bevoorradingszekerheidscriteria te respecteren.

'Low Probability, High Impact' Scenario

De beschikbaarheid van Belgische nucleaire eenheden heeft, gezien de grote geïnstalleerde capaciteit, een zeer significante impact op de Belgische bevoorradingszekerheid. De gedwongen uitval ratio's gebruikt in deze studie zijn gebaseerd op de historisch ongeplande onbeschikbaarheden van de laatste tien jaar. Uitzonderlijk lange stops die voorkwamen op de nucleaire eenheden tussen 2014 en 2019 zijn niet opgenomen in deze ratio's in het 'base case' scenario gezien hun uitzonderlijk karakter.

Extra sensitiviteit

Gezien hun significante impact echter, is het belangrijk een scenario te analyseren die dit soort 'lage waarschijnlijkheid, grote impact' situaties in rekening brengt. Hiertoe werd een gedetailleerde vergelijking tussen de gemodelleerde beschikbaarheid in de 'base case' en de reële Belgische nucleaire beschikbaarheid over de laatste zeven winters uitgevoerd.

Het resultaat van deze analyse is dat de impact van deze lage waarschijnlijkheid, hoge impact situaties, zoals geobserveerd in de laatste 7 winter, kunnen begrepen worden in een sensitiviteit waarin een additionele 1,5 GW nucleaire productiecapaciteit voor de hele winter in België als buiten dienst wordt beschouwd. Deze capaciteit wordt buiten dienst beschouwd bovenop de reeds voorziene geplande onderhoudswerken uit de 'base case' en de gesimuleerde gedwongen uitval.

Situatie in Frankrijk


Daarenboven heeft ook de onbeschikbaarheid van het Franse nucleaire productiepark een belangrijke impact op de bevoorradingszekerheidssituatie in België, zoals werd

geobserveerd in de winter van 2016-17 wanneer meerdere nucleaire eenheden in Frankrijk tijdelijk buiten dienst werden genomen op vraag van het Franse nucleaire veiligheidsagentschap. Bijgevolg werd dezelfde analyse, die uitgevoerd was voor België, uitgevoerd voor de Franse nucleaire beschikbaarheid.

Deze analyse van de reële nucleaire beschikbaarheid in Frankrijk over de voorbije zeven winters maakte duidelijk dat een sensitiviteit waarin 3,6 GW nucleaire productiecapaciteit extra in Frankrijk buiten dienst werd gesteld dient aangenomen te worden. Deze capaciteit is verondersteld de hele winter buiten dienst te zijn bovenop de reeds geplande onderhoudswerken en de gesimuleerde gedwongen uitval reeds voorzien in de 'base case' voor Frankrijk.

Conclusie

De sensitiviteitsanalyse, bedoeld om 'lage waarschijnlijkheid, grote impact' situaties in rekening te brengen, toont geen nood aan tot het aanleggen van een strategische reserve voor winter 2019-20 om aan de wettelijke bevoorradingszekerheidscriteria te voldoen. De 'lage waarschijnlijkheid, grote impact' sensitiviteit in deze studie leidt tot een marge van 400 MW.



Aanbeveling aan de Minister

Bij het bepalen van een volumenuod aan strategische reserve voor komende winter 2019-20 beveelt Elia aan een beslissing te nemen op basis van het scenario dat 'lage waarschijnlijkheid, hoge impact' situaties in rekening neemt.

Dit scenario bevat een reductie van 1,5 GW nucleaire productiecapaciteit in België en 3,6 GW nucleaire productiecapaciteit in Frankrijk gedurende de hele winter, bovenop reeds geplande onbeschikbaarheden, zoals gecommuniceerd door de respectievelijke eigenaars, en de statisch bepaalde gedwongen uitval ratio's.

Concreet geeft Elia's aanbevolen 'lage waarschijnlijkheid, grote impact' scenario aanleiding tot een marge van 400MW voor België voor komende winter 2019-20. Daarom is er in dit scenario geen nood tot het samenstellen van een strategische reserve voor winter 2019-20. Deze aanbeveling reflecteert de verbetering van de situatie voor België vergeleken met de situatie die in

rekening werd gebracht in het volumerapport van november 2017 voor winter 2018-19, met name de terugkeer van de Seraing STEG centrale in de markt, alsook de indienstname van de Nemo Link® interconnector en de minRAM20% regel.

Echter, dit resultaat is onlosmakelijk verbonden aan de beschouwde hypothesen, zowel voor België als de buurlanden.

Meer bepaald is het belangrijk aan te stippen dat voor de Belgische nucleaire eenheden:

- de assumpties genomen met betrekking tot de geplande onbeschikbaarheden gebaseerd zijn op de meest recente informatie op de relevante markttransparantie kanalen (REMIT). Deze benadering eveneens bevestigd door de eigenaar van de nucleaire eenheden (brief ontvangen op 23 oktober 2018);
- betreffende de specifieke stilstanden van lange duur van enkele nucleaire eenheden in de afgelopen jaren, Elia de sensitiviteitsmethode heeft toegepast. Voor België leidt dit tot een reductie van 1,5 GW aan Belgische nucleaire productiecapaciteit. Deze benadering werd bevestigd door de federale Minister van Energie (brief ontvangen op 22 oktober 2018).

Het weerhouden scenario resulteert in een nucleair productiepark voor België waarin:

- tot 2 GW onbeschikbaar is door gepland onderhoud in november 2019;
- 1,5 GW extra uit dienst is voor de hele winter 2019-20;
- de onvoorziene uitval ratio's van de resterende nucleaire eenheden, werden in de simulatie bepaald op 3,5%. Dit cijfer is gebaseerd op de historische ongeplande onbeschikbaarheden in de afgelopen 10 jaar, zonder de uitzonderlijke lange stilstanden in rekening te brengen die vermeld werden in vorige paragraaf.

Er is een buffer van meer dan drie maanden tussen het einde van de laatste onderhoudsperiode voor de winter, zoals vandaag gepland, en de start van de komende winter. Bovendien, in het geval van een verlenging van de ca. 2 GW onbeschikbare nucleaire productiecapaciteit aan het begin van de winter 2019-20 zou dit, zonder andere wijzigingen, gedekt kunnen worden door de beschouwde sensitiviteit en de marge van 400 MW.

Wanneer een meer problematische situatie zich voordoet, die verder gaat dan de beschouwde hypothesen, kan dit aanleiding geven tot bevoorradingszekerheidsproblemen in België en aanleiding geven tot een nood aan strategische reserve. Ter illustratie: de situatie voor winter 2018-19, zoals gedetecteerd in september 2018, zou hoogstwaarschijnlijk aanleiding opnieuw aanleiding geven tot een nood aan strategische reserve mocht deze zich opnieuw voordoen in winter 2019-20.

Een vooruitblik

Betreffende de vooruitblik voor de daaropvolgende winters schat Elia in dat onder de huidige hypothesen de marge op het Belgische elektrische energiesysteem voor het 'lage waarschijnlijkheid, hoge impact' scenario zal stijgen tot 800MW voor winter 2020-21 en tot 1000MW voor winter 2021-22. Deze resultaten zijn gebaseerd op i) de bijdrage van de nieuwe interconnector met Duitsland ALEGrO en ii) een toename van de geïnstalleerde capaciteit hernieuwbare energie in België en de buurlanden.

Niettegenstaande de conclusie dat voor de komende winter, voldoende productiecapaciteit in België zou beschikbaar moeten zijn om, onder de genomen hypothesen, bevoorradingszekerheid van het Belgische energiesysteem binnen de

wettelijke criteria te garanderen, is het toch belangrijk naar de midden- en langere termijn te kijken.

De uitvoering van de Belgische nucleaire phaseout vanaf oktober 2022 en verder zal zeker een significante impact hebben op het Belgische elektriciteitssysteem. Daarenboven, gegeven de Belgische afhankelijkheid van import, zullen ook de toekomstige exportmogelijkheden van onze buurlanden een cruciale impact hebben op de bevoorradingszekerheidssituatie en de noodzaak aan binnenlandse productiecapaciteit in België.

Om bovenvermelde redenen, en gegeven de doelstelling om een duurzaam en betrouwbaar elektriciteitssysteem aan te bieden, met competitieve prijzen met onze buurlanden, blijft Elia het belang benadrukken van de lopende activiteiten met betrekking tot het capaciteitsremuneratiemechanisme voor België, om als dusdanig de bevoorradingszekerheid van het Belgische elektriciteitssysteem op de middellange termijn te garanderen.

Elia wenst te benadrukken dat de conclusies van dit rapport onlosmakelijk verbonden zijn aan de hypothesen genomen in deze studie. Elia kan niet garanderen dat deze hypothesen werkelijkheid worden. In de meeste gevallen zijn deze ontwikkelingen buiten de directe controle of verantwoordelijkheid van de netbeheerder.

Executive Summary (FR)

Comme prévu dans la loi Électricité, Elia doit soumettre, le 15 novembre de chaque année, une analyse probabiliste sur l'adéquation de la Belgique pour l'hiver suivant. Cette analyse est un élément important à prendre en compte par le ministre fédéral de l'Énergie pour prendre une décision sur le volume de réserve stratégique nécessaire. L'échéance de cette décision pour l'hiver 2019-20 est fixée à la date du 15 janvier 2019.

Ce rapport fournit une évaluation probabiliste de la sécurité d'approvisionnement de la Belgique pour le prochain hiver (2019-20) tenant compte de certaines hypothèses. Outre le scénario 'base case', nous avons aussi effectué des analyses de sensibilité en évaluant le besoin de réserve stratégique correspondant. Ce rapport donne également une première estimation sur le besoin en réserve stratégique pour les prochaines périodes hivernales 2020-21 et 2021-22.

Scenario 'base case'

Hypothèses

Le scénario 'base case' comprend les hypothèses suivantes (seuls les facteurs déterminants pour la Belgique sont énumérés ci-dessous):

- une croissance relativement limitée de la consommation d'électricité total en Belgique, de 0,6% par an;
- la prise en compte des dernières informations publiques (REMIT) concernant les plannings de maintenance des unités nucléaires (comme indiqué sur les sites Web de transparence des exploitants des unités nucléaires concernées (dd. 8 novembre 2018). En plus de ces maintenances planifiées, les simulations du scénario 'base case' tiennent compte d'un taux d'indisponibilité fortuite statistiquement normal. Les indisponibilités « exceptionnelles » ne sont pas couvertes par ce taux d'indisponibilité fortuite statistiquement normal, mais sont traitées séparément par l'ajout d'une sensibilité à faible probabilité, grand impact ('Low Probability, High Impact').
- les prévisions de capacité installée pour le photovoltaïque et l'éolien terrestre selon les dernières données des autorités régionales, combinées aux meilleures estimations de Elia et du SPF Economie pour l'éolien offshore;
- les échanges commerciaux entre la Belgique et les autres pays de la zone CWE sont modélisés à l'aide des domaines flow-based historiques disponibles, modifiés afin de prendre en compte une disponibilité complète du réseau en Belgique et en ajoutant l'effet de ce qui est communément appelé le 20% minimum Remaining Available Margin (minRAM20%);
- la disponibilité de la nouvelle interconnexion avec la Grande-Bretagne (Nemo Link®) avec une capacité de 1000 MW à partir de l'hiver 2019-20;
- une capacité d'importation maximale simultanée de 5500 MW pour la Belgique pendant l'hiver 2019-20 est considérée. Cette limite n'est pas affectée par la mise en service de Nemo Link® et est appliquée à la somme des importations depuis la zone CWE et sur le flux sur Nemo Link®;

- une tendance stable de la capacité de production thermique installée en Belgique entre l'hiver 2018-19 et l'hiver 2019-20, avec le retour sur le marché de la centrale de Seraing (en mode 'CCGT') et en prenant en compte la centrale de Drogenbos en mode 'CCGT' durant toute la période hivernale 2019-20. De plus, les dernières informations concernant la planification de la maintenance, telles que fournies sur les sites Web de transparence des exploitants des unités thermiques, sont prises en compte (dd. 8 novembre 2018).

La Belgique reste dépendante des importations pour son approvisionnement en électricité. Par conséquent, toute modification des hypothèses concernant les pays voisins (en relation avec leur aptitude à exporter ou importer) présentera un impact potentiel sur la Belgique et sur le volume de la réserve stratégique associée.

La disponibilité maximale de la production domestique pendant la période hivernale est cruciale pour que la Belgique maintienne son adéquation. Elia exhorte donc les exploitants des unités de production concernées à éviter au maximum tout entretien prévu de leurs unités pendant la période hivernale.

Conclusion

Le scénario 'base case' de cette étude probabiliste pour l'hiver suivant (2019-20) indique une marge de 3300 MW, avec un LOLE moyen proche de zéro. En tenant compte des hypothèses du scénario 'base case', l'analyse n'identifie pas un besoin de contracter de la réserve stratégique pour l'hiver 2019-20 pour satisfaire les critères légaux.

'Low Probability, High Impact' Scenario

La disponibilité des unités de production nucléaires a un impact significatif sur l'adéquation de par le fait que celles-ci constituent une grande part du mix électrique Belge. Les taux d'indisponibilité fortuite utilisés dans les calculs sont basés sur les indisponibilités non planifiées historiques au cours des dix dernières années. Les indisponibilités exceptionnelles et de longue durée qui se sont produites entre 2014 et 2019 ne sont pas comprises dans ces taux d'indisponibilité fortuite dans le scénario 'base case', en raison de leur nature inhabituelle.

Sensitivité additionnelle

Compte tenu de leur impact significatif sur l'adéquation, il est toutefois important d'analyser un scénario 'Low Probability, High Impact'. À cette fin, une comparaison détaillée entre la disponibilité nucléaire en Belgique modélisée dans le scénario 'base case' et réelle au cours des sept derniers hivers a été réalisée.

Sur base du résultat de cette analyse, il a été conclu que les événements à faible probabilité et à grand impact, observés au cours des sept derniers hivers, peuvent être pris en compte en considérant une sensibilité caractérisée par l'indisponibilité additionnelle de 1,5 GW sur le parc de production nucléaire en Belgique. Cette capacité est considérée comme indisponible pendant tout l'hiver, et ce, en plus de la maintenance déjà prévue et prise en compte dans le scénario 'base case' et des indisponibilités fortuites simulées.


Situation en France

Pareillement, l'indisponibilité du parc de production nucléaire français a un impact important sur l'adéquation en Belgique, comme observé durant l'hiver 2016-17 où plusieurs unités étaient temporairement hors service à la demande de l'Autorité de Sûreté Nucléaire française. Par conséquent, une analyse similaire à celle effectuée pour la Belgique a été menée pour la disponibilité de la capacité nucléaire française.

En comparant la disponibilité du parc nucléaire français modélisé dans le scénario 'base case' et la disponibilité réelle au cours des sept derniers hivers, il est apparu opportun de prendre en compte une sensibilité où 3,6 GW de capacité de production nucléaire serait considérée hors-service en France. Cette capacité est considérée comme indisponible pendant tout l'hiver, et ce, en plus de la maintenance déjà prévue et prise en compte dans le scénario 'base case' et des indisponibilités fortuites simulées pour la France.

Conclusion

La prise en compte de cette analyse de sensibilité afin de prendre en compte les événements à faible probabilité et à grand impact, l'analyse n'identifie pas la nécessité de contracter une réserve stratégique pour l'hiver 2019-20 afin de respecter les critères légaux. Le scénario 'Low Probability, High Impact' de cette étude conduit à une marge de 400 MW.



Recommandation au Ministre

Afin de prendre une décision sur le volume à constituer pour la réserve stratégique pour l'hiver prochain (2019-20), Elia recommande de prendre en compte le scénario incorporant des événements à faible probabilité ayant un impact important sur l'adéquation de la Belgique.

Ce scénario comprend une réduction de l'indisponibilité nucléaire pendant tout l'hiver de 1,5 GW en Belgique et de 3,6 GW en France; en plus de l'indisponibilité planifiée communiquée par les propriétaires des unités de production en Belgique et en France et des probabilités d'arrêts fortuits déterminées de manière statistique.

Concrètement, le scénario recommandé par Elia intégrant des événements à faible probabilité et à grand impact conduit à une marge de 400 MW pour la Belgique pour l'hiver prochain (2019-20). Par conséquent, ce scénario n'induit pas la nécessité de constituer une réserve stratégique pour l'hiver 2019-20. Cette recommandation reflète l'amélioration de la situation en Belgique par rapport à la situation prise en compte dans le rapport sur le volume de la réserve stratégique de novembre 2017 pour l'hiver 2018-19, avec le retour sur le marché de l'unité CCGT de Seraing, la mise en service de l'interconnexion Nemo Link® et de l'introduction de la règle minRAM20%.

Cependant, ce résultat est indissociable des hypothèses considérées, tant pour la Belgique que pour les pays voisins.

En ce qui concerne plus particulièrement les unités de production nucléaire belges, il est important de noter que:

- les hypothèses retenues concernant l'indisponibilité prévue du parc de production belge sont basées sur les dernières informations sur les canaux de transparence de marché pertinents (REMIT). Cette approche a finalement été confirmée par le propriétaire concerné des installations de production nucléaire (lettre reçue le 23 octobre 2018);
- en ce qui concerne les pannes de longue durée spécifiques de certaines centrales nucléaires au cours des dernières années, Elia a adopté une approche de sensibilité. Pour la Belgique, cela entraîne une réduction supplémentaire de 1,5 GW de la capacité de production nucléaire belge. Cette approche a été confirmée par le Ministre Fédéral de l'Énergie (lettre reçue le 22 octobre 2018).

Le scénario retenu donne lieu à un parc de production nucléaire en Belgique pour lequel:

- jusqu'à 2 GW sont indisponibles en raison de la maintenance prévue en novembre 2019;
- 1,5 GW est en outre mis hors service pour l'ensemble de l'hiver 2019-20;
- De plus, les arrêts fortuits des unités nucléaires restantes sont simulés statistiquement à un taux de 3,5%, basé sur les indisponibilités historiques non planifiées des 10 dernières années, à l'exclusion des pannes de longue durée qui sont décrites dans le point précédent.

En considérant les périodes de maintenance prévues à ce jour, il y a une marge de sécurité de plus de trois mois entre la fin de la dernière période de maintenance avant l'hiver et le début de l'hiver prochain. En outre, dans le cas d'une extension de la capacité de production nucléaire indisponible d'environ 2 GW au début de l'hiver 2019-20 (et sans autres changements), celle-ci pourrait être couverte par la sensibilité considérée et par la marge de 400 MW qui en résulte.

Inutile de mentionner que des situations allant au-delà des hypothèses considérées pourraient à nouveau poser un problème d'adéquation pour la Belgique et un besoin correspondant de réserve stratégique. Par exemple, la situation détectée en septembre 2018 pour l'hiver 2018-19 nécessiterait probablement de nouvelles mesures si elle devait se reproduire à l'hiver 2019-20.

Un regard vers l'avenir

En ce qui concerne les perspectives pour les hivers 2020-21 et hiver 2021-22 et selon les hypothèses actuelles, nous estimons que la marge du système belge pour le scénario

'low probability-high impact' augmentera à environ 800 MW pour l'hiver 2020-21 et à 1000 MW pour l'hiver 2021-22. Ces résultats reposent sur i) la contribution du nouvel interconnexion ALEGrO avec l'Allemagne et ii) l'augmentation de la capacité de production installée en Belgique (énergies renouvelables) et à l'étranger.

Nonobstant la conclusion que, pour le prochain hiver et selon les hypothèses actuelles, une capacité de production suffisante devrait être disponible pour garantir l'adéquation du système belge aux critères légaux, il est important de se projeter à moyen et à long terme.

L'exécution du 'phase out' progressif du nucléaire belge à partir d'octobre 2022 aura certainement un impact significatif sur le système électrique belge. En outre, et compte tenu de la dépendance de la Belgique à l'égard des importations, les futures capacités d'exportation de nos pays voisins auront également un impact déterminant sur la situation d'adéquation prévue et sur la nécessité de capacité de production en Belgique.

Pour les raisons susmentionnées et compte tenu de son objectif de fournir un système électrique durable et adéquat à des prix compétitifs par rapport aux pays voisins, Elia continue de souligner l'importance des activités en cours liées à la mise en place d'un mécanisme de rémunération de la capacité pour la Belgique, et ce, afin de garantir l'adéquation du système électrique belge à moyen terme.

Elia tient à souligner que les conclusions de ce rapport sont indissociables des hypothèses mentionnées dans celui-ci. Elia ne peut garantir que ces hypothèses se matérialiseront réellement. Dans la plupart des cas, il s'agit de développements qui échappent au contrôle direct ou à la responsabilité de l'opérateur du système.

1 Introduction



A strategic reserve mechanism has been in place since 2014 to shore up Belgium's electricity security during the winter period. This mechanism entails new tasks and responsibilities for Elia as the country's system operator. One such task is to determine the need for a strategic reserve by carrying out a probabilistic assessment. This report sets out the results of the assessment of the 2019-20 winter period that Elia was required to conduct by 15 November 2018.

Elia previously carried out assessments for the winters 2014-15 up to and including 2018-19. These documents are available to the public on the website of the Directorate-General for Energy at FPS Economy [1].

This report builds further on previous editions. As such, it follows the same general structure.

Chapter 1 presents the relevant background and context, provides an overview of the roles and responsibilities of the various parties and describes the communications and consultations with stakeholders regarding this report.

Chapter 2 sets out the method and framework used for the probabilistic assessment. The application of this method is covered in **Chapters 3 and 4**, which take an in-depth look at the assessment's key parameters and assumptions. The focus here is on available generation resources, energy consumption in Belgium and the situation in neighbouring countries.

Chapter 5 presents the assumptions regarding interconnection capabilities for Belgium and neighbouring countries.

Chapters 6 sets out the results of the assessment for winter 2019-20, providing an in-depth analysis of the base-case scenario and of a sensitivity scenario based on the availability of nuclear power in Belgium and France. The sensitivity scenario is defined to account for the occurrence of 'low-probability, high-impact', yet realistic, events.

Chapter 7 sets out the conclusions of this report, and **Chapter 8** contains the appendices on modelling details and adequacy parameters.



Figure 1.1

1.1. Roles and responsibilities

Elia is Belgium's transmission system operator for the high-voltage grid (30 to 380 kV) and, as such, plays a crucial role for society. Through its **three core activities** (see Figure 1.2), Elia ensures the reliable transmission of electricity both now and in the future.




Figure 1.2

1.1.1 Operating the electricity system

This task is facing increasing challenges. Accordingly, sophisticated tools and processes and special skills are needed to maintain balance on the system 24 hours a day, all year round. As electrical energy cannot be stored in high volumes, balance must be maintained in real time with a view to ensure a reliable supply and the efficient operational management of the high-voltage grid. The role of managing the strategic reserve is part of this task.

Balancing supply and demand

In any electricity system, generated energy must always match consumed energy. If there are any differences between them, the grid's frequency will either rise (when generation exceeds consumption) or fall (when consumption exceeds generation). Elia's role is to maintain this balance at all times.

Balance between supply and demand




Figure 1.3

1.1.2 Managing the infrastructure

Power plants used to be built near cities and industrial areas, but since the advent of renewable energy sources, the distances between power generating facilities and centres where energy is consumed have increased significantly. Offshore wind farms are a good example of this. Energy distribution and transmission systems need to be expanded to integrate renewables into the energy mix and ensure that electricity flows from north to south and from west to east. Elia deploys innovative technologies to boost the efficiency and reliability of its electricity system and manages its infrastructure in a cost-efficient way, while always focussing on safety.

1.1.3 Facilitating the market

Elia makes its infrastructure available to the market in a transparent, non-discriminatory way, develops new products and services to improve the liquidity of the European electricity market, and builds new connections to provide the market with new options. In so doing, Elia promotes competition between market players and encourages the more efficient use of the energy sources available in Europe, to boost the economy and improve welfare for all.

Besides Elia, many other key players contribute to the organisation of the Belgian electricity market. Here is a brief overview:

- **Generators/suppliers** are committed to meeting their customers' energy needs. They make sure their generation or import capacity is sufficient for meeting their obligations to customers.
- **Balance responsible parties** (BRPs¹) balance their customers' injections and offtakes every quarter of an hour.
- **Distribution system operators** (DSOs) manage the distribution of electricity to the businesses and private customers connected to their grid.
- The **federal government** determines general policy, including policy on the security of the energy supply.
- The **federal regulator CREG**² advises public authorities on the organisation and operation of the electricity market and fulfils the general task of supervising and monitoring the enforcement of relevant legislation and regulations.

1.2. Legal framework and process³

Articles 7bis to 7sexies of the Law of 29 April 1999 on the organisation of the electricity market ('Electricity Act') includes the following **timetable** for determining the volume of the strategic reserve (see also Figure 1.4):

¹ These may be generators, major consumers, electricity suppliers or traders, among other parties.

² CREG = Commission for Electricity and Gas Regulation

³ Some texts in this section are taken from the Electricity Act and are not available in English (only in French and Dutch). They are translated from those languages for the reader's information. Elia assumes no responsibility for the accuracy of the translation of these legal articles and, in case of any doubt, the original text prevails over these translations. This also applies to other translations from the Electricity Act provided in this report.




Figure 1.4



Art.7bis – 7sexies

- **Prior to 15 October:** DG Energy⁴ provides the grid operator with any relevant information for the probabilistic assessment.
- **By 15 November:** The grid operator carries out a probabilistic assessment which is submitted to DG Energy.
- **By 15 December:** DG Energy provides the Minister with an opinion on the need to constitute a strategic reserve for the following winter. If the opinion concludes that such a need exists, a volume for this reserve is suggested, expressed in MW.
- **One month after receiving DG Energy's opinion:** The Minister may instruct the grid operator to constitute a strategic reserve for a period of one year starting from the first day of the next winter period, and determines the size of this reserve in MW. The Minister notifies CREG of this decision. The decision, the grid operator's assessment and DG Energy's opinion are published on DG Energy's website.
- **One month after the Minister's instruction:** The grid operator starts the procedure for constituting strategic reserves. Offers should be submitted within three months after the start of this procedure.
- **10 working days after the latest submission date of offers:** The grid operator submits a report to CREG and the Minister regarding all received offers.
- **30 working days after receipt of the grid operators report:** CREG issues an advice that explicitly and in a motivated way indicates whether or not the price of all offers is manifestly unreasonable.
- **No later than 1 September:** The Minister may revise the required volume of strategic reserve if the circumstances regarding the security of supply have evolved, based upon an updated analysis of the grid operator and advice from DG Energy.

⁴ Directorate-General for Energy at Federal Public Service (FPS) Economy

- *The grid operator makes a techno-economic selection based on the offers that were considered as non-manifest unreasonable by CREG and will conclude contracts of this selection to the extent of the volume that was determined by the Minister.*
- **By 15 September:** *The offers of which the price was considered as manifestly unreasonable by CREG are rejected by the grid operator. If the total volume of offers of which the price was considered as non-manifestly unreasonable is insufficient to reach the required volume, the grid operator must report to the Minister, DG Energy and to CREG on the necessity of an additional volume.*
- *10 working days after the grid operator's report: DG Energy proposes to the Minister prices and volumes that could be imposed.*
- *The King may, for reasons of security of supply, impose by Royal Decree the necessary prices and volumes on one or more suppliers whose offer was considered by CREG as manifestly unreasonable.*

This law also includes the following **aspects** that must be borne in mind for the **probabilistic assessment** regarding the security of Belgium's supply for the winter ahead:



Art.7 bis §4

- *the level of security of supply that needs to be achieved;*
- *the generation and storage capacities that will be available in the Belgian control area, based on such factors as scheduled cases of decommissioning in the development plan referred to in Article 13, and the communications received pursuant to Article 4bis;*
- *electricity consumption forecasts;*
- *the possibilities for importing electricity, given the capacities of the interconnectors available to Belgium, and, as the case may be, an assessment of the availability of electricity in the Central West European electricity market;*
- *the grid operator may, subject to appropriate justification, supplement this list with any other item deemed useful.*

In 2018, the European Commission approved the Belgian strategic reserve mechanism until winter 2021-22 (inclusive) in the context of compliance with the State aid guidelines (EEAG).

1.3. Adequacy criteria

The Electricity Act describes the level of security of supply (i.e. adequacy) that Belgium needs to achieve. In the absence of harmonised European or regional standards, this level is determined by a **two-part loss of load expectation (LOLE) criterion** (see Figure 1.5). The model Elia uses for the probabilistic assessment enables both indicators to be calculated.



Figure 1.5



Art.2, 52° - 53°

- **LOLE:** A statistical calculation used as a basis for determining the anticipated number of hours during which, even taking account of interconnectors, the generation resources available to the Belgian electricity grid will be unable to cover the load⁵ for a statistically normal year.
- **LOLE95:** A statistical calculation used as a basis for determining the anticipated number of hours during , even taking account of interconnectors, the generation resources available to the Belgian electricity grid will be unable to cover the load for a statistically abnormal year.⁶

How to interpret the adequacy criteria

The indicative Figure 1.6 below shows how to interpret adequacy criteria. The probabilities of a large number of future states are calculated for a given winter (see section 8.1.1). For each future state, the model calculates the LOLE for the winter in question. The distribution of the LOLE across all the future states included can then be extracted.


For the first criterion, the average is calculated based on all these LOLE results⁷. For the second criterion (95th percentile), all the LOLE results are ranked. The highest value, after the top 5% of values have been disregarded, gives the 95th percentile (a 1 in 20 chance of such a loss of load expectation). The Electricity Act stipulates that **both criteria need to be satisfied for Belgium.**

In addition to the two criteria set out in the Electricity Act, the 50th percentile is also shown for all the results. This indicator shows a 1 in 2 chance of at least a given LOLE. The figure below also includes the 50th percentile, which except for in a few rare cases, is generally not the same as the average LOLE.

⁵ Load = demand for electricity

⁶ There is a 1 in 20 chance of a statistically abnormal year (95th percentile).

⁷ The average value for of a series of numbers (LOLE for each status) is calculated by totting them up and dividing the result by the number of numbers in the series.



In addition to covering the indicators outlined above, which only take account of the number of hours when a full energy supply cannot be provided, the model used by Elia also gives an indication of the scale of the energy shortage (energy not supplied, abbreviated ENS) during these hours and the likelihood of a loss-of-load situation occurring (loss of load probability, abbreviated LOLP):

- **ENS:** The volume of energy that cannot be supplied during hours when a loss of load occurs. This yields ENS (for a statistically normal year) and ENS95 (for a statistically abnormal year), expressed in GWh per annum.
- **LOLP:** The probability of a loss-of-load situation occurring at a given time, expressed in percent.

The lack of harmonised European or regional standards defining security of supply

In 2014, the Council of European Energy Regulators (CEER) published a report providing an overview of the adequacy assessments in various European countries [2]. That report highlighted the lack of harmonisation in the methodology and adequacy criteria used in these countries and its conclusions still apply to the present analysis.

In seven countries, Great Britain, France, the Netherlands, Finland, Hungary, Belgium and the Republic of Ireland, indicators are based on a probabilistic adequacy assessment. However, the criteria used differ (an LOLE of three hours per year in Belgium, France and Great Britain, of four hours per year in the Netherlands, and of eight hours per year in the Republic of Ireland). By contrast, Sweden and Spain apply a quantitative methodology based on the power balance (i.e. capacity margin).

To fulfil both legal criteria regarding security of supply, the required strategic reserve capacity is calculated based on an assumption of 100% availability. No distinction is made between demand reduction (SDR⁸) and generation capacity (SGR⁹):

- Where SGR is concerned, the assumption of 100% availability means that the strategic reserve will never require maintenance during the winter, nor will any unscheduled outage occur. This differs from how units available in the market are modelled.
- Where SDR is concerned, the assumption of 100% availability means that the strategic reserve can be called upon at any time throughout the winter, with no restriction on the number of activations or their duration.

The assumption of 100% availability of the SGR is important, especially where large volumes are involved, as a cold spell (occurring when the need for strategic reserve is at its greatest) may cause start-up problems for old generation units. The assumption of 100% availability of the SDR is equally important, as operational requirements may restrict the number and duration of activations.

Further information about the strategic reserve product and the operational requirements can be found on Elia's website [3].

1.4. General background information on the strategic reserve

1.4.1. How is a risk to security of supply identified operationally?

The potential security of supply risk in Belgium is assessed every day for the seven days ahead. The items deterministically assessed to ascertain whether there is an increased risk include:

- renewable energy generation forecasts;
- the latest information at Elia's disposal regarding the availability of conventional generation units;
- an appraisal of potential levels of imports;
- forecasts of Belgium's total electricity consumption.

These assessments are repeated, with forecasts becoming increasingly accurate the nearer they become to real time. Since the potential risk is determined on the basis of assumptions and forecasts, there is no absolute certainty that a shortage will actually occur.

1.4.2. If a risk to security of supply is identified, how is it communicated?

If the aforementioned assessments indicate a potential risk to the security of supply in Belgium, it is communicated to the relevant authorities and to the general public. The

⁸ SDR = strategic demand reserve

⁹ SGR = strategic generation reserve

'power indicator' on Elia's website and the 'Elia4cast' app were specially developed to communicate information [4] to the general public (see Figure 1.8).




Figure 1.8

At the same time, when a structural shortage¹⁰ is identified, this may prompt the activation of the strategic reserve. Notification of any such activation is published on Elia's website [5]. The strategic reserve may be activated by an economic or a technical trigger. Further information about these triggers can be found in the rules governing the functioning of the strategic reserve [6].

The strategic reserve is distinct from the usual mechanisms involving a balancing reserve that remedies immediate, unexpected imbalances, and thus maintains the balance in the Belgian control area at all times (see section 3.1.5).

Activation of the strategic reserve does not necessarily mean there is, or will be, a power outage. The strategic reserve is simply an extra means for avoiding any interruption in the power supply.

1.4.3. What measures will be taken if security of supply is jeopardised?

If Belgium's supply margins become drastically reduced (or even disappear altogether), a number of measures can be taken to tackle the problem (see Figure 1.9):

- A request to supply potential **additional uncontracted reserve volumes** will be sent to all balance responsible parties to allow Elia to call on any residual capacity at an available power plant or deploy extra means to control electricity

¹⁰ A structural shortage as defined in the rules governing the functioning of the strategic reserve [6] is a situation in which total consumption within the Belgian control area cannot be covered by the available generation capacity there, excluding balancing reserves and bearing in mind potential imports and energy available on the market.

consumption. Elia does this by using an RSS¹¹ feed to post a balancing warning on the web [7].

- If necessary, Elia will assess whether special measures can be taken in coordination and collaboration with the other transmission system operators (TSOs) in the CWE area¹² to further increase Belgium's **import capacity**.
- An economic or technical trigger may prompt the activation of Belgium's **strategic reserve**.
- If appropriate, Elia will draw on its **contracted balancing reserve volumes**. This involves such wide-ranging measures as activating special quick-start gas units, invoking contracts with aggregators¹³, reducing the consumption of industrial customers and requesting assistance from neighbouring TSOs.
- If market mechanisms and reserves prove insufficient, the authorities may decide to restrict **electricity consumption**. Steps to raise awareness, possibly coupled with prohibitive measures, may be taken first, to maintain grid balance over the hours or days ahead.
- One final measure for avoiding an uncontrolled general blackout across Belgium entails the controlled deployment of the **load-shedding plan**, with the ministers responsible for energy and economic affairs taking a decision on this the evening before the plan is activated.

NB: These measures will not necessarily be taken consecutively and may be taken by various entities (TSO, ministry, etc.).




Figure 1.9

¹¹ RSS = really simple syndication

¹² CWE: Central West Europe

¹³ An aggregator is a demand service provider that combines multiple short-duration consumer loads for sale or auction in organised energy markets.

1.4.4. Under what circumstances will the load-shedding plan be activated?

The load-shedding plan is a measure of last resort that can be used if all other mechanisms for ensuring adequacy are insufficient to balance supply and demand. It is in fact an emergency plan for the years ahead, which – like any other similar plan – can be implemented at any time of year to prevent the power grid from collapsing completely and causing a general blackout cutting off all consumers from the electricity supply. The plan entails disconnecting specifically targeted areas from the grid for a limited period to reduce power consumption.

Further practical details of the load-shedding plan (for example, regarding a specific street, the duration of the intervention, and communications in the event of an outage) can be found on the FPS Economy website [8].

What is a load-shedding plan?

Elia has devised a comprehensive load-shedding plan that can be implemented both automatically, in the event of a sudden problem with the frequency on the high-voltage grid, or manually, for example in an anticipated power shortage. Such an outage involves disconnecting DSOs' substations from the grid to keep the system balanced and prevent a general blackout across all of Belgium.

If such an outage occurs, various high-voltage substations belonging to a single load-shedding group will have to be disconnected simultaneously. The load-shedding plan was updated in 2015 and Belgium now has eight such groups, each of which corresponds to a capacity of between 500 and 750 MW. In total, they account for about 40% of total peak consumption. The new load-shedding plan has been operational since 1 November 2015.

The eight groups do not correspond to regional or local geographical areas. Municipalities from different parts of the country can belong to the same group, and a single municipality – or even street – may be supplied by a number of distribution points that are not even part of the same group. The situation may change further depending on specific factors, such as work on the distribution grid.

The **legal framework** for the load-shedding plan is set out in the ministerial decree of 3 June 2005 on the establishment of the load-shedding plan for the electricity transmission network, which forms part of the Defence Plan pursuant to Article 312 of the Royal Decree of 19 December 2002 establishing a grid code for the management of the electricity transmission grid and access thereto.

1.5. History and current situation of strategic reserve constitution

Since the introduction of the strategic reserves in winter 2014-15, there has been a strategic reserve volume for each winter period (see Figure 1.10). More specifically, the strategic reserve for **winter 2014-15** comprised:

- 750 MW of generation capacity, for three years;
- 96.7 MW of load-shedding capacity, for one year.

The strategic reserve for **winter 2015-16** partly constituted the capacity since 2014 (three-year period) and partly new reserve capacity. On 1 November 2015, the following capacity was included in the strategic reserve:

- 750 MW of generation capacity, since 2014;
- 427.1 MW of additional generation capacity, for one year;
- 358.4 MW of load-shedding capacity, for one year.

For **winter 2016-17**, no additional volume was acquired. However, 750 MW of generation capacity was still retained (part of the three-year period since 2014). Therefore, on 1 November 2016, the strategic reserve included:

- 750 MW of generation capacity, since 2014.

For **winter 2017-18**, no capacity was contracted in advance. On 1 November 2017, the strategic reserve comprised:

- 725 MW of generation capacity, for one year.

For **winter 2018-19**, although last year's report showed a need for 500 MW, and despite the Minister's initial instruction to constitute a strategic reserve of 500 MW, in summer 2018, based on the latest data available at the time of the assessment, namely on thermal capacities, the Minister requested that the volume be revised. The assessment performed for this revision showed no need for a strategic reserve, so in the end no capacity was contracted.




Figure 1.10

1.6. Public consultations regarding strategic reserve volume calculations

The problems Belgium could face in winter, adequacy and the strategic reserve mechanism are all becoming higher-profile issues in energy-related discussions. Due to Elia's designated roles and responsibilities, in particular regarding the strategic reserve mechanism, the company is responding to the market players' demand for a better

understanding of how the strategic reserve volume is calculated and for an opportunity to have a greater say in it.

In this context, Elia launched **two public consultations** in 2018: the first on methodology, assumptions and data sources, and the second on the raw input to be used for setting the volume. Figure 1.11 shows when these consultations took place.




Figure 1.11

The consultations were announced at meetings of the Task Force 'Implementation Strategic Reserves', more specifically on 23 April 2018 for the first consultation and on 9 July 2018 for the second consultation.

Both consultations were announced on Elia's homepage and on each occasion all the relevant stakeholders (members of the Task Force 'Implementation Strategic Reserve', the contractual contact points known by the Customer Relations Department and the Belgian regulator CREG) were informed by e-mail.

1.6.1. Feedback from stakeholders

For each consultation, Elia received four responses from stakeholders during the consultation period. These responses can be found on Elia's website [9].

Elia replied to each response. Its replies were then aggregated and grouped by subject in two separate consultation documents. Oral explanations of its replies were given at the Task Force 'Implementation Strategic Reserve' meeting on 9 July 2018 for the first consultation, and on 25 September 2018 an overview of the received responses was provided for the second consultation.



PUBLIC CONSULTATION 1

Content: methodology, assumptions, data sources

Consultation Period: 23 April to 21 May 2018 at 18:00

Responses received: 4

Subjects: Data, Assumptions, Publication of results, Market Response, Flow Based

Consulted document and Consultation Report: [9]



PUBLIC CONSULTATION 2

Content: raw input data

Consultation Period: 27 August to 24 September 2018 at 18:00

Responses received: 4

Subjects: Data, Assumptions, List of Power Plants, Demand Growth, Market Response, Flow Based

Consulted Document and Consultation Report: [9]

Figure 1.12

1.6.2. Follow-up to the consultation

Elia examined the various suggestions and various actions were taken to update the data.

Methodological improvements compared to previous years are explained in more detail in section 1.7 below. Moreover, this report has been expanded to properly address the aspects raised in the consultation. Specifically, this involves providing further information about the assumptions made and more background information on the results. A special effort has been made to provide an in-depth analysis of the main new elements impacting the assessment of required volumes, namely the effect of new interconnectors and/or increases in cross-border capacity within the CWE region.

1.7. Methodology and modelling improvements from the previous assessment

Following the public consultation on methodology, hypotheses and data sources, several improvements in the modelling were implemented for this assessment. Below we include an overview of the new methodological improvements that were considered in the assessment for winter 2019-20, compared to the assessment performed for winter 2018-19:

Profiled thermal power plant modelling

Elia performed an in-depth analysis of the available metering data for thermal non-CIPU units (mainly smaller biomass, waste & CHP units) to identify the primary drivers and create production profiles that match the aggregated behaviour of these units. What emerged was a very strong correlation between the daily average temperature and daily production. This led to the creation of 34 temperature-dependent production profiles, one for each climatic year. These new profiles provide a better match than those used in previous analyses, both regarding their hourly shape and annual energy production.

Flow-based modelling

A revision of the selection process of typical days and their corresponding flow-based domains from the flow-based operational environment was followed. Data comprising observations of the previous 2017 year was used for this purpose. Also special focus was on ensuring consistency with the Standard Process to Assess the Impact of significant Changes (SPAIC) within the CWE Flow Based consultation group towards Market Parties, as well as with ongoing national and regional adequacy assessments including flow-based methods (see section 5.1 for more details).

A systematic approach for correlating the flow-based domains with climatic data is taken into account, following the approach developed and used last year. This approach enables, for example, specific combinations of climatic factors, like wind, and demand to be linked with the representative flow-based domains to be considered in the simulations (see section 5.1).

Finally, a 20% minimum remaining available margin (minRAM20%) for day-ahead flow-based market coupling (FBMC) domains used in the assessment is considered. The effect of minRAM20% is taken into account as a baseline assumption in this volume assessment for strategic reserves, since this feature is currently operational in the capacity calculation of the FBMC framework. Notwithstanding the daily verification of the minRAM20% feasibility by the TSOs, it is assumed that especially if any country suffers severe adequacy issues, every effort will be made to ensure the application of the minRAM20% principle.

Growth in demand

Some stakeholders voiced concerns regarding the method Elia uses to forecasts total load growth. To accommodate these concerns, Elia engaged with the external consultant IHS Markit to gain a deeper insight into the demand modelling framework used. In

In addition, the various 'European energy scenarios' developed by IHS were further analysed with a view to concluding which one was the most appropriate in the context of determining the strategic reserve volume. Finally, certain checks were carried out to compare historical IHS forecasts with the most recent historical total load figures, to confirm the soundness of the approach. All these findings were either communicated via the methodology consultation report or via the Task Force 'Implementation Strategic Reserves' and are further elaborated in this volume report.

Market response

The methodology for evaluating the available market response, developed in close cooperation with the stakeholders in the context of determining the strategic volume for winter 2017-2018, is now widely accepted. The process entails both a qualitative and quantitative analysis. As agreed with stakeholders, this year only the quantitative part, i.e. the analysis of aggregated power-exchange data, was carried out, to update the figures on the available market response (see section 3.3).

1.8. Other adequacy studies with results relevant to Belgium

In addition to this report, other, similar ones deal with the same subject, though each has its own special focus, methodology and time horizon. Figure 1.13 affords a general overview. Each study is then presented in further detail below.




Figure 1.13

Elia is committed to ensuring a high level of consistency between the above-mentioned assessments by:

1. developing and applying a common probabilistic methodology;
2. ensuring the complementarity of the results obtained by different studies.

The pan-European, regional and national studies featured above share the same probabilistic methodology, therefore enabling consistent analyses and comparisons. It is also worth noting that due to the different scope, purpose and time of completion of the different studies, some updates in the methodological assumptions and data may be worth considering.

1.8.1. Elia's 2017-2027 adequacy and flexibility study



Elia adequacy and flexibility study 2017-2027

LINK:	[12], [13]
METHOD:	Probabilistic
TIME-FRAME:	2017-2021-2023-2027
Latest publication:	04/2016 and 09/2016
Scope	19 countries
Country results:	Belgium
Frequency of publication:	Within the updated electricity law, biannual publication. Next edition will be issued in 2019

Based on Elia's expertise in analysing security of supply, the Belgian federal Minister for energy assigned Elia two specific missions for 2016.

The first mission was to carry out a long-term predictive analysis (covering the period 2017-2027) of the adequacy of electricity generation in relation to consumption and assess the need for flexibility in the electricity system.

Elia conducted the study, which is essentially a quantitative analysis of Belgium in the context of the European market. While the study's scope comprised 19 European countries, the findings focus solely on Belgium.

Given the broad scope of such an analysis, the methodology and assumptions were developed in close collaboration with DG Energy and the federal Minister for energy. In addition, full transparency was ensured for the report and its findings. Accordingly, special workshops and presentations were held and the full report is available on Elia's website [11].

The second mission followed up on its predecessor. More specifically, following the publication of the first study, DG Energy organised a public consultation, open to all market actors and institutions in Belgium.

This public consultation led to Elia being requested to analyse an additional scenario (produce an 'addendum') with regard to the need for adequacy and flexibility in the Belgian electricity market over the period 2017-2027.

This addendum relied on the same methodology albeit with a few changes to the initial assumptions, as determined by the federal Minister for energy. It was also presented to and shared with market parties and is publicly available on Elia's website [12].

The updated Electricity Act provides for this study to be carried out biannually. The next edition will be published in 2019.

1.8.2. Electricity Scenarios for Belgium towards 2050



Electricity Scenarios for Belgium towards 2050

LINK:	[77]
METHOD:	Probabilistic
TIME-FRAME:	2030-2040-2050
Latest publication:	11/2017
Scope	22 countries
Country results:	Belgium
Frequency of publication:	ad hoc Elia publication

This study builds on the Elia report entitled *The need for adequacy and flexibility in the Belgian electricity system for 2017-2027* (see above).

This study analysed both short-term and long-term policy options regarding the future energy mix for Belgium between now and 2050, bearing in mind the planned nuclear phase-out in 2025, and striving to establish a sustainable, adequate electricity system.

In addition to quantifying the various future scenarios for 2030 and 2040, the study also focused on a few options for sustainability and ensuring short-term security of supply. These options are needed to cope with the planned 2025 nuclear phase-out and provide sufficient replacement capacity to guarantee security of supply.

1.8.3. ENTSO-E: Outlook reports



ENTSO-E Winter and Summer outlooks

LINK:	[78]
METHOD:	Deterministic
TIME-FRAME:	next winter/summer
Latest publication:	every 6 months
Scope	all pan EU perimeter
Country results:	all pan EU perimeter
Frequency of publication:	Twice a year

Every year, ENTSO-E¹⁴ publishes a report entitled *Winter Outlook and Summer Review*. One of the focal points of this short-term report is the main adequacy risk for the winter ahead. The report considers various uncertainties such as climatic conditions, outages of generation units, load prospects and load management and stability issues affecting the electricity grid. It also sums up the main events from the previous summer. The purpose of the document is to establish a platform where TSOs can exchange information, create transparency and inform stakeholders about potential risks for the winter ahead.

For the winter period, the report presents an overview of the national and regional power balances between available generation capacity and forecast load. ENTSO-E gathers the information to compile this deterministic assessment using a qualitative and quantitative questionnaire completed by each individual TSO. A similar report is also published every year for the following summer period.

¹⁴ ENTSO-E = European Network of Transmission System Operators for Electricity Organisation, representing 41 TSOs from 34 European countries

Ongoing discussions within ENTSO-E are geared towards seeing the report develop into a probabilistic assessment.

1.8.4. ENTSO-E: Mid-Term Adequacy Forecast



ENTSO-E Mid Term Adequacy Forecast

LINK:	[16]
METHOD:	Probabilistic
TIME-FRAME:	2020 - 2025
Latest publication:	10/2018
Scope	all pan EU perimeter
Country results:	all pan EU perimeter
Frequency of publication:	Yearly

Every year, until 2015, ENTSO-E published the *Scenario Outlook & Adequacy Forecast* (SO&AF), a report based on a deterministic method. In 2016, the first *Mid-Term Adequacy Forecast* (MAF) was published following a probabilistic method like the one Elia uses to assess the volume of strategic reserve. The latest edition of this report, MAF 2018, has been published and submitted for public consultation [15], giving stakeholders in the European energy market an overview of the national and European adequacy situation. The assessment uses best-estimate scenarios based on bottom-up data collection from TSOs, and focuses on the LOLE and ENS as adequacy indicators. The 2016, 2017 and 2018 reports all include an assessment for 2020 and 2025 covering all European countries. The MAF study is the first pan-European adequacy assessment to use several probabilistic models but follow the same methodology.

Elia is an active contributor, as one of the MAF modelling parties and by helping to improve the methodology and modelling for subsequent editions, since the planned improvements are entirely consistent with Elia's adequacy assessment approach.

1.8.5. Pentalateral Energy Forum (PLEF): Regional Generation Adequacy Assessment



Penta Lateral Energy Forum Adequacy study

LINK:	[79]
METHOD:	Probabilistic
TIME-FRAME:	2018-19 - 2023-24
Latest publication:	01/2018
Scope	all pan EU perimeter
Country results:	AT,BE,CH,DE,FR,LU,NL
Frequency of publication:	ad hoc request by PLEF Ministries

The TSOs belonging to the PLEF (BE, DE, FR, LU, NL, AT and CH) region published a regional adequacy study in early 2015, based on suitable probabilistic methodology (the same as used by Elia). This study assesses the main adequacy indicators (LOLE and ENS), both for the countries covered and for the entire region. The study analysed both winter 2015-16 and winter 2020-21 and was published in March 2015.

The second PLEF adequacy assessment was published in early 2018 and covered winters 2018-19 and 2023-24. Elia is actively contributing as one of the modelling parties within PLEF.

The next PLEF study will be carried out at the end of 2019 and is expected to be published in early 2020.

1.9. Disclaimer


This report provides a probabilistic assessment of Belgium's security of supply and the need for strategic reserves for the winters in 2019-20, 2020-21 and 2021-22. The assessment is based on the following key assumptions:

Within the calculated volume, no distinction is made between demand reduction and generation capacity. The calculated volume is considered to be 100% available.

The volume calculation disregards the possibility of actually being able to find this volume in the Belgian market.

Elia would like to stress that the conclusions of this report are inextricably linked to the initial assumptions set out in it. Elia is not liable for the realisation of these assumptions, as in most cases they relate to developments falling outside the direct control of the grid operator.

2 Methodology



The volume of strategic reserve needed for a specific winter is determined using the iterative process depicted in Figure 2.1. First it is ascertained whether a margin or necessary strategic reserve volume has been identified for the situation under consideration. If both the relevant legal criteria are not met, then additional strategic reserve volume is needed. On the other hand, if the simulation without any additional volume of strategic reserve already complies with both legal criteria, the margin on the system will be examined. The extra volume or margin is increased by 100 MW blocks until the legal criteria are met. 100 MW-block resolution is also used in adequacy analyses performed by other TSOs as well as in ENTSO-E analyses.




Figure 2.1

At each step of this iteration, a full probabilistic simulation of the Western European electricity market is carried out. This **simulation**, performed on an hourly basis for the winter in question, is described in **section 2.1**. The hourly output of this simulation is subsequently analysed to determine whether the two adequacy criteria are fulfilled. **Section 2.2** sets out how **hours in which a structural shortage is present are identified**. Depending on whether a margin or a needed volume of strategic reserve is sought, the iterative process is halted as specified in Figure 2.1.

2.1 Probabilistic simulation of the Western-European electricity market

Each iteration initially entails carrying out a probabilistic simulation of the Western European electricity market, in two separate steps:

1. Construction of 'Monte Carlo' years (section 0);
2. Simulation of each 'Monte Carlo' year (section 2.1.2).

This section briefly summarises how the probabilistic simulation is performed. The whole simulation process, as well as the tools and methods used, are described in greater **detail in the appendix** (section 8.1).

As Belgium depends on electricity imports for its security of supply, the modelling has to include the neighbouring countries. This study involved the individual modelling of 20 neighbouring countries, as shown in Figure 2.2, namely: :

- Austria (AT)
- Belgium (BE)
- Switzerland (CH)
- the Czech Republic (CZ)
- Germany (DE)
- Denmark (DK)
- Spain (ES)
- France (FR)
- United Kingdom (GB and NI)
- Hungary (HU)
- the Republic of Ireland (IE)
- Italy (IT)
- Luxembourg (LU)
- the Netherlands (NL)
- Norway (NO)
- Poland (PL)
- Portugal (PT)
- Slovenia (SI)
- Slovakia (SK)
- Sweden (SE)

Due to the specific market situation in Italy, Denmark, Norway and Sweden, these countries are modelled using multiple market nodes. This type of specific modelling is in line with the real market situation, and is identical to the approach used in other studies, e.g. at ENTSO-E.

For the probabilistic simulation, 20 countries are modelled individually.



Figure 2.2

In the assessment, 20 countries are modelled in detail. This makes it possible to determine the available generation capacity abroad when Belgium needs to import energy.

2.1.1 Construction of 'Monte Carlo' years

For each of the countries simulated, a large number of future states – also called 'Monte Carlo' years – are constructed. Each future state is established based on historical meteorological data (on wind, sun, temperature and precipitation), the unavailability of power plants and HVDC links, by combining different climatic conditions with the random availability of power plants and HVDC links, as illustrated in Figure 2.3. For this analysis, climatic variables are modelled using data from 33 past winters.




Figure 2.3

2.1.2 Simulation of each 'Monte Carlo' year

Constructed 'Monte Carlo' years are then input into the simulation of the Western European electricity market. The power plants' economic dispatching is then detailed. This assessment considers, among other things, power plants' marginal costs and enables pumped-storage power plants and other hydroelectric storage facilities to be appropriately modelled. Furthermore, the modelled adequacy assessment rightly takes account of the fact that in periods of structural shortage, all available generation facilities will be taken into account, operating at maximum capacity, to minimise the shortage.

The market simulator used in the scope of this study is ANTARES¹⁵, a sequential 'Monte Carlo' multi-area simulator developed by French TSO RTE to assess generation adequacy problems and economic efficiency issues. The model's inputs and outputs are depicted in Figure 2.4.




Figure 2.4

¹⁵ <https://antares.rte-france.com/>

2.2 Identifying periods of structural shortage

The **second part of each iteration step** involves **identifying periods of structural shortage**, i.e. times when electricity generation and imports are insufficient to meet demand. To this end, the output of the probabilistic market simulation is assessed on an hour-by-hour basis by simulating the European electricity market.

Figure 2.5 exemplifies how consumption is covered by the available generation facilities and imports for every hour of the week. If, for a given hour, the combination of generation capacity, imports and market response falls short (by 1 MW or higher) of the capacity required to meet demand, this corresponds to one hour of structural shortage, or 'energy not served' (ENS) situation. Within the Monte Carlo approach, the mean total of all such hours is referred to as loss of load expectation (LOLE). Figure 2.5 shows the energy that cannot be supplied by combining domestic generation and imports.






Figure 2.5

3 Assumptions about the power supply and electricity consumption in Belgium



This chapter elaborates the assumptions used in this analysis for Belgium. Section 3.1 details the hypotheses used with regard to the Belgian electricity supply. Section 3.2 details the demand for electricity in Belgium and how its specifics are incorporated into the model. Section 3.3 details the Belgian market response. Finally, section 3.4 summarises the input data for Belgium.

Furthermore, according to Article 7quater of the Electricity Act, the Minister can review the volume for the strategic reserves no later than 1 September 2019 for winter 2019-20. Such a decision by the Minister must be based on a probabilistic 'updated analysis' by Elia with respect to the analysis performed and presented here. When preparing this updated analysis, Elia must only take account of the following information, which is sufficiently relevant to the capacity and use of facilities for the generation, storage, consumption or transmission of electricity or natural gas or related to the capacity and use of LNG facilities, including the scheduled or unplanned unavailability of these facilities, e.g.:

- any inside information published in accordance with Regulation 1227/2011 on wholesale energy market integrity and transparency;
- any concrete and relevant information that entails a formal commitment by a relevant entity and is explicitly communicated to Elia by or on behalf of said entity;
- any information that the Minister explicitly asks Elia to take into consideration.

Elia organised a public consultation on the detailed assumptions used for Belgium in this analysis (see section 1.6 for more information), thereby contributing to a more transparent flow of information on the Belgian electricity system.

Elia publishes a large volume of real-time data on its website [24] to give stakeholders an overview of the Belgian transmission system. The datasets made publicly available on Elia's website include:

- the total load in Belgium and the load on Elia's grid;
- photovoltaic and wind generation data and forecasts;
- generation capacity forecasts.

These datasets, along with many others, can be downloaded for detailed analysis. Furthermore, Elia contributes to the ENTSO-E transparency platform [26] by providing real-time data.

3.1 The electricity supply in Belgium

The ANTARES model takes account of thermal generation facilities, renewable energy sources and other electricity generation for each country covered by the simulation. In line with Article 7bis of the Electricity Act, Elia received input from the Directorate-General of Energy at Federal Public Service (FPS) Economy prior to the analysis. The information received from FPS Economy was included in the report and taken on board in the analysis.



This section provides an overview of the assumptions made with regard to the Belgian electricity supply. The modelling details are provided in section 8.1 (Appendix).

3.1.1 Wind and solar forecasts

The FPS Economy consults Belgium's three regional authorities to obtain forecasts for the installed capacity of onshore wind and photovoltaic production. Further details of these forecasts are provided in sections 0 and 3.1.1.3. Elia takes as its basis the latest information available to consolidate a forecast of the installed capacity of offshore wind. This is further elaborated in section 3.1.1.2.

3.1.1.1 Wind onshore

Figure 3.1 shows the actual increase over time in the installed capacity from onshore wind generation and the forecast consolidated by the FPS Economy. The average forecast development amounts to a yearly increase of approximately 230 MW. For information purposes, the geographical distribution of onshore wind farms in Belgium (as at the end of 2017) is shown in Figure 3.2.



230 MW/year




Figure 3.1




Figure 3.2

3.1.1.2 Wind offshore

The Belgian government has awarded domain concessions for the construction and exploitation from offshore wind generation to nine wind farms (see Figure 3.3). The commissioning of the Rentel wind farm in 2018 will increase the total installed capacity from offshore wind generation to 1,179 MW by the end of 2018. Figure 3.4 shows the historical increase in installed capacity of offshore wind and the forecast installed capacity taken into account for the purposes of this analysis, which is a best estimate based on the latest information available to Elia.



Figure 3.3

Evolution and forecast of installed capacity offshore wind




Figure 3.4

3.1.1.3 Solar

Figure 3.5 shows the historical increase in installed capacity from photovoltaic (PV) generation in Belgium and the forecast used in this analysis, which was consolidated by the FPS Economy. The average yearly increase is approximately 490 MW. For information purposes, the geographical distribution of installed PV capacity in Belgium as at the end of 2017 is shown in Figure 3.6.



+ 490 MW/year




Figure 3.5




Figure 3.6

3.1.2 Biomass, waste and CHP facilities

This section elaborates on the installed capacity of biomass, waste and combined heat and power (CHP) production facilities in Belgium. Elia maintains a database of centralised and decentralised generation units, which is updated on a monthly basis following exchanges with DSOs and direct clients of Elia. The database includes units covered by a CIPU¹⁶ contract as well as units not covered by such a contract.

Owners of units covered by a CIPU contract must notify Elia about these units' availability and provide Elia with both long-term (one-year) and short-term (one-day) availability forecasts. In general, units not covered by CIPU contracts have a lower installed capacity. It has been agreed with DSOs that all units with an installed capacity of more than 0.4 MW must be reported to Elia for inclusion in the database. In practice, many units with an installed capacity of less than 0.4 MW are also reported, either individually or on an aggregated basis. The database contains information concerning units that are **in service** as well as on projects that are currently **under development**.

Following a discussion with the FPS Economy, it was decided to determine installed **biomass** generation capacity based on the information in the Elia generation unit database. Subsequently, a capacity growth rate determined by the FPS Economy after consultation with the Regions was added to predict the installed generation capacity for the next three winters. This forecast is globally in line with the information in the Elia database. Figure 3.7 shows the forecast increase in installed capacity from biomass generation in Belgium. The figure differentiates between units covered by a CIPU contract and units not covered by such contracts. Furthermore, 'additional biomass units' are included in keeping with the forecast provided by the FPS Economy. These additional biomass units not deemed to be subject to a CIPU contract. For information purposes,

¹⁶ CIPU: Contract for the Injection of Production Units. The signatory of the CIPU contract is the single point of contact at Elia for aspects relating to the management of the generation unit injecting electricity into the high-voltage grid. The CIPU contract serves as the basis for the provision of other reserve power, and the activation by Elia of such reserve power.

the geographical distribution of biomass generation units with a CIPU contract is shown in Figure 3.8.




Figure 3.7




Figure 3.8

Similarly, it was decided to determine installed **CHP and waste generation** capacity based on the information in the Elia generation unit database. Only projects communicated to Elia that are in a sufficiently mature phase of development were included in this analysis. Figure 3.9 shows the forecast increase in installed capacity from CHP and waste generation. Again, the figure differentiates between units covered by a CIPU contract and those not covered by such contracts. Based on Elia's generation database, no notable change is predicted regarding the installed capacity of waste-powered units, and an increase of approximately 80 MW is anticipated for CHP units not covered by a CIPU contract.




Figure 3.9

For information purposes, the geographical distribution of installed capacity from CHP and waste generation units covered by a CIPU contract is shown in Figure 3.10 and Figure 3.11.

Total installed CIPU CHP capacity available in Belgium for all studied winters




Figure 3.10

Total installed CIPU waste capacity available in Belgium for all studied winters




Figure 3.11

3.1.3 Thermal generation under a CIPU contract

This section details Belgian thermal generation units covered by a CIPU contract. Biomass, waste, and CHP generation units covered by such contracts were discussed in section 3.1.2 above. Section 3.1.3 below presents the installed capacity from thermal units covered by a CIPU contract. Since such units are modelled individually, outages of individual units are taken into account. This is described in greater detail in section 3.1.3.2.

3.1.3.1 Installed capacity from thermal generation by units covered by a CIPU contract

The installed capacity of Belgian thermal generation by units covered by a CIPU contract is consolidated by Elia and the FPS Economy based on information submitted by producers to the federal Minister for energy, the FPS Economy, CREG and Elia, as stipulated in the Electricity Act. These parties cannot be held accountable for actually realising the hypothetical volumes, as this is the producers' responsibility. Figure 3.12 shows the forecast output from thermal generation units covered by a CIPU contract.

Section 3.1.2 already provided equivalent details for Belgian **biomass, waste and CHP** units covered by a CIPU contract. In April 2016, the decommissioning of the Langerlo plant marked the closure of the last big **coal-fired generation facility** in Belgium.




Figure 3.12

The hypothesis used in this analysis regarding installed capacity from **nuclear** generation is aligned with the law governing the nuclear phase-out, which has been amended twice:

- in 2013, to extend the working life of the Tihange 1 power plant (installed capacity of 962 MW) by 10 years;
- in June 2015, when the Belgian government decided that the Doel 1 and Doel 2 nuclear power plants (each with an installed capacity of 433 MW) could stay operational for an additional 10 years.

In line with the amended Belgian law on the nuclear phase-out, it is assumed that in the base case all seven nuclear reactors (with a total installed capacity of 5,919 MW) will remain in service for the entire period covered by the study. Figure 3.13 provides the geographical locations of installed capacity from nuclear electricity generation.

For all generation units considered in the market, all calculations take account of their scheduled maintenance as announced by their owners in line with the REMIT transparency regulation and of CIPU processes, forced outages and rates of use based on an analysis of their historical unavailabilities. This is explained in detail in section 3.1.3.2.




Figure 3.13

The installed capacity of **CCGT** plants for winter 2018-19 is noticeably higher than the figure in last year's report. This is due to the definitive return to the market of the Seraing CCGT plant [77] (485 MW). Moreover, the Vilvoorde CCGT unit, Ham CCGT unit [76] and Langerlo GT unit announced their temporary return to the electricity market for winter 2018-19 only. According to the owner of the Drogenbos CCGT unit, which can operate both in combined-cycle (460 MW) and open-cycle (230 MW) mode, it will be considered as a combined-cycle unit for the entire timeframe of the study.

For information purposes, the geographical distribution of CCGT and OCGT units in Belgium is shown in Figure 3.14 and Figure 3.15 respectively. The installed capacity from turbojet units in Belgium is summarised in Figure 3.16.




Figure 3.14




Figure 3.15



Art.4bis, §1

Legal notice period for production facility closure according to Article 4bis

The article setting the rules for the closure of a production power plant was changed during the course of 2018. Its full version, too long to be copied in this document, can be found on the Belgian ejustice website in Dutch and French [78].

Total installed turbojet capacity available in Belgium




Figure 3.16

3.1.3.2 Availability of thermal generation covered by a CIPU contract

Belgian thermal generation units covered by a CIPU contract are modelled individually in the ANTARES model. The analysis takes account of two types of unavailability for CIPU generation units:

- **planned unavailability**, usually for maintenance;
- **unplanned unavailability**, usually caused by an unexpected malfunction.

3.1.3.2.1 Planned unavailability

Owners of all generation units with an installed capacity of at least 100 MW are obliged to transparently publish the latest information on the unavailability of units in their fleet via official transparency channels (REMIT), over a three-year time horizon. The assumptions made in this study regarding planned unavailabilities of Belgian generation units are based on the latest information available via the relevant market transparency channels (REMIT).

As the maximum availability of domestic generation during the winter period is crucial for Belgium to maintain its adequacy, Elia urged the owners of the generation units' concerned to maximally avoid all planned maintenance of their units during the winter period (for details, see *Method and hypotheses used for the calculation of the maximal maintenance curve* below).

Nevertheless, the extracts from the transparency channels from 22 October 2018 to 8 November 2018, which were used for this study contained some planned unavailabilities in winter periods. Below is an exhaustive list of those unavailabilities, which were taken into account for our analysis:

- TIHANGE 1N undergoing maintenance from 3/08/2019 until 28/11/2019 (inclusive)
- TIHANGE 1S undergoing maintenance from 3/08/2019 until 28/11/2019 (inclusive)
- DOEL 1 undergoing maintenance from 24/08/2019 until 27/12/2019 (inclusive)
- DOEL 2 undergoing maintenance from 31/08/2019 until 20/12/2019 (inclusive)
- MARCINELLE ENERGIE (Carsid) undergoing maintenance from 21/12/2019 until 29/12/2019 (inclusive)
- RODENHUIZE 4 undergoing maintenance from 28/12/2019 until 29/12/2019 (inclusive)
- RODENHUIZE 4 undergoing maintenance from 14/03/2020 until 22/03/2020 (inclusive)

Planned outages winter 2019-2020						
Unit	Fuel	Pmax Available (MW)	Pmax Available after Outage (MW)	Start Outage	(Estimated) End Outage	
TIHANGE 1S	NU	481	0	03/08/2019	28/11/2019	
TIHANGE 1N	NU	481	0	03/08/2019	28/11/2019	
DOEL 1	NU	433	0	24/08/2019	27/12/2019	
DOEL 2	NU	433	0	31/08/2019	20/12/2019	
MARCINELLE ENERGIE (Carsid)	NG	413	0	21/12/2019	29/12/2019	
RODENHUIZE 4	Other	268	0	28/12/2019	29/12/2019	
RODENHUIZE 4	Other	268	0	14/03/2020	22/03/2020	

source: <http://www.elia.be/en/grid-data/power-generation/unplanned-outages>

3.1.3.2.2 Unplanned unavailability

On top of planned unavailability, this study also takes account of unplanned or forced unavailability. An analysis was carried out for each generation type (CCGT, gas turbine, turbojet, etc.), based on historical unplanned unavailability for the period 2007-17 and using the availability information for generation units nominated in the day-ahead market. The results are shown in Figure 3.17.

Belgian average forced outage rate over 2007-2017 per production type




Figure 3.17

The current expected unavailabilities of the Doel 1 (April 2018 until December 2018), Doel 2 (May 2018 until December 2018), Doel 3 (March 2014 to December 2015 and during 2018 until August of that year), Doel 4 (August 2014 to December 2014 and August 2018 to December 2018), Tihange 1 (September 2016 to May 2017 and October 2018 to 12 November 2018), Tihange 2 (March 2014 to December 2015 and August 2018 until May 2019) and Tihange 3 (April 2018 until March 2019) nuclear plants were not taken into account when determining the above-mentioned forced outage rates. Given the specific nature of these unavailabilities, it was decided to analyse such events as a 'sensitivity' instead (see chapter 6.3.1).

An analysis of the forced outage rates of Belgian generation units showed that they can differ greatly from one year to the next. In Figure 3.18

and Figure 3.19, this variability is illustrated for CCGT and nuclear units respectively. It can be observed that the forced outage rate for Belgian CCGT units has been dropping in recent years. One possible explanation for this is that older CCGT units have been taken out of operation.

Forced outage rate for Belgian CCGT power plants per year




Figure 3.18

Forced outage rate for Belgian nuclear power plants per year




Figure 3.19

In addition to analysing the frequency at which unplanned outages affecting Belgian generation units occur, we also modelled the duration of these outages. For unavailability of a very short duration (i.e. intra-day outages), balancing reserves can be used (see section 3.1.5). Consequently, such outages do not need to be taken into account when calculating the required strategic reserve volume.

For each type of generation unit, the probability associated with the duration of an unplanned unavailability was modelled separately. An analysis of the historical durations of forced outages showed that unavailabilities usually lasting a limited number of days. However, lengthier unplanned unavailability can also occur, as illustrated in Figure 3.20 ('Duration of unavailability' indicates the number of days), where the duration curve for forced outages of CCGT power plants was analysed.

Example: distribution of the duration of an unavailability for one type of production units (based on the analysis of historical data).




Figure 3.20

Method and hypotheses used for calculating of the optimal maintenance curve

Every year, on a fixed date, the access responsible parties (ARPs) submit a proposed maintenance schedule for their generation units to the TSO. If a risk of a one-off or structural shortage is identified, the TSO has the option of modifying these maintenance schedules:

- The TSO determines the **optimal maintenance curve** for Belgian generation units on an annual basis. For each week of a full calendar year, this curve indicates the total generation capacity that can undergo maintenance. The curve is based on a **probabilistic analysis**, taking account of the following adequacy criterion: the 95th percentile of the remaining available capacity that can undergo maintenance, calculated on an hourly basis. Elia uses the **same type of model and the same hypotheses** to determine the required strategic reserve volume, but modified to cover a complete calendar year.

By way of illustration, Figure 3.21 shows the result of the aforementioned exercise for 2018. The orange area shows the optimal maintenance curve, with the solid line indicating current scheduled maintenance. Since Elia strives to avoid overhauling power plants during the winter, no maintenance capacity is available in wintertime.

Current planned overhauls go 'outside the ORP curve' and extend into the winter period, as indicated by the red curve in the figure below between weeks 44 and 52. Current planned overhauls include the following winter maintenance occurring in 2019 (as mentioned above and considered in the assessment):

- TIHANGE 1N undergoing maintenance from 3/08/2019 until 28/11/2019 (inclusive)

- TIHANGE 1S undergoing maintenance from 3/08/2019 until 28/11/2019 (inclusive)
- DOEL 1 undergoing maintenance from 24/08/2019 until 27/12/2019 (inclusive)
- DOEL 2 undergoing maintenance from 31/08/2019 until 20/12/2019 (inclusive)
- MARCINELLE ENERGIE (Carsid) undergoing maintenance from 21/12/2019 until 28/12/2019 (inclusive)
- RODENHUIZE 4 undergoing maintenance from 28/12/2019 until 29/12/2019 (inclusive)




Figure 3.21

3.1.4 Hydroelectric power stations

The Belgian electricity system includes two types of hydroelectric power station:

- pumped-storage units;
- run-of-river units.

Belgium has 10 **pumped-storage** units, six at Coe and four at Plate Taille. The total installed turbine capacity is 1,308 MW, with a combined storage capacity of approximately 5,800 MWh. Pumped-storage units are typically also used to provide ancillary services. Accordingly, specifically to account for the provision of 'black start' services, the total storage capacity available for economic dispatch in this analysis is reduced by 500 MWh, lowering the available storage capacity available for economic dispatching to 5,300 MWh.

In the ANTARES model, the 10 Belgian pumped-storage units are modelled individually, enabling planned and forced outages of these units to be taken into account. The model determines the units' dispatch in a daily cycle, taking account of the hourly electricity price (optimal economic dispatch, see section 8.1.2). The power required by pumped-storage units to pump water into the reservoir can be considered additional consumption.

Likewise, the turbinning of water boosts Belgium's electricity generation. The historical use of pumped-storage power plants in Belgium is in line with the modelled results.

When the model encounters periods of structural supply shortage (with prices of up to €3,000/MWh), the pumped-storage units are used at maximum capacity. If the supply shortage lasts longer, the model will dispatch the pumped-storage units in a bid to flatten peaks in electricity consumption.

Belgium's **run-of-river** power stations have a combined installed capacity of 118 MW. For information purposes, the geographical distribution of this type of generation unit as at the end of 2018 is shown in Figure 3.22. According to the information available to Elia, a very slight increase in this capacity is expected, resulting in an installed capacity of 126 MW by the end of 2021. As described in greater detail in section 8.1.1.2.4, run-of-river power stations are taken into account in the model based on monthly profiles for the past 33 winters.




Figure 3.22

3.1.5 Balancing reserves

Article 8, §1 of the Electricity Act stipulates that Elia is obliged to contract ancillary services to ensure a secure, reliable and efficient electricity grid. These ancillary services, also called balancing reserves, are agreements with certain producers and consumers to increase or decrease production on demand at certain sites when required. Elia can use these reserves to restore the balance between generation and consumption when a real-time imbalance occurs. Such imbalances can be caused, among other things, by the unforeseen loss of a generation unit or forecasting errors about renewables.

Since balancing reserves have to be available to restore deviations independently of the strategic reserve, the simulations take account of the volume of generation capacity contracted for frequency containment reserves (FCRs) and frequency restoration reserves (FRRs) as reductions in available capacity to cope with adequacy. This study found a conspicuous stabilisation in the volume of balancing reserves for Belgian generation units for winter 2019-20 (based on the required volume for 2019), compared to the value used in the previous study for winter 2018-19 (based on the capacity required for 2018).

Figure 3.23 also shows how the balancing reserves provided by Belgian power plants have diminished over time.

The volume of balancing reserves needed for 2019 was proposed by Elia and approved by the Belgian federal regulator (see the approval document on CREG's website) [27].

FCR – Frequency containment reserve (aka 'primary reserve'):

The objective of primary frequency control is to maintain the balance between generation and consumption within Europe's interconnected high-voltage system. This frequency containment reserve is defined by ENTSO-E for the European synchronous area. At the time of writing, the figure for 2019 was not yet known. This study assumed that it will be around 86 MW. Since part of this volume has been contracted on demand since mid-2016 and FCR can also be contracted abroad, 13 MW of FCR is assumed to be sourceable from Belgian generation units for winter 2019-20. For subsequent winters, other technologies, such as battery storage plants, are expected to entirely take over the role of FCR providers from thermal power plants.

aFRR – Automatic frequency restoration reserve (aka 'secondary reserve'):

For winter 2019-20, it is assumed that 148 MW will be provided by Belgian generation units. Given the specific requirements of this type of reserve, it is currently provided by Belgian thermal generation units, but there are plans to open up the aFRR market to all technologies in 2020.

mFRR – Manual frequency restoration reserve (aka 'tertiary reserve'):

Tertiary reserve products can be provided either on demand or by generation. The volume reserved for Belgian generation units in this study is 393 MW for winter 2019-20.

For information purposes, Figure 3.23 shows the balancing reserves considered to be provided by Belgian generation units in this study, listed per type of reserve. More information about these types of reserve can be found on Elia's website [22].




Figure 3.23

Strategic and balancing reserves are used for different ends, which does not mean that

Elia will not use balancing reserves to prevent load-shedding. Applying balancing reserves is one of possible measure to be taken if security of supply is jeopardised (see section 1.4.3).

3.2 Electricity consumption in Belgium

As discussed in greater detail in the appendix (section 8.1.1.3), modelling electricity consumption consists of three steps (see Figure 3.24). This section outlines the assumptions taken for Belgium during each of these steps.

- 1 Growth of the total demand
- 2 Growth applied to an hourly profile normalised for temperature
- 3 Addition of the temperature sensitivity effect to the normalized load

Figure 3.24



This section provides an overview of the assumptions made with regard to Belgian electricity consumption. The modelling details are provided in the appendix in section 8.1.1.3.

What is total electrical consumption (aka 'total load')?

Total electrical consumption takes account of all loads on the Elia grid and distribution system (including losses). Given the dearth of quarter-hourly measurements for distribution systems, this load is estimated by combining calculations, measurements and extrapolations.

What are the differences compared with Elia's consumption (aka 'Elia grid load')?

The Elia grid load is a calculation based on injections of electrical energy into Elia grid that incorporates the measured net generation of (local) power stations that inject power into the grid at a voltage of at least 30 kV and the balance of imports and exports. Generation facilities that are connected to distribution systems at voltages under 30 kV are only included if net injection into the Elia grid is measured. The energy needed to pump water into the storage tanks of the pumped-storage power stations connected to the Elia grid is deducted from the total.

Decentralised generation that injects power into the distribution networks at a voltage under 30 kV is not fully included in the Elia grid load. The significance of this segment has steadily increased in recent years. Elia therefore decided to complement its publication with a forecast of Belgium's total electrical load.

Elia's grid comprises networks with voltages of at least 30 kV in Belgium plus the Sotel/Twinerg grid in southern Luxembourg.

How is the consumption of the Sotel/Twinerg in Luxembourg taken into account?

Elia's grid not only includes systems with voltages of at least 30kV in Belgium, but also the Sotel/Twinerg grid in southern Luxembourg. In this study, Belgium's total load does not include the consumption of the Sotel/Twinerg grid. Instead, this consumption is modelled as a separate load connected to Belgium. For more information, see section 4.5.

What is published on Elia's website?

Two load forecasts are published on Elia's website: the Elia grid load and the total load.

The Elia grid load and total load published there do include the load of the Sotel/Twinerg grid (which is not the case for the total load calculated in this study). For a full explanation, see the website [24].

3.2.1 Growth of Belgium's total load

For Belgium, the most recent forecast by IHS Markit, an internationally renowned consultancy agency, is taken as the reference for total demand for electricity in Belgium in this study. This forecast takes account of IHS Markit research on the underlying economic and policy drivers that affected the European power markets up to June 2018. The IHS Markit forecast was based on a multi-sector model in which the industrial and commercial sectors are by far the biggest drivers of incremental power demand in Belgium the years to come. This study considers relatively modest average growth of 0.59%.

Figure 3.25 gives an overview of annual total demand since 2012 and its value normalised for temperature. The table includes the base-case forecasts used both for this analysis and in the previous study from November 2017.

	Historical values			Base case normalized total demand		Forecast Nov. 2017
	Total demand [TWh]	Normalised total demand [TWh]	Growth rate	Growth rate	Forecast [TWh]	Forecast [TWh]
historical 2012	84.86	84.66	-3.97%			
historical 2013	86.24	85.81	1.36%			
historical 2014	83.73	85.14	-0.78%			
historical 2015	85.01	85.64	0.58%			
historical 2016	85.02	84.86	-0.91%			
historical 2017	84.826	85.38	0.61%			85.23
forecast 2018				0.59%	85.88	85.51
forecast 2019				0.66%	86.45	86.07
forecast 2020				0.74%	87.08	86.55
forecast 2021				0.62%	87.62	87.07
forecast 2022				0.49%	88.05	

Figure 3.25

The values presented in table form in Figure 3.25 are also plotted as a graph in Figure 3.26, which clearly shows the relationship between measured and normalised historical demand. Also worth noting is the fact that last year the 'normalised total demand' exceeded the forecast for 2017.




Figure 3.26

3.2.2 Belgian normalised demand profile

The normalised profile used in this study was constructed by a dedicated ENTSO-E working group by combining historical load data with temperature data and information about public holidays. The growth identified in step 1 is applied to this normalised profile to match the total forecast demand normalised for temperature. The hourly normalised profile for Belgium used in this study is shown in Figure 3.27.




Figure 3.27

Figure 3.27 clearly shows the weekday/weekend and holiday effects on Belgian consumption.

This profile does not take account of consumption by pumped-storage units. The model optimises these units' dispatching, thereby adding their load on top of this profile. Section 3.1.4 provides more details about Belgium's pumped-storage units.

Likewise, the profile does not consider the impact of market response, which is modelled separately and optimised based on the cost of electricity generation. Section 3.3 provides more information on the market response in Belgium and the method developed to assess its volume and activation.

3.2.3 Sensitivity of the Belgian load to temperature

The final step entails applying thermosensitivity to the temperature-normalised hourly profile. For each climate year, an hourly profile for consumption is created. Figure 3.28 shows the impact of temperature on the total hourly profile for Belgium for one of the 33 past winters used in this study.




Figure 3.28

The method for taking account of load thermosensitivity was developed in the context of the ENTSO-E MAF study (see section 1.8.4) and relates daily minimal and maximal power to daily temperature (averaged over 24 hours). Furthermore, it is based not on a linear relationship, but on a cubic relationship between temperature and load, since this enables effects like saturation to be systematically captured, while maintaining the same level of accuracy as the previously used linear method. More details of this method are given in section 8.1.1.3.3.

For the purposes of this study, Elia again chose to apply this method, developed in the context of ENTSO-E, for the analysis of winter 2019-20. This choice was made to retain methodological consistency between the determination of strategic reserve volume and the methods developed and used at European level by ENTSO-E.

Forecast peak demand in Belgium for winter 2019-20

Figure 3.29 gives an overview of peak demand after applying the thermosensitivity effect for the 33 winters included in this study to the normalised Belgian profile. The peak demand thus shown is the maximum value observed for a given winter. Although this figure indicates the maximum load observed during the winters covered by the study, it does not show the frequency with which high demand values occurred during those winters.

The winter period included more than one cold spell, the duration of such periods being a very important parameter for adequacy problems. If high demand is observed for just a few days, it will have a lower impact than if a cold snap lasts a fortnight. Figure 3.29 shows a peak demand of 13.7 GW for the 50th percentile for the winter covered in this study (2019-20) – a probability of 'once every two years'. In extreme cases, peak demand could be even higher, 14.4 GW, as indicated by the 1 in 20 probability (95th percentile, probability of 'once every 20 years').




Figure 3.29

Figure 3.30 shows historical peak demand¹⁷ between 2002 and 2016, indicating that this parameter is not constant and is primarily influenced by the temperature. The graphic also shows the probability percentiles for peak demand in winter 2019-20 as used in this analysis, whose range covers the observed historical peak demands.

¹⁷ Peak demand is an estimate based on measurements and calculations.




Figure 3.30

Peak demand in winter 2019-20 is forecast at between 12.9 GW and 14.7 GW, depending on climatic conditions.

3.3 Market Response in Belgium

This section discusses how this adequacy study takes account of the available market response in Belgium. As consumers may react when electricity is in scant supply by lowering their net consumption, it is important to take this response into account to avoid overestimating the strategic reserve needed. Section 0 provides a brief overview of how market response has been integrated in the past and of the procedure resulting in the development of the new method for correctly integrating market response into the process of determining strategic reserve volume. Section 3.3.2 then gives a detailed description of the newly developed method, together with the results obtained.

3.3.1 Introduction

Market response is a crucial dynamic parameter when difficult situations arise on the electricity grid, especially under demanding conditions when adequacy problems arise. European policymakers (2009/72/EC and 2012/27/EC), national politicians and regulators are all pushing for the further development of demand-side response (DSR) and market response (MR). Their urging is echoed by the call by market stakeholders call (flexibility-requesting parties (FRPs), BRPs, producers, suppliers, third-party aggregators and customers) to fine-tune the methodology used to identify the volume of market response¹⁸ in Belgium when determining the strategic reserve volume.

In 2015, Elia sent a questionnaire to BRPs, Elia grid users and/or aggregators to estimate market response at times of system stress. The survey investigated three types of

¹⁸ DSR generally takes the form of lower consumption (not including distributed generation or storage technologies), whereas market response should be understood in a broader sense, leaving out the technology (including distributed generation or storage technologies). This adequacy study was based on a market response of the latter, broader type.

flexibility through load reduction in the market: based on contracts, on prices and on a voluntary mechanism. The results focused on the flexibility available to market participants, not on the volumes that Elia can contract and activate when balancing reserves or drawing on the strategic reserve.

In 2017, a broad range of market players expressed their willingness to participate in developing a new method for determining market response in Belgium as part of the process for determining the strategic reserve volume. In January 2017, in the context of the Task Force 'Implementation Strategic Reserve', a Demand Response Study subgroup was set up to design the most appropriate methodology for determining these market response volumes. Its work was conducted together with E-CUBE Strategy Consultants. The method they designed was based on interactions with stakeholders over four workshops and bilateral interviews.

3.3.2 Development of a new method for determining market response volume

The market response used in the context of determining the strategic reserve volume, encompasses the full, energy-only market response when prices are exceptionally high. The market response under normal price conditions (i.e. prices < €150/MWh) is already taken into account in the normalised load profile constructed by Elia for its adequacy study. The newly developed methodology makes it possible to determine the market response volume available when prices are exceptionally high (> €150/MWh). The conclusion reached was that the method can estimate the market response across all different consumer segments.

Based on the workshops and input from consultants, it was concluded that the entire available market response can be taken into account by following the threefold approach set out below (see Figure 3.31). Global market response volumes can be estimated by analysing the aggregated demand and supply curve¹⁹ of the EPEX Spot Belgium day-ahead market (section 3.3.2.1). This analysis was supplemented with a qualitative questionnaire (section 3.3.2.2) to assess the activation details and lastly verified by performing a sanity check (section 3.3.2.2).

¹⁹ An aggregated curve is a curve representing all demand offers, expressed in capacity, ranked from lower to higher price.




Figure 3.31

Section 3.3.3 summarises the results of the analysis and how they are to be integrated into the adequacy assessment. The methodological framework is considered robust for the coming years, though it could be regularly updated by repeating some analyses, as reflected in section 3.3.4. The final reports based on this study can be consulted on Elia's website [57] and [58].

3.3.2.1 Aggregated curves- analysis: estimating global volume

Aggregated curves methodology enables the total market volume to be estimated for contract-based, price-based and voluntary market responses. In these aggregated curves, market response volumes can take the form of a drop in demand or an increase in supply.

The **drop in demand** due to a price increase is directly incorporated in the aggregated curves by studying the decreasing volume associated with the price increase from €150/MWh (the lower limit for market response volumes) to €3,000/MWh (the maximum day-ahead price), as is evident in Figure 3.32. Since aggregated curves are provided every hour, this volume comparison is also computed hourly.




Figure 3.32

On the demand side, the output is the market response volume every hour.

For example, if 400 MW are above the €150/MWh limit, the estimated market response volume for that particular hour is estimated to be 400 MW.

Instead of a drop in demand, suppliers can value market response in terms of **increased supply** to the market. The market response cannot be directly deducted from these curves as they aggregate this capacity with generation. Contrary to demand curves, where the presence of bids representing reduced generation is considered very limited above €150/MWh, supply curves can contain generation bids in this price range. Generation bids higher than €150/MWh can be justified by extraordinary variable costs, such as foreign sourcing.

To refine the analysis of the supply curve, two price thresholds are considered (see Figure 3.33):

- **€150/MWh:** generally regarded as the limit bid for generation assets, even if some generation assets can justify higher bids in specific cases;
- **€500/MWh:** above this value, it is deemed very difficult to justify the price, and it can be assumed that only demand response bids will appear in the curves.

The analysis of supply-aggregated curves provides a range including:

- **a low estimate** for the supply side that does not take account of the potential value under €500/MWh, but definitely excludes generation;
- **a high estimate** that integrates the adequate scope of market response but may also take account of additional volumes of generation assets.




Figure 3.33

The aggregated curves do not take account of smart orders²⁰. This could reduce the total estimated market response volume. However, the volume of market response smart orders is very limited, since most such orders are linked to generation assets. The impact on the assessment of market response volumes is very limited.

The curves do implicitly take account of over-the-counter (OTC) bids. If this volume would not in the curves, it would correspond to irrational behaviour by the stakeholders, which was not taken into account in the study.

As an example, if the volume above €150/MWh is 150 MW and the volume above €500/MWh is 100 MW, the market response volumes presented as values in the supply curve can be considered to fall within the 100-150 MW range.

The volume obtained by following this method corresponds to the adapted scope for contract-based and price-based market responses, as well as the voluntary market response forecast by market players. If some volumes are in the voluntary market response category, the market players will anticipate such events. Theoretically, their anticipation should be reflected in bidding behaviour, if the BRPs deem the changes to be definite, with the voluntary market response then implicitly taken into account in this methodology. In general, this approach makes the methodology robust with an eye to future changes (e.g. new technologies facilitating market response), since any change that the market players deem or will deem to be firm will appear in the aggregated curves, and will therefore be considered in the analysis.

²⁰ Smart orders are either linked block orders (one block is executed if the other is) or exclusive block orders.

3.3.2.2 'Objective qualitative questionnaire: qualitative content to complement the aggregated curves analysis

The aggregated curves analysis provides a capacity estimate, not an hourly volume to integrate into the model. The number of activations per week and maximum duration of activation must be ascertained for this estimate to be taken into account in Elia's adequacy assessment.

The activation details are obtained by sending out a questionnaire focussed on facts, so as to avoid unrealistic or unanswerable questions. It was also qualitative, focussing on gathering required activation information, so as to correctly link adequacy and methodology.

According to the discussions conducted with stakeholders, the questionnaire needed to be simple, intuitive and focus on facts. Its main objective was to obtain high-quality information to complement the aggregated curves methodology, key data being the number of possible activations per week and their duration.

A specific questionnaire was developed for each type of player (suppliers, aggregators and customers), to take their specific characteristics into account. These questionnaires were drawn up in close cooperation with the respondents, to ensure that the answers they provided would prove useful.

3.3.2.3 Global sanity check

To conduct a sanity check, the questionnaire also provided an estimate of current volumes. This effectively avoided the main limitation of the questionnaire raised by stakeholders: the description of hypothetical situations.

An international benchmarking exercise was conducted, putting market response volumes in proportion to maximum peak loads in the electrical system. These volumes were then compared to those previously established, to assess their global consistency.

3.3.3 Results of the analysis and integration in the adequacy assessment

The **aggregated curves analysis** made it possible to estimate market response volumes. These volumes had first to be extracted from EPEX Spot Belgium day-ahead market aggregated curves to obtain a processable dataset of hourly market response values from 01/01/2014 to 31/04/2018. On the demand side, market response volumes can be directly found in the aggregated demand curve by studying the drop in volume when the price rises from €150/MWh to €3,000/MWh (excluding 'at-any-price' bids). In the supply curves, the market response is represented by two volumes: above €150/MWh (high bound) and above €500/MWh (low bound).

The dataset was then refined, firstly by excluding days on which national strikes occurred and treating national public holidays like Sundays. Secondly, 2014 was excluded from the dataset because that year's supply curves reflected a specific bidding behaviour that did not correspond to the reality of today's market. So this refined dataset is more accurate whilst also containing a satisfactory volume of data.

The refined dataset was then analysed to assess the impact on market response volumes of various parameters, including temperature, price and Elia's grid load. Although regressions did not reveal any statistical correlations between market response volumes and these parameters, another analysis showed that Elia's grid load has the greatest impact on market response volumes. Indeed, during high-load periods, the dataset's standard deviation is reduced and its average volume increases. Consequently, volumes for winter peak hours were extracted, so that high-load hours could be examined

separately. For the refined dataset, the average volume during winter peak hours totals 691 MW.

Finally, the extrapolated output was applied to the three next winters (i.e. 2019-20, 2020-21 and 2021-22). Options for changing the extrapolation factor for market response volumes for these years was discussed at the Task Force meetings, where three alternatives were presented:

- an extrapolation factor of 7% growth per year, based on a 4-winter compound annual growth rate, or CAGR (2014/15 – 2017/18);
- an extrapolation factor of 4% growth per year, based on a 3-winter CAGR (2014/15 – 2016/17);
- an extrapolation factor of 5% growth per year, corresponding to the value used in last year's study.

Based on discussions at Task Force meetings, a 7% annual growth rate was proposed, subject to an annual reassessment based on an update of the quantitative analysis. Two arguments were put forward in support of this. Firstly, in the event of real adequacy stress in Belgium, new parties might offer a market response. And secondly, the increase in market response between the penultimate winter and previous one was 12%, even higher than the proposed CAGR. The values to be taken on board in the adequacy study are shown in Figure 3.34:




Figure 3.34

To be useful for this adequacy study, the output of the aggregated curves analysis was supplemented with activation constraints: the number of weekly activations and the maximum duration of these activations. This **qualitative information was provided in the questionnaire** sent to all relevant market players, i.e. TSO grid users, BRPs (non-grid users) and aggregators in 2017. A satisfactory response rate of 50% (81 out of 162 questionnaires sent) enabled us to identify seven different categories of activation constraints. Most volumes are estimated to prompt between 2 and 28 activations per week, and between 1 and 4 hours of maximum activation duration, while 5% of volumes

have no limitations regarding both the number of activations per week and the duration of these activations.

This categorisation, based on answers from TSO grid users, was broadly validated by answers from BRPs (non-grid users) and aggregators. Figure 3.35 gives an overview of the constraints applied in the model, as assumed after analysing the various answers to the questionnaire. For this year's analysis, Elia did not update the categories' constraints.

Number of activations per week	2	4	7	14	14	28	No limits
Activation duration (hours)	1	4	2	2	4	4	No limits
% of Market Response volumes	~10%	~10%	~25%	~10%	~30%	~10%	~5%

Figure 3.35

For the adequacy assessment model, in practice this means that both the market response in MW and constraints on usage should be taken into account. How this market response is used in the model depends, among other factors, on the price and number of hours of structural shortage. During a structural shortage, when high prices are to be expected, the additional market response will be deployed before proceeding to a situation where the energy supply is not met.

Given these constraints, the additional market response cannot offer a solution at all times of structural shortage, but this model will optimise the deployment of available flexibility, as its output shows. A detailed analysis of how the market's response is used in the simulations is provided in section 6.2.3.

3.3.4 Methodological updates

To take account of future changes in market response volumes, the method could be regularly updated to obtain representative results. However, the methodological framework itself, defined together with market parties, may be considered robust for the years to come.

The quantitative method facilitates an annual re-calculation based on updating the data and parameters, without necessitating annual redesigning of the methodology. The EPEX Spot Belgium day-ahead market's aggregated curves should be updated by adding recent data every year, along with price thresholds, the extrapolation factor and ancillary service changes. Note that new market changes impacting the aggregated curves will automatically be incorporated in the analysis.

However, the qualitative methodology is less sensitive to annual changes and is also more resource-intensive for Elia and market parties. An update of the qualitative aspects could be planned after a few years or whenever the need becomes apparent.

In the event, Elia chose to only update the quantitative aspect of this method to analyse the market response available for determining the strategic reserve for winter 2019-20.

3.4 Summary of electricity supply and demand in Belgium

Figure 3.36 summarises the forecast installed generation capacity in Belgium taken into account in the base-case scenario for the next three winters and also provides an overview of installed capacities during the previous two winters. Note that this installed capacity does not take into account either forced or scheduled outages or the energy limitations of some technologies.

		Production capacity in winter available in the market [MW]				
		2017-18	2018-19	2019-20	2020-21	2021-22
Non RES	Nuclear	5,919	5,919	5,919	5,919	5,919
	CCGT/GT/CL	3,846	3,846	4,491	4,491	4,491
	CHP	1,837	1,890	1,970	1,970	1,970
	Turbojets	158	158	140	140	140
Storage	Pumped-storage	1,308	1,308	1,308	1,308	1,308
RES	Waste	318	318	313	313	313
	Biomass	794	804	815	826	830
	Run of river hydro	114	114	118	123	126
	Wind onshore	1,915	2,254	2,513	2,775	2,939
	Wind offshore	859	1,051	1,610	2,271	2,271
	PV	3,526	3,932	4,433	5,070	5,600
TOTAL		20,594	21,594	23,630	25,206	25,907

Figure 3.36

Figure 3.37 was put together by combining the installed generation capacity with the P90 peak demand forecast in Belgium for winter 2019-20. In addition to these capacities, the market response when prices are high should be considered together with its respective activation limits (see section 3.3 for more information). Likewise, this figure does not show potential imports (see chapter 5 for detailed information). Moreover, it should be noted that comparing the shown P90 peak demand with installed capacity does not provide any indication regarding adequacy. Indeed, the availability of generation and the exact distribution of demand have to be correctly taken into account when analysing Belgium's adequacy.

Installed generation capacity in the market and P90 peak demand in Belgium for winter 2019-20





Figure 3.37

4 Assumptions for neighbouring countries



Given the high number of potential energy exchanges between countries, accurate modelling of the situation outside Belgium is crucial for quantifying structural shortages in Belgium. To enable such modelling, data from and assumptions applying to neighbouring countries are collected via bilateral contacts with the respective TSOs. For those non-neighbouring countries included in the model, data were harvested from regional or European joint studies carried out by ENTSO-E or PLEF, or from reports on national adequacy and electricity generation. See section 1.8 for more information on these European and regional studies. The report's main hypotheses are cited for those countries that can exert a strong impact on Belgium's adequacy, namely France, the Netherlands, Germany, Great Britain and Luxembourg.

4.1 France



The French government recently announced [34] its postponement of the initial goal set in 2015 in its Energy Transition Act (*Loi de Transition Énergétique*) to halve the share of nuclear generation in the country's energy mix by 2025. Based on arguments put forward by the French government, this target is no longer realistic for France because it would increase CO₂ emissions, jeopardise security of supply and threaten jobs.

The assumptions for France are based on the latest adequacy report (*Bilan Prévisionnel*) issued by the French transmission system operator (RTE) [32]. The short term is covered by an annual report by RTE, spanning four years. Its biannual report also includes a long-term forecast.

For this French adequacy report, RTE uses the same probabilistic method and model as applied by Elia in this study to simulate the European electricity market. Data mentioned in this section are consistent with the trends presented in the French report [32] for the period 2019-2023. Figure 4.1 provides a base-case overview of installed capacity in France for winter 2019-20. P90 peak demand is also indicated.




Figure 4.1

4.1.1 Electricity supply in France

4.1.1.1 Thermal capacity (excluding nuclear)

The base-case scenario includes the following assumptions about changes in installed thermal capacity (nuclear assumptions are detailed below):

- all CCGT units are expected to be operational for all winters included in the assessment;
- coal-fired units are expected to still be in the market, but with installed capacity starting to fall in winter 2021-22;
- decentralised thermal generation is expected to be in the market

The thermal generation base case (excluding nuclear) is shown in Figure 4.2 below.

Installed thermal capacity considered for the 'base case' for the French production park (excluding nuclear)




Figure 4.2

4.1.1.2 Nuclear capacity

France has 63 GW of nuclear installed capacity, divided across 19 sites spread around the country. Figure 4.3 shows that a stable level of 63 GW of nuclear installed capacity is expected in the base case for the next three winters. The new European pressurised reactor (EPR) in Flamanville should be available for winter 2020-21, by which time the oldest nuclear site (Fessenheim 1&2) should have been decommissioned. This explains the small, 200 MW decrease in installed capacity when comparing winter 2019-20 to 2020-21.

Installed nuclear capacity considered in France for the 'base case'




Figure 4.3

Since the French government also stated in November 2017 [34] that "*while there was a delay [...] a clear programme on which reactors to close and when*" would be put forward

in a year's time, the assumptions made for a stable level of nuclear capacity for winter 2019-20 and thereafter should be treated with caution and might need to be revised in next years' assessment. A reduction in installed nuclear capacity in France could lead to adequacy concerns if no replacement can be found and if that reduction is accompanied by a coal-phase out, according to RTE [32] (see section 0).

Given the significant impact of the French nuclear generation fleet on Belgium's adequacy level, a similar approach to the one adopted for Belgium was followed for the planned unavailabilities of French nuclear generation units. The availabilities of French nuclear units were taken into account in the models of the relevant generation units' owners published via official transparency channels (REMIT).

An extract from the availability data provided by the relevant generation units' owners in France was taken from the transparency channels on 18 October 2018 (and monitored until 8 November 2018), and this provided the data used for this study, as the 'best forecast' of planned unavailability for the nuclear park in France. The model also took account of forced outages. Furthermore, an analysis of historical availability in France over the past seven winters was performed to determine unavailability in France corresponding to 'low-probability, high-impact' sensitivity analysed in the study (see section 6.3.1 for details).

4.1.1.3 Renewable electricity generation

France has a high volume of hydro installed capacity, mainly derived from large reservoirs in the mountains and run-of-river installations. Pumped-storage units' turbinning capacity is also counted in the installed capacity displayed in Figure 4.4 below.

The expected short term change in French renewables is as follows:

- + 1-2 GW/year for the onshore wind;
- + 1.8 GW/year for PV installations;
- + 100 MW/year for biomass units;
- The first French offshore wind farm is expected to come online by 2022, so no offshore wind was taken into account in this study for France.




Figure 4.4

4.1.2 Electricity demand in France

Historical total demand data are shown in Figure 4.5. Historical consumption has not been normalised for temperature, so include meteorological fluctuations. The figure also shows projected normalised consumption.

Over the past few years, RTE has noted a stabilisation in power demand in France, mainly due to energy-efficiency measures and moderate economic growth. These efficiency measures will be further refined in the coming years, so power demand is likely to stabilise or decrease. Peak power demand should follow a similar downward trend.

The Energy Transition Act of 2015 sets out the ambitious objective of halving France's final energy consumption by 2050 (compared with 2012). It provides the legal framework for supporting new tools to optimise energy consumption in the country and sets ambitious targets to reduce multi-energy consumption. The input in this paragraph is taken from comments on the national situation in France provided by French TSO RTE in the PLEF GAA study [56].




Figure 4.5

Consumption in France is highly sensitive to temperature differences, accounting for around 2,400 MW/°C, mainly due to the high penetration of electrical heating in the country [35] [36] [37].

For this years' analysis, the same method for modelling load thermosensitivity for France was applied again. It is also in line with the method used by RTE in its adequacy report for 2018 [32].

The market response expected in France mainly corresponds to demand-side management of around 2.5 GW.

4.1.3 Security of supply in France

The adequacy report by French TSO RTE studies the situation for France [32]. The next such report (BP2018) is scheduled for publication in mid-November.

Furthermore, France has had a capacity mechanism (CM) since 30 November 2016 [67], which is organised as a decentralised capacity market designed to ensure compliance with the reliability criterion set by the French authorities (an LOLE of 3 hours per year).

This mechanism rewards operators for feeding available capacity into the electricity system by when the supply is tight. And it is intended to send out economic signals complementing those emanating from the energy market.

The French capacity mechanism applies across the energy market, with all participating generators of capacity allowed to be involved. A clear distinction is drawn between the energy market and the capacity market. Indeed, generators with certified capacity will only be required to make that capacity available, but will still be able to decide not to generate energy based on the order of merit. Consequently, the capacity mechanism is effectively designed not to alter market participants' bidding strategy and dispatching decisions in the short term.

4.2 The Netherlands



Bilateral communication with TenneT NL TSO indicates that, the Netherlands can ensure their adequacy solely by relying on domestic power production for winter 2019-20.

Taking into account the expected reduction in operational thermal production capacity, TenneT NL TSO confirms that the Netherlands might have to rely on imports for their security of supply, but only around year 2025.

The 700 MW HVDC interconnector with Denmark (Cobra cable) is assumed as available for winter 2019-20 in this study. This assumption needs to be taken with care as delays in the commissioning date might still occur.

The assumptions made in this study for the Netherlands, collected through bilateral contacts with Dutch TSO TenneT NL, are in line with those used for the Dutch national adequacy study, *Rapport Monitoring Leveringszekerheid 2018* (due to be published in December 2018). Figure 4.6 indicates the assumptions used for the Dutch electricity supply and demand for winter 2019-20. Sections 4.2.1 and 4.2.2 elaborate on supply and demand in the Netherlands respectively.

Installed capacity and P90 peak demand considered in the 'base case' for winter 2019-20 in The Netherlands




Figure 4.6

4.2.1 Electricity supply in the Netherlands

4.2.1.1 Non-renewable electricity generation

Non-renewable electricity generation in the Netherlands is mainly fuelled by **gas and coal**; see Figure 4.7 for the assumptions made in this study. Coal-fired power is expected to remain at the current level, generating approximately 4.6 GW. Sustainable energy policies have led to the closure of five older coal-fired power stations totalling 2.7 GW in 2016 and 2017. Although the Dutch government is pressing ahead with its plans [64] to close all other coal-fired power plants by 2030, no additional closures of coal-fired power plants are assumed between winter 2019-20 and winter 2021-22.

As in other European countries, Dutch gas-fired power plants have faced challenging economic conditions in recent years. Several gas-fired plants have announced temporary mothballing (i.e. a halt to operations). Some of them only shut down during the summer (summer mothballing), and are thus taken into account in the analysis concerning the winter only. The figures considered this year for winter 2019-20 are based on similar assumptions concerning plants listed as mothballed in last year's study for winter 2018-19. The default assumption, based on last years' trend, was to assume that 1.6 GW of gas-fired generation capacity will be either temporarily or permanently lost between winter 2019-20 and winter 2021-22. However, it is worth noticing that the Maasbracht Claus C CCGT unit is now expected to come out of mothballing from late 2020 onwards. Consequently, the above assumption needs to be considered with caution for winter 2020-21 and winter 2021-22.

The Borssele **nuclear** power plant (with an installed capacity of approximately 0.5 GW) is the Netherlands' only nuclear generation facility and is expected to remain throughout the timeframe of this study. No new Dutch nuclear power plant projects are expected.




Figure 4.7

4.2.1.2 Renewable electricity generation

Forecasts of installed capacity of **renewable** electricity generation in the Dutch national adequacy study are traditionally based on the Dutch National Energy Report (NEV) [47], based on a study conducted by the Energy Research Centre of the Netherlands (ECN). No National Energy Report (NEV) was published in 2018 due to the ongoing National Climate Agreement (*Nationaal Klimaatakkoord*) process [79].

On 23 February 2018, the Dutch Council of Ministers launched discussions with the business community, social society and other authorities (municipalities, provinces, water boards) on the Climate Agreement. On 10 July 2018, all the parties involved presented their proposals to Economic Affairs and Climate Policy Minister Eric Wiebes. In the summer of 2018, the Dutch Environmental Assessment Agency (PBL) and the Dutch Bureau for Economic Policy Analysis (CPB) also submitted their proposals. In October 2018, the government and Dutch House of Representatives were still discussing these proposals. Afterwards, the parties involved intend to draw up concrete plans. The National Climate Agreement is due to take effect in 2019.

This agreement will build on previous climate legislation, namely the Energy Agreement for Sustainable Growth (*Energieakkoord voor duurzame groei*) [48], envisaging a target of 4.5 GW of offshore wind installed capacity by 2023, achieved through a tendering process involving the installation of 700 MW per year between 2015 and 2019 [65]. The first 700 MW of additional offshore wind capacity is expected to be commissioned by winter 2020-21. For both PV and onshore wind, an increase of approximately 600 MW is expected between winter 2019-20 and winter 2020-21. These upward trends should with a view to winter 2021-22. Furthermore, 6 GW of onshore wind capacity should be available for winter 2021-22, reflecting agreements concluded between the Dutch provinces and the Netherlands' national government.

While these political processes are ongoing, this study drew on a set of assumptions about renewables installed capacity compiled by Dutch TSO TenneT NL (see Figure 4.8).




Figure 4.8

4.2.2 Electricity demand in the Netherlands

Assumptions about electricity demand in the Netherlands are in line with the latest Dutch adequacy report (to be published in December 2018), as estimated by Dutch TSO TenneT NL. Figure 4.9 shows historical Dutch electricity demand (not normalised for temperature), as well as its projection (normalised for temperature) over the coming years. Electricity demand normalised for temperature is expected to remain relatively stable during the period in question. This study does not take account of any potential for **demand-side response** in the Netherlands. While discussions are ongoing in the aforementioned agreements and political processes, in the absence of any hard-and-fast information on this topic at the time of the assessment, we made a conservative assumption.




Figure 4.9

4.3 Germany



Germany has a high RES penetration but also high installed capacity of coal and lignite production. A significant decrease in installed capacity of coal & lignite production is expected in the coming years.

Germany has a comfortable margin when scarcity occurs in Belgium and France because of its large amount of possible imports from the north and the east, and its diversified domestic production park.

The German nuclear phase out is on track with more than half of the installed capacity in 2010 already taken out of service and only 7 more nuclear power plants remaining.

The 1400 MW Nordlink interconnector is not taken into account out of precaution, since commercial operation for winter 2020-21 is not certain.

The assumptions about Germany made in this study are based on data compiled from the German Ministry of Energy [38], the German *Netzreserve* (literally 'network reserve') [39],[40] and bilateral contacts with German TSOs and the 2018 mid-term adequacy forecast (MAF). Figure 4.10 summarises the assumed supply and demand for winter

2019-20. Germany's electricity supply is discussed in greater detail in section 4.3.1. German demand is discussed in section 4.3.2. Finally, Section 4.3.3 discusses the coal phase-out in Germany and its potential impact on Belgium.




Figure 4.10

4.3.1 Electricity supply in Germany

4.3.1.1 Non-renewable electricity generation

The assumptions made about non-renewable electricity generation in Germany are illustrated in Figure 4.11, showing that the total installed capacity of non-renewable electricity production is expected to drop by approximately 6% over the next four winters.

In 2010, the German government passed legislation on the *Energiewende* (energy transition). One of the key points in its energy transition policy is the phase-out of all German **nuclear** production by the end of 2022. Ten of the 17 nuclear reactors in operation at the end of 2010 have already been taken out of service. The next nuclear power plants scheduled to be shut down are Philippsburg 2, by the end of 2019, and Grohnde, Gundremmingen C and Brokdorf, by the end of 2021 [52]. In total, this amounts to a nearly 10 GW reduction in installed nuclear capacity already.

Today, almost 22% of the electricity generated in Germany is fuelled by **coal and lignite** [68], down from 43% in 2015 [69]. A significant drop in the installed capacity of German coal and lignite production is expected, due partly to environmental policies, but also to government plans to phase out hard coal-mining subsidies.

Although a number of **gas-fired** power plants are expected to shut down, a slight increase in gas-fired generation is envisaged by 2021-22 because several efficient new CCGT plants are expected to be commissioned in the years to come.

Installed non-renewable production in Germany considered for the 'base case' in this study




Figure 4.11

4.3.1.2 Renewable electricity generation

Figure 4.12 shows the assumptions made for the installed capacity of German renewable electricity generation. Currently, around 30% of power generated in Germany is derived from renewable sources. This large share of renewables is due to the country's high volume of wind and solar facilities, which give it an installed capacity of more than 90 GW for winter 2019-20. When biomass, hydro and other renewables are included, this figure rises to more than 110 GW.

The data on renewable generation capacity in Germany are in line with the ENTSO-E Seasonal Outlook Report and the 2018 mid-term adequacy forecast (MAF).

Installed RES and pumped storage




Figure 4.12

4.3.2 Electricity demand in Germany

Between 2010 and 2014, Germany's total (non-normalised) electricity demand was seen to decrease by an average of approximately 1% a year. This trend appears to have changed around 2015. The assumption made about German demand in this study is in line with what German TSOs communicated to ENTSO-E in the context of the MAF. For the next three winters, Germany's load is expected to remain stable and should start falling slightly from 2020-21 onwards, thanks to increasing energy efficiency in line with the attainment of political objectives.

in the PLEF study [56], German TSOs report that 1 GW of 'switchable loads' is available in Germany. However, this volume should not be deemed eligible for a potential market response there, but rather viewed as an emergency facility to be called upon by German TSOs only in truly urgent real-time operations. Accordingly, no market response potential was taken into account when modelling the situation in Germany for this study.




Figure 4.13

4.3.3 Germany's coal phase-out and its impact on Belgium

Significant discussions are under way in Germany regarding the so-called 'coal phase-out' and the possibility of setting adequacy criteria in Germany. The effect of such decisions in Germany could have a major impact on Belgium's adequacy level.

Recently, within the context of the in ENTSO-E MAF 2018, a study on phasing out coal by 2025 was carried out, envisaging a capacity reduction of around 23 GW in the EU compared to the base case, with a net reduction of more than 8 GW in the volume of coal generation in Germany.

The results of this are also in-line with similar assessments performed by Elia in its study entitle Electricity Scenarios for Belgium Towards 2050, which indicated that in the event of inadequacy in neighbouring countries, especially Germany and France, Belgium might need an additional 1 to 2 GW in generation capacity to meet its adequacy criteria.

4.4 Great Britain



As of winter 2017-18, security of supply in Great Britain is managed through the Capacity Market (CM), based on a recommendation regarding the capacity to secure provided by the British TSO National Grid.

In its 'Winter Outlook Report 2018-19', the British TSO National Grid indicates that no security of supply problems are expected for winter 2018-19.

A reduction of the installed thermal capacity is foreseen. More specifically approximately 75% of the installed capacity of coal-fired power production is expected to close over the course of the next five winters.

This section elaborates on the assumptions about the situation in Great Britain used in this study, which are pretty much in line with the 2018 edition of the Future Energy Scenarios (FES) [23]. The FES is a report published by British TSO National Grid describing a set of scenarios up to 2050. This analysis adopted assumptions about a

'steady progression' scenario from the FES report. The discrepancies between installed capacity and demand in the different scenarios detailed in the FES report are limited in the short term [24].

The British government's 2013 Energy Act [49] introduced the **electricity market reform (EMR)**. Two policies arising from the EMR are the introduction of a capacity market (CM) and the contracts-for-difference (CfD) mechanism. The British capacity market is meant to ensure security of supply in Great Britain, and is discussed in greater detail in section 4.4.3. The CfD mechanism provides incentives for low-carbon electricity generation capacity.

Section 4.4.1 sets out the assumptions made with regard to the electricity supply for Great Britain. Section 4.4.2 details the demand-related hypotheses used in this analysis. And Figure 4.14 summarises the supply and demand hypotheses for Great Britain for winter 2019-20.




Figure 4.14

4.4.1 Electricity supply in Great Britain

4.4.1.1 Non-renewable electricity generation

Historically, in Great Britain, most electricity has been derived from gas-fired, coal-fired and nuclear generation. However, in 2013, the British government introduced a carbon price floor (CPF). Initially, this mechanism aimed to bring about a carbon price of

£30/tCO₂ by 2020²¹, but in 2016 it was modified to limit its impact on British competitiveness [50], [52].

Figure 4.15 shows the assumptions made about Great Britain regarding non-renewable thermal generation. The CPF has put significant pressure on the profitability of **coal-fired** plants, resulting in a drop of around 7.1 GW in 2018 in installed capacity from coal-fired generation, compared to a 2015 level of 17.3 GW. The installed capacity of coal-fired electricity production is expected to continue falling over the coming winters and reach 4.3 GW by winter 2021-22. This will amount to a total decrease of approximately 75% of installed coal-fired capacity in Great Britain over five winters.

British **gas-fired** generation units are not expected to face the same profitability issues as in the rest of Europe. The closure of older units is being offset by additional CHP projects and other small-scale non-renewable generation, leading to a stable level of gas-fired generation over the coming winters. No closures of existing **nuclear** units are taken into account, and the most advanced new nuclear project in Great Britain – the EPR Hinkley Point C – will not be on stream in the years under consideration.




Figure 4.15

4.4.1.2 Renewable electricity generation

Figure 4.16 shows the assumptions made in this study regarding renewable electricity generation in Great Britain. The development of renewable generation capacity in Great Britain is incentivised through the contracts-for-difference (CfD) mechanism introduced in the 2013 electricity market reform. The installed capacity of offshore wind is expected to increase by more than 4 GW by winter 2021-22, compared to winter 2018-19. For photovoltaic and onshore wind production, limited increases in installed capacity of

²¹ A carbon price of £30/tCO₂ by 2020 (in 2009 prices) was initially envisaged.

roughly 8% and 3% respectively are expected for the same period. No significant change is expected during that time for biomass, hydropower and other renewable generation capacity.




Figure 4.16

4.4.2 Electricity demand in Great Britain

The total electricity demand assumed in this study for Great Britain is in line with the steady progression scenario set out in the 2018 FES report [23]. This scenario envisages pretty stable normalised annual demand up to 2022, as in three of the four 2018 FES scenarios. The 2018 FES two degrees scenario is the only one that envisages a slight increase in demand due to the very rapid electrification of transport.

Figure 4.17 shows historical electricity demand in Great Britain (not normalised for temperature) together with the projection used in the current study (normalised for temperature). For all winters, 2.24 GW of demand-side response is assumed for Great Britain, in line with what National Grid communicated to ENTSO-E in the context of the 2018 MAF.




Figure 4.17

4.4.3 Security of supply in Great Britain

Since winter 2017-18, Great-Britain's security of supply has been managed through its capacity market (CM). British TSO National Grid performs analyses the capacity that needs to be contracted to enable Great Britain to meet its adequacy criterion, namely an average LOLE of less than or equal to three hours. A recommendation about the capacity to contract is made using a least worst regret (LWR) method that considers multiple scenarios (including the FES scenarios) and sensitivities. Subsequently, it is up to the government to decide on the details of the capacity market auction.

The first CM auction was held in December 2014 for delivery in winter 2018-19. For winter 2017-18, capacity was auctioned via an 'early auction' held in February 2017 and a 'transitional auction' held in March 2017.

The latest report analysing medium-term security of supply in Great Britain is the *Electricity Capacity Report 2017* [51] submitted to the British government by National Grid in May 2017. That report recommended the capacity market volume to be secured for winters 2018-19 and 2021-22. Making only minor adjustments [63], the British government followed the recommendation made by National Grid. The auctions designed to guarantee capacity for winters 2018-19 and 2021-22 took place at the start of 2018.

The latest CM auction, held on 8 February 2018, secured around 50 GW of capacity at a relatively low price of £8.40/kW for delivery in 2021-22. This year's auction signifies a major shift away from coal, with 8 GW of existing coal plants not securing agreements via the auction. Existing gas and nuclear facilities, new interconnectors and decentralised energy are expected to fill the gap [80][81].

On 15th November 2018, the General Court of the European Union has decided, to annul the European Commission's decision not to raise objections to the aid scheme establishing a 'capacity market' in the United Kingdom. The ruling has resulted in the suspension of the UK's 'capacity market', thus preventing the government from holding future auctions or making payments under existing agreements [82].



Winter Outlook Report 2018-19

Source: National Grid (11 October 2018)

For this winter, even under colder conditions than experienced in recent years, we are confident we have the right products and strategies in place to help us balance the gas and electricity networks.

[...]

We currently expect there to be sufficient levels of generation and interconnector imports to meet demand throughout the winter.

[...]

We expect a net flow of power from Continental Europe to GB at peak times, occasionally not at full import.

There are no planned outages on the IFA and BritNed interconnectors and so we expect full imports into GB from France and the Netherlands under normal network operating conditions.

4.5 Luxembourg

Modelling the situation in Luxembourg is important for Belgium because part of that tiny country is connected to the Belgian control area (the 'LUB' zone in Figure 4.18). In 2016, the CCGT plant in Luxembourg but belonging to the Belgian control area was shut down definitively [53]. Since that closure, the LUB zone has only included consumption. Consumption in that zone is therefore counted as part of Belgium's load. The two other electrical zones in Luxembourg are:

- a part connected to France (LUf) that only contains load;
- the remainder of the country, which is connected to Germany. This zone includes all the country's hydroelectric capacity, wind, PV and residual load;
- The IC BeDeLux project, which physically connects the LUB and LUG zones, is not taken into account in this study. See section 5.1.4 for more information.




Figure 4.18

4.6 Other countries modelled

This study models 20 countries in all, making assumptions about each of them regarding non-renewable generation facilities, demand and renewables. Most of these assumptions are based on pan-European adequacy studies, such as the mid-term adequacy forecast published this year covering 2020 and 2025 (see section 1.8.4 for more information), ENTSO-E transparency platform [26], ENTSO-E statistics [33], bilateral contacts, PLEF adequacy study and national reports and statistics.

5 Interconnection modelling and assumptions



Belgium is at the heart of the interconnected European grid. It is surrounded by France, the Netherlands, Germany, and Luxembourg, which, depending on the situation of their respective grids and markets, can each import or export large amounts of electricity. Moreover, as of winter 2019-20, the Nemo Link[®] interconnector will enable Belgium to exchange electricity directly with Great Britain. Furthermore, the ALEGrO interconnector is expected. As Belgium is structurally dependent on imports to ensure its adequacy, correct modelling of these interconnections is crucial.

Exchange capabilities between countries are modelled in this analysis in the same way as currently done on the day-ahead market:

- Commercial exchanges **inside the CWE** region are taken into account using the same **flow-based** methodology in the actual day-ahead market coupling (see Figure 5.1). This is further described in section 5.1.
- Exchanges between **other countries and the CWE zone** are modelled with **fixed exchange capacities** (also called NTC – Net Transfer Capacities). See section 5.2 for more information.

Interconnections inside the CWE zone are modelled with the flow-based methodology



Figure 5.1

Maximum simultaneous import capacity for Belgium

Belgium's maximum simultaneous import capacity is the maximum power that the country can import under normal grid operation conditions, meaning without either planned or forced outages of the grid infrastructure, (in Belgium and in the neighbouring countries) that results from the need of ensuring sufficient available resources for voltage regulation, short-circuit power and inertia that are normally offered by the countries' internal production. In the event of considerable imports, steps must be taken to ensure that such production is still sufficiently present.

For the winter 2019-20 analysis, the maximum simultaneous import capacity is assumed to be equal to 5500 MW. Since as from winter 2019-20, the Nemo Link[®] High-Voltage

Direct Current (HVDC) interconnector will be operational, Belgium's total maximum simultaneous import capacity needs to account both for the imports within the CWE area and imports or exports from/to Great Britain through the Nemo Link® High-Voltage Direct Current (HVDC) interconnector.

5.1 Flow-based methodology applied to the CWE zone

Elia is a pioneer in the flow-based approach for adequacy studies, and has developed a methodology to model exchanges between CWE countries that replicates the day-ahead operation. Building on the experience of the previous assessments for winters 2016-17, 2017-18 and notably 2018-19, the same methodology is used for the winter 2019-20 assessment (see Figure 5.2). The correlation of the flow-based domains with climatic conditions is considered in a systematic way by the applied methodology. Moreover, the most recent historical domains from 2017 have been considered. These have been recalculated to consider two important features:

1. All grid maintenances occurring on the historical days considered for winter have been removed to account for the effect of a 'full grid' within CWE.
2. The historical domains have also been recalculated considering the effect of the so-called minRAM20% (see text box).




Figure 5.2

Introduction of the 'minRAM20%' in the flow-based market coupling algorithm

During 2018, CWE NRAs asked CWE TSOs to implement a 20% minimum Remaining Available Margin (minRAM20%) for the day-ahead flow-based market coupling (FBMC). The agreed minRAM20% level equals 20% of the Fmax (the maximum allowed power flow), applied on each Critical Network Element and Contingency (CNEC). The feasibility of the minRAM20% application is verified by TSOs for each business day. The go-live of

the minRAM20% implementation happened on 24 April 2018 in D-2 (for FBMC Business Day 26 April 2018).

The minRAM20% process is applied to provide a minimal flow-based domain to the market. The minRAM20% is applied using the AMR (Adjustment for Minimum RAM) attribute of each affected CNEC which guarantees a minimal RAM per CNEC. The implementation of minRAM20% provides more capacity for commercial exchanges and thus potentially lowers the need for strategic reserves.

The effect of minRAM20% is taken into account as a baseline assumption in this and any further assessment performed by Elia regarding the volume assessment for strategic reserves, since this feature is currently operational in the capacity calculation of the FBMC framework. Notwithstanding the daily verification of the minRAM20% feasibility by the TSOs, it is assumed that especially in case any country suffers severe adequacy issues, all efforts will be taken to ensure the application of the minRAM20% principle.

The flow-based method used for this analysis was developed and implemented by French TSO RTE (see reference documents [70] and [71]), and is also used in RTE's adequacy study (Bilan Prévisionnel 2017 and 2018 editions [32]) as well as in the 'Pentalateral Energy Forum - GAA 2018 report' (PLEF 2017) published in January 2018 and the latest MAF 2018 report [15]. The method can be summarised as follows:

1. The method **is consistent** with the method used last year;
2. A large set of domains, 4 x 24 hourly historical domains, is used;
3. A **systematic approach** is used to correlate the above 4 x 24 flow-based domains with **expected climatic situations** for the next winters.

These improvements make it possible to better capture uncertainties about Belgium's import and export capabilities.

German - Austrian bidding zone split


Capacity calculation with separate German and Austrian bidding zones is operational only since 1st October 2018. No sufficient historical winter domains were available at the time of the assessment. Still and in order to consider this evolution in the best possible way, the assumptions agreed between TSOs in the 'Pentalateral Energy Forum - GAA 2018 report' (PLEF 2017) have been followed also in the assessment here. During the PLEF study, two different market zones for DE and AT, interconnected by an NTC interconnection, were implemented in the model.

5.1.1 Why is the flow-based methodology applied for this study?

As Belgium is at the centre of the CWE zone, the country's import and export capabilities are currently entirely defined by the flow-based methodology used at regional level for the day-ahead markets. Belgium's net position is therefore linked to the net position of the other countries in the CWE zone and to the flow-based domain defining the possibilities of energy exchange between those countries. It is therefore critical to replicate market operation as closely as possible in order to quantify the country's loss of load expectation.

The flow-based method makes it possible to properly take into account interactions between market outcomes and the transmission grid. For instance, at moments when both France and Belgium are in structural shortage, Belgium's achievable imports can be

significantly reduced. Using the flow-based method in this assessment makes it possible to calculate the likelihood and impact of reduced imports on adequacy as a result of market conditions in neighbouring countries. Figure 5.3 shows the flows between four fictitious zones when 100 MW is exchanged from zone A to zone D. The resulting flows follow the path of least impedance. This will result in flows between zones not participating in this energy exchange (zones B and C for example). This example illustrates the basic principle behind and reason of introducing a flow-based approach into the market coupling.



5.1.2 How does the flow-based method in day-ahead work in reality?

i An informative explanation (in French) of flow-based market coupling is available. It is based on a film produced by the French energy regulator (CRE) [43].

More information about the flow-based rules and methodologies is available from Elia [44], JAO resource center [45] and EPEX Spot Belgium [46].

The flow-based method implemented in day-ahead market coupling uses Power Transfer Distribution Factors (PTDF factors) that make it possible to model real flows through the physical network lines as a result of commercial exchanges between countries after market coupling.

For each hour of the year, the impact of energy exchanges on each Critical Network Element (also called 'branch') taking into account the N-1 criterion is calculated (see box on the N-1 criterion). The combination of Critical Network Elements and Contingencies (CNEC's) therefore forms the basis of the flow-based calculation.

A reliability margin on each CNEC is considered and, where appropriate, 'remedial actions' are also taken into account. These actions can be taken, preventively or after an outage has occurred, to partly relieve the loading of the concerned critical network

element. Those actions make possible to maximise exchanges thanks to changes in the topology of the grid or the use of phase shifting transformers.

This procedure finally leads to constraints which form a domain of safe possible energy exchanges between the CWE countries (this is called the flow-based domain).

Different assumptions are made for the calculation of this domain, such as the expected renewable production, consumption, energy exchanges outside the CWE area, location of generation, outage of units and lines, etc.

For every hour there might be a different flow-based domain because:

- the topology of the grid can change;
- outages or maintenance of grid elements can be present;
- the location of available generation units can vary.

The operational calculation of the flow-based domain for a given day is started two days before real-time operation and is used to define the limits of energy exchange between countries for the day-ahead market.

The N-1 security criterion for the grid

Interconnection capacity takes into account the margins that transmission system operators (TSOs) must maintain in order to follow the European rules ensuring the security of supply. A line or grid element can be lost at any time. The remaining lines must be able to cope with the increased electricity flow due to any such outage. In technical terms, this is called the N-1 rule: for a given number N of lines that are transmitting a given amount of energy, there cannot be an overloaded line in case of the outage of one of the lines. The flow-based domain is calculated taking into account N-1 cases.

Note, however, that European rules stipulate that this criterion must be fulfilled at each moment, including in the event of maintenance or repair works. In such cases, it is possible that interconnection capacity will have to be reduced. Wherever possible, maintenance and repair works are avoided during the most critical periods, e.g. around the peak consumption times of the year, but cannot be ruled out, especially after winter weather conditions.

The adequacy patch

The CWE flow-based algorithm includes an 'adequacy patch' defining rules for sharing energy exchanges in scarcity situations.

If a country has a structural shortage (day-ahead price reaches 3000 €/MWh in that country) the adequacy patch ensures that the maximal feasible import capacity will be allocated to that country.

When two or more countries simultaneously have a structural shortage, imports will be allocated to those countries in proportion to their respective needs, on the basis of a quadratic function defined in the Euphemia market coupling algorithm.

For the purposes of the adequacy study, a modelisation of the adequacy patch is taken into account in the results from ANTARES in post-processing.

5.1.3 Improved method for determining the representative flow-based domains and their correlation with climatic variables

The representative flow-based domains have been chosen after analysis of historical data for 2017. The historical data used is the same as the data used in the framework of the Standard Process to Assess the Impact of significant Changes (SPAIC) within the CWE flow-based consultation group towards market parties. The historical domains here considered are therefore those from the official 'SPAIC 2017 typical days' selection process.

Three main steps (see Figure 5.4) have been followed to define the relevant flow-based domains for the analysis of winter 2019-20:

1. Selection of 'typical' days;
2. Determination of the correlation between typical days and specific climatic conditions;
3. Assignment of flow-based domains to the hourly market simulations based on the correlation determined in step 2.




Figure 5.4

Step 1: Selection of 'typical' days

A statistical analysis of the geometrical shapes of available flow-based domains is performed on historical records of domains from the FB CWE operational tool. Historical days are therefore clustered in families defined by the size of their 24 hourly domains,

i.e. typically 'large', 'medium' and 'small' families of domains are clustered. Each typical day consists of 24 hourly domains (one for each hour).

- Small domains correspond to situations with a highly congested network and therefore with small values for the maximum power exchanges possible between the different market areas considered by the given domain (related to the small volume inside the domain);
- Large domains correspond to situations with a less congested network and therefore relatively higher values of maximum possible power exchanges between the market nodes considered by the given domain (larger volume);
- A typical day is the historical day within a given family or cluster of domains, which provides the best representation of all the other days in the cluster;
- Since flow-based domains are hourly, this typical day is selected by comparing its domain at every hour to the other days' equivalent domain (at the same hour).

Step 2: Establishment of the correlation between each 'typical' day and specific climatic combinations

Four typical days for winter are found as a result of the clustering analysis (three weekdays and one weekend day). A probability matrix is then calculated as a function of daily energy ranges (high/medium/low) of wind production and load. This calculation provides the correlation of each typical day (24 hourly domains) to given climatic combinations (e.g. low wind, high load).

Step 3: Assignment of flow-based domains to hourly market simulations

The typical days for winter of Step 1 are used as *proxies* for the relevant domains expected during next winter 2019-20 and are assigned to hourly simulations by the correlation found in Step 2. Each hourly simulation of the interconnected power system presents different expected climatic, generation and demand situations during next winter.

This kind of systematic approach makes it possible to link specific combinations of climatic conditions expected next winter, e.g. high/low wind infeed in Germany, high/low temperature and demand in France and Belgium, with representative domains for these conditions. The systematic approach constitutes a significant improvement compared to eg. the 2017-18 assessment, where the domains were assigned to specific hours based on the German wind production only.

5.1.4 What changes were made to the 'representative operational domains'?

For the above mentioned historical days, the topology of the grid is known, including historical planned and unplanned outages. The representative flow-based domains mentioned in section 5.1.3 were updated to remove historical grid outages. This was done by all CWE TSOs, so these considerations apply to the grids of BE, FR, DE and NL used for the re-calculations of the domains.

Note on planned investments

On one hand, the Nemo Link[®] HVDC [42] interconnection with Great Britain, was taken into account as of winter 2019-20 in all simulations. The link is modelled as an NTC link

without impact on the flow-based domains, and the connection has an exchange capability of 1000 MW between Belgium and Great Britain. The maximum simultaneous import capacity for Belgium for winter 2019-20 accounts for:

1. imports into Belgium from CWE
2. imports or exports over the Nemo Link® interconnector.

This maximum simultaneous import capacity for Belgium is set to 5500 MW in the assessment for winter 2019-20.

The planned HVDC interconnection with Germany (ALEGrO project [41]) has a target commissioning date of late 2020 and it is assumed to be operational for winter 2021-22 and winter 2021-22 in this assessment.

The maximum simultaneous import capacity for Belgium for winter 2021-22 then accounts for:

1. imports into Belgium from CWE including the effect of the ALEGrO interconnector;
2. imports or exports over the Nemo Link® interconnector.

The additional voltage regulation possible thanks to the ALEGrO project, combined with investments in additional capacitor banks will allow for an increase of the maximum simultaneous import capacity for Belgium to 6500 MW in the assessment for winter 2020-21 and 2021-22.

Implementation of ALEGrO in the FB domains calculation for the winter 2020-21 and 2021-22 assessments required addition of virtual HUBs in the PTDF – RAM calculation.

Inclusion of ALEGrO in the FB modelling




Figure 5.5

IC BeDeLux project

The technical go-live of the phase shifter transformer (PST) situated in Schiffflange connecting the grid of Elia and Creos was put in operation 11 October 2017. The technical trial period consists of 2 phases and will have a duration of one year starting from the moment of the technical go-live. After the first phase of the technical trial period an assessment was made by the project to evaluate whether new insights were gathered that would allow an earlier initiation of the commercialization of the

interconnector. The IC BeDeLux project (Amprion, Creos and Elia) will assess further whether new insights were gathered based on the technical trial period so far that allow significant adaptation of the technical parameters and as such, justify the launch of a new SPAIC study.

Major adjustments in the constraints and/or available PST taps for capacity calculation in Day-Ahead (DA) timeframe are a prerequisite to reassess, through a new SPAIC study, the impact of the commercialization of IC BeDeLux within the CWE region. If this new SPAIC study indicates a positive welfare gain for the CWE region, then an initiation of the commercialization of the interconnector could be initiated.

The PST is thus not included in the 2017 SPAIC typical days used as input for this study, since the PST is not (yet) considered in the DA FB assessment.

5.1.5 Illustration of the domains used for this study on the BE-FR CWE net positions:

The relevant typical days found by the clustering procedure explained above for the winter period are:

- Flow-based typical day 1: **19-01-2017** (weekday - SMALL)
- Flow-based typical day 2: **16-11-2017** (weekday - MEDIUM)
- Flow-based typical day 3: **18-12-2017** (weekday - LARGE)
- Flow-based typical day 4: **07-01-2017** (weekend - WE)

Each typical day consists of 24 hourly domains (one for each hour). The projections of the 24 domains for the flow-based typical day 1 (SMALL) onto the Belgium-France balance plane are shown in Figure 5.6. It can be seen that hour 19 (from 18:00–19:00) provides a highly constraining boundary in the lower left quadrant. This boundary is highly relevant for the Belgium adequacy, as it constrains the combined import capacity available to France and Belgium from CWE.

The 24 hourly domains for the flow based typical day 1 (SMALL)




Figure 5.6

The domains used in the assessment are based on historical domains from the CWE flow-based environment, and have been recalculated to remove the effect of grid outages that occurred during the selected historical days. Furthermore the effect of the so-called 20% minimum Remaining Available Margin (minRAM20%) has been also considered in the domains.

For illustrative purposes, domains are depicted in Figure 5.7 for the typical day 1 (SMALL), in Figure 5.8 for the typical day 2 (MEDIUM), and in Figure 5.9 for the typical day 3 (LARGE), at hour 19. Different types of domains are shown, indicating the impact of:

- not considering the minRAM20%: ('W19-20 - MinRAM0%' in the legend);
- adding the effect of minRAM20%: ('W19-20 - minRAM20%' in the legend);
- adding the effect of ALEGrO for winter 2020-21 and 2021-22: ('W20-21/21-22 - minRAM20%' in the legend);
- the domains used in last year's assessment: 'W18-19', for comparison.

The 'W19-20 - minRAM20%' and 'W20-21/21-22 - minRAM20%' domains are the ones used in the assessment for the need of a strategic reserve.

A detailed analysis of the impact of the domains on the adequacy results is presented in sections 6.2 and 6.3.




Figure 5.7




Figure 5.8




Figure 5.9

The flow-based domains depicted on the figures above only reflect exchange capacities between the countries inside the CWE region, so the import possibilities of CWE countries from outside CWE are not shown. In the model used for determining the volume of strategic reserves (ANTARES) as well as in the day-ahead market coupling, France can for example import from other countries within the limits of the NTC constraints on the concerned borders.

5.2 Commercial exchange capacities within CWE

The NTC capacities used in this study are obtained through studies conducted within ENTSO-E and from bilateral and multilateral contacts between Elia and other TSOs. The capacities take into account planned new interconnections for future winters. In reality, NTC's can vary from day to day depending on the conditions of the network and the availability of lines and other network elements. In this study, a single reference value is used for a given interconnection in a certain direction during the entire period simulated. The historical exchange capacities can be found on the websites of the relevant system operators and on ENTSO-E's transparency website [26].

5.2.1 Import capacities of the CWE zone from neighbouring countries

The impact of countries outside the CWE zone on the risk of a structural shortage in Belgium consists of the capacity of these countries to provide energy to the CWE zone in case of a power shortage at CWE level.

The following import capacities (NTC) into the CWE zone are taken into account in this study:

- **Austria:** Total net import capacity for Austria (from outside CWE), is considered to be **3.9 GW** for winter **2019-20**. This value is the sum of import capacities on the borders with Czech Republic, Hungary, Switzerland, Italy, Slovenia;
- **Belgium:** Total net import capacity for Belgium (from outside CWE) is considered to be **1 GW** as of winter **2019-20**, thanks to the HVDC interconnection with Great Britain (Nemo Link®);
- **Germany:** Total net import capacity for Germany (from outside CWE), is considered to be **12.7 GW**. This value is the sum of import capacities on the borders with Poland, Czech Republic, Switzerland, Norway, Sweden, and Denmark;
- **France:** Total net import capacity for France (from outside CWE) is considered to be **6.4 GW** for winter **2019-20**. This value is the sum of import capacities on the borders with Spain, Italy, Switzerland and Great Britain;
- **The Netherlands:** Total net import capacity for the Netherlands (from outside CWE), is considered to be **2.4 GW** for winter **2019-20**. This value is the sum of import capacities on the interconnectors with Norway and Great Britain as well as the 700 MW HVDC cable (COBRA cable [59]) between the Netherlands and Denmark.

The sum of import capacities shown in Figure 5.10 is the maximum possible import capacity to the CWE region (Belgium, France, Netherlands, Germany, Austria,

Luxemburg) during winter as assumed in the simulations. The sum of this maximum import capacity (>25 GW) may seem high. However for the whole capacity to be used, the energy must be available in the foreign countries (outside the CWE zone) at times of structural shortage. As the simulation scope includes those countries, the availability of generation is explicitly taken into account.

Assumptions regarding the maximum import capacity from outside the CWE zone (only from countries outside this zone)




Figure 5.10

Exchanges with non-modelled countries

No exchanges between the countries that are modelled and those that are not modelled are considered. This is a conservative assumption because these exchanges do exist and could contribute to power supply of the CWE region. The countries modelled in addition to the CWE countries²² are: Spain (ES), Portugal (PT), Great-Britain (GB), Ireland (IE), Northern Ireland (NI), Switzerland (CH), Slovenia (SI), Czech Republic (CZ), Slovakia (SK), Hungary (HU), Norway (NO), Denmark (DK), Sweden (SE) and Poland (PL). Since the geographical perimeter considered around Belgium is significant, the effect of the above mentioned assumption has little impact on the adequacy situation in Belgium.

5.2.2 HVDC forced outages

A detailed modelling of the availability of HVDC system elements is included in the analysis. The availability of HVDC interconnectors is modelled using a forced outage rate (FOR), which in this case defines the annual rate an HVDC interconnector is unavailable. Forced outages are simulated by random occurrences of outages within the probabilistic 'Monte Carlo' scheme (see section 8.1.1), whilst respecting the annual rate defined. This is illustrated in Figure 5.11 for the 1000 MW Nemo Link[®] HVDC interconnector between

²² Germany (DE), France (FR), Belgium (BE), The Netherlands (NL), Luxembourg (LU) and Austria (AT)

Belgium and Great Britain. The figure shows the average availability of the interconnector throughout the winter, as well as some examples of availabilities for a given 'Monte Carlo' year. An unavailability rate for each HVDC interconnector of 6% has been used, in line with the value used for the ENTSO-E MAF report [15]. Moreover, the ENTSO-E 'HVDC Reliability' Task Force within the 'Asset Implementation and Management' Working Group (WG AIM) has recently confirmed the 6% HVDC FO as a benchmark value.






Figure 5.11

6 Results



This chapter contains the results for winter 2019-20, winter 2020-21 and winter 2021-22. Section 6.1 provides a short overview of the main assumptions used for winter 2019-20. Section 6.2 provides a detailed analysis of the results for the 'base case' scenario for winter 2019-20. In addition to the 'base case' scenario, a sensitivity regarding nuclear availability in Belgium and France was also analysed for winter 2019-20. This 'low probability - high impact' scenario, together with its results is discussed in section 6.3. Section 6.4 presents the corresponding results for winter 2020-21 and winter 2021-22.

The results are presented using the following adequacy indicators:

- The criteria defined by law (**LOLE average and LOLE95**) as discussed in section 1.3, given in hours. The distribution of the LOLE is also presented where the other percentiles can be clearly identified. Additionally a table is given next to the chart containing P50 and maximum values of LOLE;
- The **Energy Not Served (ENS)**, expressed in GWh. Both the average over all simulated 'Monte Carlo' years is given for the studied winter, as well as the P95;
- The **probability of a structural shortage** for a given winter reflects the chance of having at least one hour of structural shortage;
- The **need for strategic reserve (positive number) or margin (negative number)** in the system in order to reach the adequacy criteria defined by law;
- When a need for a volume of strategic reserve is identified, the **number of activations** and the **length of an activation** of this volume are given with average, P95 and maximum values. When a margin is identified, these numbers are given for a hypothetical volume of strategic reserve.

6.1 Assumptions for winter 2019-20

The 'base case' was constructed on the basis of the situation as known at the end of October 2018. A brief summary of this 'base case' scenario is given below, with the details provided in chapters 3, 4 and 5.

6.1.1 Main hypotheses for Belgium

Thermal generation facilities as known at end-October 2018, based on the latest closure announcements by producers (announced at the latest by 31 July 2018 for winter 2019-20) (cfr. chapter 3).

Regarding their availability, an extract of the transparency channels (REMIT) taken on October 22nd 2018 and monitored until November 8th 2018, is used for the purpose of this study.

In this extract, some planned unavailabilities were still remaining for winter 2019-20. Below an exhaustive overview of those unavailabilities, which have been taken into account for all the analysis performed, is provided:

- TIHANGE 1N in maintenance from 3/08/2019 until (inclusive) 28/11/2019
- TIHANGE 1S in maintenance from 3/08/2019 until (inclusive) 28/11/2019
- DOEL 1 in maintenance from 24/08/2019 until (inclusive) 27/12/2019
- DOEL 2 in maintenance from 31/08/2019 until (inclusive) 20/12/2019

- MARCINELLE ENERGIE (Carsid) in maintenance from 21/12/2019 until (inclusive) 29/12/2019
- RODENHUIZE 4 in maintenance from 28/12/2019 until (inclusive) 29/12/2019
- RODENHUIZE 4 in maintenance from 14/03/2020 until (inclusive) 22/03/2020

Market response is taken into account based on the results of the market response study (820 MW for winter 2019-20);

Forecasted installed capacities for wind onshore and PV are a best estimate based on a consultation with the regions, the offshore installed capacity is forecasted based on a best estimate by Elia and FPS Economy;

Total demand growth is approximately 0.6%/year on average between the years 2019 and 2022;

Forced outage rates are based on observations over the past 10 years, excluding the exceptional nuclear unavailability experienced in Belgium in recent years, which is specifically covered by the analysed sensitivity.

6.1.2 Main hypotheses for other countries

French assumptions are in line with those used for the latest adequacy report published by RTE [32];

Dutch assumptions are in line with the latest TenneT adequacy report 2018 (to be published in December 2018);

German assumptions are in line with the latest communications from German regulator BNetzA [40];

Assumptions for **Great Britain's** are based on the 2018 FES 'Steady Progression' scenario [23].

6.1.3 Interconnections

A new interconnection between Belgium and Great Britain (Nemo Link[®]) capable of exchanging 1000 MW is assumed to be available from winter 2019-20 onwards.

Flow-based modelling with four typical days for winter 2019-20 is used in this assessment for the CWE region. For the rest of Europe, interconnection capacity is modelled as NTC.

A maximum simultaneous import capacity of 5500 MW is considered for Belgium in winter 2019-20. This simultaneous import capacity is imposed on the 'global Belgian import', i.e. import from CWE plus the flow through Nemo Link[®].

As mentioned in section 5.1, the 'base case' scenario considers the effect of a 20% minimum remaining available margin (minRAM20%) for the day-ahead flow-based market coupling (FBMC) domains considered.

6.2 Results for winter 2019-20 'base case'

6.2.1 Calculation of LOLE, ENS and number of activations

As explained in chapter 2, a margin or deficit (i.e. a need for strategic reserve volume) is calculated for both legally required criteria (LOLE average and LOLE95). The resulting values are shown in Figure 6.1. The LOLE average for winter 2019-20 is **below 15 minutes** and the percentile 95 is **0 hours**. These results are lower than the criteria defined by law, and the margin corresponding to the 2019-20 'base case' scenario is **3300 MW**.




Figure 6.1

As can also be observed in Figure 6.1, the number of activations of a possible volume of strategic reserve would be very low: **0.1 times** per year on average, **0 times** in P95 and **5 times** in the most extreme 'Monte Carlo' year simulated. The figure also indicates the maximum duration that a possible volume of strategic reserve would be activated without interruption. For the most extreme simulated event in all the future states, a possible volume would be activated for a maximum duration of **6 hours** without interruption. The average of the maximal activation length is around **1.4 hours**. Furthermore, Figure 6.1 shows that the amount of Energy Not Served (ENS) is limited to a value lower than **0.1GWh** over the winter on average and to **0 GWh** in P95.

Figure 6.2 shows the cumulative distribution of the LOLE over all 'Monte Carlo' years simulated for the 'base case' scenario when no volume or margin was added. The probability of having at least one hour of structural shortage amounts to **3%** for winter 2019-20. In the most extreme year simulated, **10 hours** of structural shortage were obtained. The small table next to the graph indicates the P10, P50 and P95 of the LOLE distribution. In the 'base case' scenario for winter 2019-20, those are all equal to **0 hours**.




Figure 6.2

6.2.2 Imports in periods of structural shortage

The hours in which structural shortage is identified for winter 2019-20 in the 'base case' simulation, can be classified on the basis of Belgium's imports during these hours (see Figure 6.3).

In this figure, each point represents one hour in which ENS is identified in Belgium. The graph shows imported energy for Belgium and France within CWE (resulting from flow-based market coupling), and the coloured domains indicate the respective flow-based domain types of each hour relevant for the situations in which ENS was identified.

In Figure 6.4 , focuses in on the relevant area is shown. The purple points indicate situations with simultaneous scarcity in Belgium, France and Great Britain. The blue circles indicate simultaneous scarcity in Belgium and France only.

Imported energy for Belgium within CWE vs Energy Not Served (ENS) in MWh/hour is shown in Figure 6.5. It is important to specify that this graph is based on the 'base case' simulation, which has an average LOLE below **15 minutes**. Still in situations of simultaneous scarcity in Belgium, France and Great Britain (purple points), the ENS of Belgium can reach values up to **600 MWh/hour**. ENS in Belgium occurs when imports within CWE are around 500 MW or less.

**Belgian and French balance (CWE only) for hours with ENS
in the winter 2019-20 'base case' scenario**




Figure 6.3

**Belgian and French balance (CWE only) for hours with ENS
in the winter 2019-20 'base case' scenario**




Figure 6.4

Hourly Energy Not Served, vs BelgianCWE balance for winter 2019-20 'base case' scenario




Figure 6.5

The ability to find energy abroad when there is structural shortage in Belgium is crucial for Belgium's security of supply, due to Belgium's high dependence on imports for its own adequacy. This ability for Belgium to obtain sufficient imports in situations of structural shortage will be reduced if its neighbours are also experiencing adequacy problems at the same time. This is readily illustrated in the figures above with the distinction of two situations i) situations of simultaneous scarcity in Belgium, France and Great Britain (purple points) and ii) situations of simultaneous scarcity in Belgium and France.

Figure 6.6 depicts the distribution of ENS among the different flow-based domains for the winter 2019-20 'base case', both per hour and aggregated per 'typical day'. The hours with highest contribution to ENS are 'hour 19' (18:00 - 19:00 CET), 'hour 18' (17:00 - 18:00 CET) and 'hour 20' (19:00 - 20:00 CET) for the medium and small domains. These hours typically correspond to the highest European residual load (load - renewable generation) from observed historical data (see ENTSO-E Seasonal Outlooks [74]) and are the hours when the peak load typically occurs for France and Belgium in winter.

Furthermore, from the hourly distribution of ENS amongst the Flow-Based domains depicted in Figure 6.6, it is visible that ENS can also occur at hours other than the evening peak-load hours. ENS is observed from 8 AM when the electricity demand starts to increase before the morning peak. Penetration of renewables, mainly wind in Germany, is also correlated with the appearance of medium and small domains in the analysis. As shown in Figure 6.6, medium and small domains limit CWE exchanges in a large part of hours with ENS, with the medium domain accounting for 65.4% of the hours

with ENS while the small domain accounts for 34.2%. The large domains only appear in 0.4% of the hours with ENS. No ENS is found in the weekend hours.




Figure 6.6

6.2.3 Market response impact on adequacy

The market response assumptions used in the 'base case' scenario are explained in section 3.3. This available market response capacity for winter 2019-20, amounting to 820 MW, is taken into account with constraints on the number of activations and their duration, as described in section 3.3.

Figure 6.7 (left) shows three days of the simulation during which a relatively small structural shortage occurs. In such situations, market response helps to cover the shortages. It can be seen that market response makes it possible to cover Energy Not Served, resulting in no structural shortage during three consecutive situations. This was possible because the number of hours when market response was needed was limited, and the energy that had to be served was below the market response capacity. However, later in that week there are still remaining hours that cannot be covered due to the imposed limitations on the number of activations of such volume taken into account in this study.

Figure 6.7 (right) shows a more extreme situation during the same days of another week where larger volumes of structural shortages occur for several consecutive hours. In such situations, market response is of little help to cover the total Energy Not Served, but will still help to reduce the peaks. Increasing the market response capacity in such cases will also not help, unless the limitations on the volume are also reduced.




Figure 6.7

6.2.4 When is a structural shortage risk identified in the 'base case' scenario?

The risk of structural shortage in the 'base case' has been calculated from the hourly remaining margin of the system, after taking into account all possible imports within CWE and via Nemo Link® (see Figure 6.8). This 'heat-map' chart is constructed for didactic purposes and makes it possible to clearly identify those times when the risk of structural shortage is the highest. The colour legend shows the relative risks (structural shortages are more likely to happen in hours that are coloured red than hours that are coloured green). In general, the risk follows the country's residual demand (demand minus non dispatchable generation). Furthermore, effects such as weekday, weekends, peak/off-peak or holidays can be derived from the figure.




Figure 6.8

6.3 The ‘low probability – high impact’ sensitivity on nuclear availability

To provide a complete view of the adequacy of the Belgian system, it is important to also quantify low probability events with a high impact on Security of Supply. Therefore, on top of the analysis of the ‘base case’ scenario which was presented in section 6.2, Elia studied a specific sensitivity for nuclear availability in Belgium and France. Section 6.3.1 provides more details for this sensitivity, together with the elements that justify the analysis of the sensitivity. Next, in section 6.3.2 the results of the sensitivity are given.

6.3.1 Description of the sensitivity analysed

Due to the large share of nuclear capacity compared to the total installed generation capacity in Belgium, their availability has a significant impact on Belgian adequacy. In section 3.1.3.2, the unusual outages that occurred for **Belgian nuclear power** plants between 2014 and 2018 were already mentioned. Given the unusual nature of those outages, the decision was made not to include them in the forced outage rates of the ‘base case’ scenario. However, given their significant impact, it is important to analyse a scenario taking into account such events. Therefore, a detailed comparison between the availability modelled in the ‘base case’ and the Belgian nuclear availability experienced in the last seven winters was conducted. The seven winters taken into account range from 2012-13 until 2018-19 included.




Figure 6.9

Figure 6.9 gives the average and P95 modelled Belgian nuclear availability for the 2019-20 ‘base case’ scenario. When comparing the modeled P95 indicator with the same indicator as experienced over the last seven winters, it becomes apparent that the ‘base case’ modelled availability is highly optimistic in terms of the P95 indicator.

The P95 nuclear availability power indicator is then calculated when 1 GW and 1.5 GW, respectively, of nuclear production capacity is removed for the entire winter from the 'base case' scenario (middle and right bars in Figure 6.9). This indicator is then compared with the same indicator as experienced over the last seven winters (horizontal line in Figure 6.9).

As a result of this analysis, it is concluded that low-probability, high-impact events, as observed during the last seven winters, could be properly captured by assuming a **sensitivity with an additional 1.5 GW of nuclear production capacity out of service** for the entire winter in Belgium. This is demonstrated in Figure 6.9, with the P95 nuclear availability modelled for this sensitivity being in line with the P95 availability experienced over the past seven winters.

The same analysis was conducted for **French nuclear availability**, see Figure 6.10. When comparing the French P95 nuclear availability modelled in the 'base case' with the historical French nuclear availability of the last seven winters, it became apparent that a **sensitivity with an additional 3.6 GW (4 units of 910 MW) of nuclear production capacity** out for the entire winter in France should be considered in order to bring the P95 modelled availabilities in line with the experienced availabilities over the last seven winters in France.




Figure 6.10

It should be noted that the abovementioned calculated outages for the entire winter, for both France and Belgium, come on top of the planned outages and forced outages already modelled for the nuclear as well as the rest of the generation park for both countries in the 'base case' simulation.

6.3.2 Results for the 'low probability - high impact' sensitivity

6.3.2.1 Calculation of LOLE, ENS and number of activations

As explained in chapter 2, a margin or deficit (i.e. a need for strategic reserve volume) is calculated for both legally required criteria (LOLE average and LOLE95). The resulting values are shown in Figure 6.11 for the sensitivity. The LOLE average for winter 2019-20 in this sensitivity is **1 hour and 45 minutes** and the percentile 95 is **16 hours**. These results are lower than the criteria defined by law, and the margin corresponding to the

2019-20 'low-probability high-impact' scenario is **400 MW**. Note that the margin is determined by the percentile P95 indicator.




Figure 6.11

As can also be observed in Figure 6.11, the number of activations of a possible volume of strategic reserve would be very low: **0.5 times** per year on average, **4 times** in P95 and **9 times** in the most extreme 'Monte Carlo' year simulated. The figure also indicates the maximum duration that a possible volume of strategic reserve would be activated without interruption. For the most extreme simulated event in all the future states, a possible volume would be activated for a maximum duration of **18 hours** without interruption. The average of the maximal activation length is around **2.4 hours**. Furthermore, Figure 6.11 shows that the amount of energy not served (ENS) is limited to **0.7 GWh** over the winter on average and to **3.02 GWh** in P95.

Figure 6.12 shows the cumulative distribution of the LOLE over all 'Monte Carlo' years simulated for the 'low-probability high impact' scenario when no volume or margin was added. The probability of having at least one hour of structural shortage amounts to **15%** for winter 2019-20 in this sensitivity. In the most extreme year simulated, **45 hours** of structural shortage were obtained. The small table next to the graph indicates the P10, P50 and P95 of the LOLE distribution. In the 'low-probability high-impact sensitivity' scenario for winter 2019-20, the P95 is equal to **16 hours**.




Figure 6.12

6.3.2.2 Imports in periods of structural shortage

As for the 'base case' simulation, Belgium's and France's imports within CWE, during hours of ENS, are shown also here for the 'low probability high impact' scenario (see Figure 6.13).

In this figure, each point represents one hour in which ENS is identified in Belgium. The graph shows imported energy for Belgium and France within CWE (resulting from flow-based market coupling), and the coloured domains indicate relevant flow-based domains within hours for which ENS was identified. Three types of situations are identified: i) The purple dots indicate situations with simultaneous scarcity in Belgium, France and Great Britain. ii) The blue dots present situations of simultaneous scarcity in Belgium and France, thus when both countries are importing and present ENS. Belgian imports within CWE are in this case lower than 3500 MW. iii) Finally, the green dots present situations of scarcity in Belgium only. In this case, Belgium is importing and France is exporting. Belgian imports within CWE are in this case higher than 2000MW. We observe also that the maximum import of Belgium within CWE, within the identified hours with ENS, equals 4500 MW. This is in correspondence with the global import limit for Belgium of 5500 MW, since for those hours it is found from the simulations that there is an additional import from Great Britain via Nemo Link® of 1000 MW.

Imported energy for Belgium within CWE vs Energy Not Served (ENS) in MWh/hour is shown in Figure 6.14, also for the three different situations identified above. It is important to specify that this graph is based on the 'low-probability high-impact' simulation which has an average LOLE of **1 hour and 45 minutes and P95 of 16 hours, thus still within the legal criteria**. Still in very few situations of simultaneous scarcity in Belgium and France, the ENS of Belgium can reach values above **3000 MWh/hour**. These situations have been analysed in detail and correspond to situations of low temperatures in France and Belgium and high loads in France. These situations of high ENS of Belgium occur when imports within CWE for BE are 3000 MW or less. When Belgium can import above **3000 MW**, the values of ENS are reduced to values of **1500 MWh/hour** or less.




Figure 6.13





Figure 6.14

6.3.2.3 When is a structural shortage risk identified in the ‘low probability – high impact’ scenario?

Relative risk to have a structural shortage hour for winter 2019-20 in the ‘1.5GWBE+4uFR’ scenario based on the average hourly margin



Note that the probability to have a structural shortage for the winter 2019-20 based on the base case assumptions is very low and the legal criteria are satisfied without strategic reserve. This figure only shows the relative risk between the hours.

Figure 6.15

The risk of structural shortage for the ‘low-probability high-impact’ case has been calculated from the hourly remaining margin of the system, after taking into account all possible imports within CWE and via Nemo Link® (see Figure 6.15). This ‘heat-map’ chart is constructed for didactic purposes and makes it possible to clearly identify those times when the risk of structural shortage is the highest. The colour legend shows the relative risks (structural shortages are more likely to happen in hours that are coloured red than hours that are coloured green). In general, the risk follows the country’s residual demand (demand minus non-dispatchable generation). Furthermore, effects such as weekday, weekends, peak/off-peak or holidays can be derived from the figure.

6.4 Results for winter 2020-21 and 2021-22

6.4.1 Results for winter 2020-21 ‘base case’

Main hypotheses for Belgium

The ‘base case’ for winter 2020-21 follows the assumptions presented in chapter 3.

Regarding the planned unavailabilities of the thermal park, the assumptions of winter 2019-20 have been kept. This approach is chosen due to the uncertainty of the figures which can be found today in the transparency channels (REMIT) for winter 2020-21, as it

is likely that this figures will change next year. Furthermore, this allows comparison with the results for winter 2019-20 presented above.

The main changes of winter 2020-21 compared to winter 2019-20 are:

Market response is taken into account in line with the results of the market response study (868 MW for winter 2020-21);

Forecasted installed capacities for wind onshore and PV are a best estimate based on a consultation with the regions, the offshore installed capacity is forecasted based on a best estimate by Elia and FPS Economy. The following evolution is considered between winter 2019-20 and winter 2020-21:

- Onshore wind increase from 2513MW to 2775 MW
- Offshore wind increase from 1610MW to 2271 MW
- PV increases from 4433 MW to 5070 MW

Total demand growth is approximately 0.6%/year on average between the years 2019 and 2022;

Forced outage rates are based on observations over the last ten years, excluding the exceptional nuclear unavailability that was experienced in recent years in Belgium, which will be specifically covered by the analysed sensitivity.

Main hypotheses for other countries

French assumptions are in line with those used for the latest adequacy report published by RTE [32] and are presented in section 0;

Dutch assumptions are in line with the latest TenneT adequacy report 2018 (to be published in December 2018) and are presented in section 0;

German assumptions are in line with the latest communications from German regulator BNetzA [40] and are presented in section 4.3;

Great Britain's assumptions are based on the 2018 FES 'Slow Progression' scenario [23] and are presented in section 4.4.

Interconnections

A new interconnection between Belgium and Great Britain (Nemo Link®) capable of exchanging 1000 MW is assumed available from winter 2019-20 onwards.

Additional voltage regulation would be possible thanks to the ALEGrO project, combined with investments in additional capacitor banks. This will allow for an increase of the maximum simultaneous import capacity for Belgium to 6500 MW in the assessment for winter 2020-21.

Flow-based modelling with four typical days for winter 2019-20 is used in this assessment for the CWE region. Implementation of ALEGrO in the FB domains calculation for winter 2020-21 assessment is performed on these winter 2019-20 domains. For the rest of Europe, interconnection capacity is modelled as NTC.

A maximum simultaneous import capacity of 6500 MW is considered for Belgium in winter 2020-21. This simultaneous import capacity is imposed on the global Belgian import, i.e. import from CWE including the effect of ALEGrO, plus the flow through Nemo Link®.

As mentioned in section 5.1, the 'base case' scenario considers the effect of a 20% minimum remaining available margin (minRAM20%) for the day-ahead flow-based market coupling (FBMC) domains considered.

LOLE, ENS and number of activations




Figure 6.16

The resulting values are shown in Figure 6.16. The LOLE average for winter 2019-20 in the 'base case' is **15 minutes** and the percentile 95 is **1 hour**. These results are lower than the criteria defined by law, and the margin corresponding to the 2020-21 'base case' scenario is **3400 MW**. Note that the margin is determined by the percentile P95 indicator.

As can also be observed in Figure 6.16, the number of activations of a possible volume of strategic reserve would be very low: **0.2 times** per year on average, **1 time** in P95 and 6 times in the most extreme 'Monte Carlo' year simulated. The figure also indicates the maximum duration that a possible volume of strategic reserve would be activated without interruption. For the most extreme simulated event in all the future states, a possible volume would be activated for a maximum duration of **5 hours** without interruption. The average of the maximal activation length is around **1.2 hours**. Furthermore, Figure 6.16 shows that the amount of Energy Not Served (ENS) is limited to a value lower than **0.1GWh** over the winter on average and in P95.

Figure 6.17 shows the cumulative distribution of the LOLE over all 'Monte Carlo' years simulated for the 'base case' scenario when no volume or margin was added. The probability of having at least one hour of structural shortage amounts to **5%** for winter 2020-21. In the most extreme year simulated, **11 hours** of structural shortage were obtained. The small table next to the graph indicates the P10, P50 and P95 of the LOLE distribution. In the 'base case' scenario for winter 2020-21, P10, P50 are equal to **0 hours** and P95 is **1 hour**.




Figure 6.17

6.4.2 Results for winter 2020-21 'low probability – high impact' sensitivity

The same sensitivity as defined for winter 2019-20 is analyzed in winter 2020-21. This approach is chosen since it is considered that the unusual outages that occurred for Belgian and French nuclear power plants between 2014 and 2018 should be representative enough of low probability events having a big impact on Belgium's adequacy. Furthermore, this approach allows comparison with the results for winter 2019-20 presented above.

LOLE, ENS and number of activations




Figure 6.18

The resulting values are shown in Figure 6.18 for the sensitivity. The LOLE average for winter 2020-21 in this sensitivity is **2 hours** and the percentile 95 is **10 hours**. These results are lower than the criteria defined by law, and the margin corresponding to the 2020-21 'low-probability high-impact' scenario is **800 MW**. Note that the margin is determined by the percentile P95 indicator.

As can also be observed in Figure 6.18, the number of activations of a possible volume of strategic reserve would be very low: **0.5 times** per year on average, **4 times** in P95 and **13 times** in the most extreme 'Monte Carlo' year simulated. The figure also indicates the maximum duration that a possible volume of strategic reserve would be activated without interruption. For the most extreme simulated event in all the future states, a possible volume would be activated for a maximum duration of **18 hours** without interruption. The average of the maximal activation length is around **2.9 hours**. Furthermore, Figure 6.18 shows that the amount of energy not served (ENS) is limited to **1.3 GWh** over the winter on average and to **3.08 GWh** in P95.

Figure 6.19 shows the cumulative distribution of the LOLE over all 'Monte Carlo' years simulated for the 'low-probability high impact' scenario when no volume or margin was added. The probability of having at least one hour of structural shortage amounts to **10%** for winter 2020-21 in this sensitivity. In the most extreme year simulated, **59 hours** of structural shortage were obtained. The small table next to the graph indicates the P10, P50 and P95 of the LOLE distribution. In the 'low-probability high-impact sensitivity' scenario for winter 2020-21, the P95 is equal to **10 hours**.




Figure 6.19

6.4.3 Results for winter 2021-22 'base case'

Main hypotheses for Belgium

The 'base case' for winter 2021-22 follows the assumptions presented in chapter 3.

Regarding the planned unavailabilities of the thermal park, the assumptions of winter 2019-20 have been kept. This approach is chosen due to the uncertainty of the figures which can be found in the transparency channels (REMIT) for winter 2021-22, as it is likely that these figures will change next year. Furthermore, this allows comparison with the results for winter 2019-20 and winter 2020-21 presented above.

The main changes of winter 2021-22 compared to winter 2020-21 are thus:

Market response is taken into account in line with the results of the market response study (931 MW for winter 2021-22);

Forecasted installed capacities for wind onshore and PV are a best estimate based on a consultation with the regions, the offshore installed capacity is forecasted based on a best estimate by Elia and FPS Economy. The following evolution is considered between winter 2021-22 and winter 2020-21 are:

- Onshore wind increases from 2775 MW to 2939 MW
- Offshore wind remains constant at 2271 MW
- PV increases from 5070 MW to 5600 MW

Total demand growth is approximately 0.6%/year on average between the years 2019 and 2022;

Forced outage rates are based on observations over the last ten years, excluding the exceptional nuclear unavailability that was experienced in recent years in Belgium, which will be specifically covered by the analysed sensitivity.

Main hypotheses for other countries

French assumptions are in line with those used for the latest adequacy report published by RTE [32] and are presented in section 0;

Dutch assumptions are in line with the latest TenneT adequacy report 2018 (to be published in December 2018) and are presented in section 0;

German assumptions are in line with the latest communications from German regulator BNetzA [40] and are presented in section 4.3;

Great Britain's assumptions are based on the 2018 FES 'Slow Progression' scenario [23] and are presented in section 4.4.

Interconnections

A new interconnection between Belgium and Great Britain (Nemo Link®) capable of exchanging 1000 MW is assumed available from winter 2019-20 onwards.

Additional voltage regulation would be possible thanks to the ALEGrO project, combined with investments in additional capacitor banks. This will allow for an increase of the maximum simultaneous import capacity for Belgium to 6500 MW in the assessment for winter 2021-22.

The same flow-based modelling of winter 2020-21 is used for the winter 2021-22 assessment of the CWE region. For the rest of Europe, interconnection capacity is modelled as NTC.

A maximum simultaneous import capacity of 6500 MW is considered for Belgium in winter 2021-22. This simultaneous import capacity is imposed on the global Belgian import, i.e. import from CWE including the effect of ALEGrO, plus the flow through Nemo Link®.

As mentioned in section 5.1, the 'base case' scenario considers the effect of a 20% minimum remaining available margin (minRAM20%) for the day-ahead flow-based market coupling (FBMC) domains considered.

LOLE, ENS and number of activations




Figure 6.20

The resulting values are shown in Figure 6.20. The LOLE average for winter 2021-22 in the 'base case' is lower than **15 minutes** and the percentile 95 is **0 hours**. These results are lower than the criteria defined by law, and the margin corresponding to the 2021-22 'base case' scenario is **3500 MW**, both for the average as well as for the percentile P95 indicator.

As can also be observed in Figure 6.20, the number of activations of a possible volume of strategic reserve would be very low: **0.1 times** per year on average, **0 times** in P95 and **5 times** in the most extreme 'Monte Carlo' year simulated. The figure also indicates the maximum duration that a possible volume of strategic reserve would be activated without interruption. For the most extreme simulated event in all the future states, a possible volume would be activated for a maximum duration of **5 hours** without interruption. The average of the maximal activation length is around **1.4 hours**. Furthermore, Figure 6.20 shows that the amount of Energy Not Served (ENS) is limited to a value of **0.1GWh** over the winter on average and is **0 GWh** in P95.

Figure 6.21 shows the cumulative distribution of the LOLE over all 'Monte Carlo' years simulated for the 'base case' scenario when no volume or margin was added. The probability of having at least one hour of structural shortage amounts to 5% for winter 2021-22. In the most extreme year simulated, **12 hours** of structural shortage were obtained. The small table next to the graph indicates the P10, P50 and P95 of the LOLE distribution. In the 'base case' scenario for winter 2020-21, P10, P50 and P95 are all equal to **0 hours**.




Figure 6.21

6.4.4 Results for winter 2021-22 ‘low probability – high impact’ sensitivity

The same sensitivity as defined for winter 2019-20 is analyzed in winter 2021-22. This approach is chosen since it is considered that the unusual outages that occurred for Belgian and French nuclear power plants between 2014 and 2018 should be representative enough of low probability events having a big impact on Belgium’s adequacy. Furthermore, this approach allows comparison with the results for winter 2019-20 and 2020-21 presented above.

LOLE, ENS and number of activations




Figure 6.22

The resulting values are shown in Figure 6.22 for the sensitivity. The LOLE average for winter 2021-22 in this sensitivity is **1 hour and 30 minutes** and the percentile 95 is **8 hours**. These results are lower than the criteria defined by law, and the margin corresponding to the 2021-22 'low-probability high-impact' scenario is **1000 MW**. Note that the margin is determined by the percentile P95 indicator.

As can also be observed in Figure 6.22, the number of activations of a possible volume of strategic reserve would be very low: **0.4 times** per year on average, **3 times** in P95 and **10 times** in the most extreme 'Monte Carlo' year simulated. The figure also indicates the maximum duration that a possible volume of strategic reserve would be activated without interruption. For the most extreme simulated event in all the future states, a possible volume would be activated for a maximum duration of **18 hours** without interruption. The average of the maximal activation length is around **2.7 hours**. Furthermore, Figure 6.22 shows that the amount of energy not served (ENS) is limited to **1.2 GWh** over the winter on average and to **3.27 GWh** in P95.

Figure 6.23 shows the cumulative distribution of the LOLE over all 'Monte Carlo' years simulated for the 'low-probability high impact' scenario when no volume or margin was added. The probability of having at least one hour of structural shortage amounts to **10%** for winter 2021-22 in this sensitivity. In the most extreme year simulated, **49 hours** of structural shortage were obtained. The small table next to the graph indicates the P10, P50 and P95 of the LOLE distribution. In the 'low-probability high-impact sensitivity' scenario for winter 2019-20, the P95 is equal to **8 hours**.




Figure 6.23

7 Conclusions



This report gives an estimate of the needed capacity of strategic reserve in order to maintain Belgium's adequacy, in compliance with the criteria defined by law for winter 2019-20 and provides an outlook also for winter 2020-21 and winter 2021-22. If no volume is identified, the margin for each scenario was also calculated.

Elia performed a probabilistic analysis following the timetable set out in the law to allow the Federal Minister for Energy to take a decision on the volume needed by 15 January 2019.

The assumptions used in this report were defined end October 2018, taking into account remarks received during the public consultation on input data. The assumptions include the best available estimates for installed generation capacities in Belgium and neighbouring countries at the time of collecting the inputs.

Furthermore, according to Article 7quater of the Electricity Law, the Minister can review the volume for the strategic reserves no later than 1 September 2019 for winter 2019-20. Such a decision by the Minister shall be based on an updated probabilistic analysis ('the Updated Analysis') by Elia with respect to the analysis performed and presented here. When preparing this Updated Analysis, Elia shall exclusively take into account the following information, which is sufficiently relevant to the capacity and use of facilities for production, storage, consumption or transmission of electricity or natural gas or related to the capacity and use of LNG facilities, including planned or unplanned unavailability of these facilities, such as:

- any inside information duly published in accordance with Regulation 1227/2011 on wholesale energy market integrity and transparency;
- any concrete and relevant information which entails a formal commitment by a relevant entity and which is explicitly communicated by or on behalf said entity to Elia;
- any information of which the Minister explicitly requests Elia to take it into account.

7.1 'Base case' scenario

The 'base case' scenario - as it is called in this study - describes the most likely situation regarding the Belgian generation facilities given the information that Elia collected, which was discussed with FPS Economy as requested by law and submitted to a public consultation ending on 24 September 2018.

It includes the following assumptions (only the main drivers for Belgium are listed below):

- a relatively limited growth of 0.6 % per year in Belgium's total electricity demand;
- the latest public information (REMIT) regarding the future maintenance planning of the nuclear units is considered (as provided on the transparency websites of the nuclear units' owners dd. 8 November 2018) for Belgium and France. On top of any planned outages, 'base case' simulations account for a normal Forced Outage rate. 'Exceptional' outages are not covered by this normal Forced Outage rate, but are treated separately through the low probability, high impact sensitivity described below;

- installed capacity forecasts for photovoltaic and onshore wind generation based on the latest data from the regions, combined with a best estimate made by Elia and FPS Economy about offshore wind generation;
- commercial exchanges between Belgium and the other CWE countries are modelled using historical flow-based domains available, modified to take into account full grid availability in Belgium and adding the effect of the so-called 20% minimum Remaining Available Margin (minRAM20%);
- the availability of the new interconnector with Great Britain (Nemo Link[®]) with a capacity of 1000 MW from the winter 2019-20 onwards; For winter 2020-21 and winter 2021-22 the effect of the new interconnector with Germany (ALEGrO), with a capacity of 1000MW, is considered as well.
- a maximum global simultaneous import capacity of 5500 MW for Belgium for winter 2019-20 is considered. This limit is not affected by the go-live of Nemo Link[®], and applies to the sum of the imports from CWE and the flow on the Nemo Link[®] interconnector;
- For winter 2020-21 and winter 2021-22, additional voltage regulation would be possible thanks to the ALEGrO project, combined with investments in additional capacitor banks. This will allow for an increase of the maximum simultaneous import capacity for Belgium to 6500 MW.
- a stable trend in the installed thermal generation facilities in Belgium between winter 2018-19 and winter 2019-20, with the Seraing power plant having returned to the market as CCGT and the operation mode of the Drogenbos power plant as CCGT during the entire winter 2019-20. Such trend is expected to remain stable for winter 2020-21 and winter 2021-22. Furthermore, the most 'up-to-date' information is considered regarding maintenance planning, as provided on the transparency websites of the thermal units' owners (dd. 8 November 2018).

For the 'base case' scenario in winter 2019-20, as defined in this report, the need for strategic reserve is equal to 0 MW, as a margin of **3300 MW** was obtained for Belgium.

For the 'base case' scenario in winter 2020-21, as defined in this report, the need for strategic reserve is equal to 0 MW, as a margin of **3400 MW** was obtained for Belgium.

For the 'base case' scenario in winter 2021-22, as defined in this report, the need for strategic reserve is equal to 0 MW, as a margin of **3500 MW** was obtained for Belgium.

7.2 'Sensitivity to the Belgian and French nuclear availability'

To capture the consequences of low-probability, high-impact events, an analysis of French and Belgian historical nuclear availability was conducted. From this analysis, it was observed that the modelled nuclear availability of the 'base case' scenario does not sufficiently take into account the unusual unavailability of Belgian and French nuclear

units that occurred during recent winters. Therefore, the decision was made to analyse a sensitivity in which the Belgian and French nuclear availability is aligned with that of the last **seven** winters.

For Belgium, a sensitivity in which 1.5 GW of nuclear production capacity is out of service for the entire winter (on top of the normal forced outage rates and planned maintenance as above mentioned and simulated in the 'base case' model) makes it possible to correctly align the modelled P95 availability with the historical availability of the last seven winters. For France, the same analysis resulted in 3.6 GW of nuclear production capacity considered unavailable for the entire winter (on top of the normal forced outage rates and planned maintenance as simulated in the 'base case' model for France), making possible to correctly align the modelled P95 availability with the historical availability of the last seven winters, as observed in France. This sensitivity was also retained for winter 2020-21 and winter 2021-22.

For this 'low-probability high-impact events' scenario, as defined in this report, the need for strategic reserve is equal to 0 MW, and a margin of **400 MW** is obtained for Belgium in winter 2019-20.

For this 'low-probability high-impact events' scenario, as defined in this report, the need for strategic reserve is equal to 0 MW, and a margin of **800 MW** is obtained for Belgium in winter 2020-21.

For this 'low-probability high-impact events' scenario, as defined in this report, the need for strategic reserve is equal to 0 MW, and a margin of **1000 MW** is obtained for Belgium in winter 2021-22.

7.3 Overview of results

The results of the 'base case' scenario, as well as of the 'sensitivity' described above, are given in Figure 7.1 for the 3 analyzed winters:




Figure 7.1

8 Appendices



8.1 Appendix 1: Simulation of the Western-European electricity market

This appendix provides a general overview of how the simulation of the Western-European electricity market was conducted for this analysis. In section 8.1.1, we elaborate on the construction of the 'Monte-Carlo' years, which serve as input for the actual simulation. Next, we describe in detail how the market simulation is conducted and we elaborate on the tool used in section 8.1.2.

8.1.1 Construction of the 'Monte-Carlo' years

A probabilistic risk analysis requires the construction of a large number of future states. Each of these states can then be analysed to determine the adequacy indicators. We begin this section by indicating **which variables are taken into account** (section 8.1.1.1). Next, we illustrate how both **electricity production** (section 8.1.1.2) and **electricity consumption** (section 8.1.1.3) are modelled in general. Finally, section 8.1.1.4 elaborates on how the different variables are **combined into 'Monte-Carlo' years**.

8.1.1.1 Variables taken into account for the simulation

The key variables in this study can be subdivided into two categories: climatic variables and the availability of the generation facilities.

There are mutual correlations between the following **climatic variables**:

- hourly time series for wind energy generation;
- hourly time series for PV²³ solar generation;
- daily time series for temperature (these can be used to calculate the hourly time series for electricity consumption);
- monthly time series for hydroelectric power generation.

However, one variable is **not correlated** with the others, namely:

- parameters relating to the **availability of thermal generation facilities** on the basis of which samples can be taken regarding power plants' unavailability.

Correlation of climatic conditions

The various meteorological conditions having an impact on renewable generation and electricity consumption are not independent of each other. Wind, solar radiation, temperature and precipitation are correlated for a given region. In general, high-pressure areas are characterised by clear skies and little wind, while low-pressure areas have cloud cover and more wind or rain. Given the very wide range of meteorological conditions that countries in Europe can experience, it is very hard to find clear trends between meteorological variables for a given country. Figure 8.1 attempts to show the non-explicit correlation between wind production, solar generation and temperature for Belgium. The graph presents

²³ PV: photovoltaic

the seven-day average for these three variables for Belgium based on 40 climatic years. The hourly or daily trends cannot be seen as the variables were averaged by week but various seasonal and high-level trends can be observed:

- The higher the temperature, the lower the level of wind energy production. During the winter there is more wind than in the summer;
- The higher the temperature, the higher the level of PV solar generation. This is a logical result from the fact that more solar generation goes on during the summer and inter-season months (see Figure 8.5);
- When the level of wind energy production is very high, the level of PV solar generation tends to fall;
- In extremely cold periods, wind energy production falls while there is a slight increase in PV solar energy generation. This is a key finding that will affect adequacy during very cold weather.

The various meteorological data are also geographically correlated as countries are close enough to each other to be affected by the same meteorological effects. A typical example of this is the occurrence of a tight situation due to a cold spell which first spreads over western France, then over Belgium and after that over Germany. It is essential to maintain this geographical correlation between countries in terms of climate variables.

Given the high amount of renewable energy from variable sources that is installed each year in Europe and the high sensitivity to temperature of some countries' electricity demand, it is essential to maintain the various geographically and time-correlated weather conditions in the assessment.

Correlation between wind production, solar production and temperature (average of 7 days)




Figure 8.1

The climatic variables in this study are modelled on the basis of 33 historical winters, namely those between 1982 and 2015. The historical data for temperature, wind production, and solar production are procured in the context of ENTSO-E. These

data are used *inter alia* in the ENTSO-E MAF (see section 1.8.4) and the ENTSO-E TYNDP market simulations.

For the modelling of the hydroelectric power production, Elia has performed an analysis based on statistical data provided by TSOs to ENTSO-E combined with precipitation data from the NCDC²⁴ database of the United States [17]. For years 1991 to 2015, the hydroelectric power generation data come from ENTSO-E data portal [33]. The data for the other years, i.e. from 1982 to 1990, are reconstructed on the basis of the historical precipitation data for each country (NCDC).

The availability data for Belgian **thermal generation** facilities comes from a historical analysis based on the years from 2007 to 2016 (see section 3.1.3.2). For the other countries, the unavailability data come from the ENTSO-E studies [15], [26], [33] and/or data from bilateral contacts with TSOs.

The climatic conditions are modelled using 33 (historical) climatic winters.




Figure 8.2



Variability of wind energy production

Wind energy production depends on the wind speed where the wind turbines are located. Figure 8.3 shows the wind power load factor each month²⁵ for the 34 historical years based on which the 33 winters used in the assessment are created. Here the average value, the 10th percentile (P10) and the 90th percentile (P90) are marked for each month in the graph. The graph shows that the level of wind energy production is higher in the winter than in the summer.

²⁴ NCDC: National Climatic Data Centre

²⁵ The load factor is the ratio between the electrical energy actually generated during a given period and the energy which would have been generated if the facility had been operating at nominal capacity during the same period.

In addition to the variability depending on the month, wind energy production may fluctuate considerably across the same day, as illustrated by Figure 8.4.




Figure 8.3




Figure 8.4

The greater the installed capacity of the wind farm, the more wind energy contributes to helping ensure system adequacy. If there is little or no wind, other generation units will have to be activated to meet electricity demand.



Variability of PV solar generation

PV solar generation is subject to sunshine variability. The average level of generation is higher in the summer than in the winter:

- the number of hours of solar radiation rises in the summer (reaching a peak at summer solstice around 21 June and a low at winter solstice around 21 December);
- the incident solar radiation is greater at summer solstice than at winter solstice (as the sun is higher in the sky);
- the weather (for example the sky being covered by clouds) has a major impact on solar generation;
- the performance depends on, among other things, the outside temperature, meaning that the performance level is higher in cold weather.

Figure 8.5 shows the solar generation load factor for an average day in each month of the year in Belgium.




Figure 8.5

As PV solar generation levels are low during the winter, solar generation's contribution to security of supply is fairly limited. Furthermore, the generation level is zero during the winter peaks because by then the sun has already gone down.



Variability of temperature

The temperature is decisive in determining the risk of a structural shortage due to the sensitivity of electricity demand to temperature; the colder the weather, the higher the level of electricity consumption (see section 8.1.1.3).

Figure 8.6 shows, for every winter between 1975 and 2015, the number of days when the average day temperature was below 0°C (as measured at the Royal Meteorological Institute in Uccle). The colour code indicates how far below zero this was (the darker the colour, the lower the temperature).




Figure 8.6

Figure 8.7 gives the distribution of the equivalent daily temperature observed in the period from 1975 to 2015, indicating for each day the P10-P90 range, P40-P60 range and minimum and maximum range. The temperature observed in winter 2015-16 is also shown. Statistically, the coldest periods in Belgium are in December and January although cold spells can also take place in other months.




Figure 8.7



What is a cold spell?

A cold spell is a weather phenomenon defined by the rate at which the temperature falls and the associated minimum value to which it falls. These criteria are defined depending on the geographical region and time of year. For Belgium, a cold spell is described as a period where the average daily temperature is lower than -2°C for at least 7 consecutive days **and** when at least one of the following conditions is met:

- the low temperature during this period dropped at least twice to below -7°C ;
- the high temperature remained below 0°C for 3 days during the period

too.

Physically, the cold wave is characterised by 3 distinct phases:

- 1) The **cooling phase or cold advective phase** lasts around 2-3 days;
- 2) The **self-supply of this cold phase or the radiative phase** having a highly variable duration, from a few days to weeks. Its duration and its associated strength defines the intensity of the cold snap;
- 3) The **heating phase or hot advective phase** with a very fast duration, typically below 24 hours or also few days.

Figure 8.8 illustrates the different cold spells that have occurred in Belgium between 1975 and 2012. The last cold snap was recorded in winter 2017-2018 and lasted 15 days.

Source and more information can be found on the meteobelgique.be website [14].




Figure 8.8



Variability of hydroelectric power generation

Hydroelectric power generation (excluding pumped-storage power plants) depends on the supply of water in the reservoirs (precipitation, melting of snow or glaciers), the size and management of the reservoirs and the location of the various hydroelectric power plants.

A dry year reduces the generation potential of hydroelectric power plants compared to an average precipitation or wet year.

Figure 8.9 shows that hydroelectric power generation (excluding pumped-storage power plants) in the CWE area (plus Switzerland) has a historical variability level of 4 TWh per month (difference between the 10th and 90th percentiles). The difference between annual generation levels in the driest year (2011) and the year with the most precipitation (2001) comes to almost 50 TWh in the area under consideration.





Figure 8.9



Variability in the availability of thermal generation facilities

As regards the availability of thermal generation facilities, random samples are taken by the model on the basis of historical parameters relating to the probability and length of the unavailability. For more information concerning the exact modelling, see section 8.1.1.2.2.

Other variables (see below) might have a potential impact on security of supply but are disregarded in the 'base case' of this study. However, some events listed below are taken into consideration as a sensitivity for this study.

The simulations performed in this study disregard, in the base case, the following events (this list is not meant to be exhaustive):

- long-term power plant unavailability (sabotage, political decisions, strikes, maintenance due to inspections, bankruptcy, terrorist attacks, etc.). Those events if quantified are assessed as sensitivities;
- interruption of the fuel supply for the power plants;
- extreme cold freezing water courses used for plant cooling;
- natural disasters (tornadoes, floods, etc.).

8.1.1.2 Modelling of electricity production

This section elaborates on the modelling of electricity generation for use in market simulations. First, section 0 discusses the modelling of wind and solar electricity production. Second, both the modelling of individually modelled thermal production (section 8.1.1.2.2), and profiled thermal production (section 8.1.1.2.3) are elaborated upon. Third, the modelling details of hydroelectric power production are given in section 8.1.1.2.4.

8.1.1.2.1 Wind and solar electricity production

As already indicated in 8.1.1.1, hourly wind energy production and solar generation data used are historical data for these production types. The forecasts of installed capacity for each simulated country are combined with this historical data to obtain production time series for onshore wind, offshore wind and photovoltaic production. This process is illustrated in Figure 8.10.




Figure 8.10

8.1.1.2.2 Individually modelled thermal production

Large thermal production units, independent of their production types, are modelled individually, with their specific technical and economic characteristics. Their individual availability is determined by a probabilistic draw for each 'Monte Carlo' year (see section 8.1.1.4) based on historical availability rates. This way, a very high sequence of availabilities can be drawn for each unit to be used in the simulations.

Figure 8.11 shows an example of a distribution of various samples for thermal units with individual modelling for a given month. Extreme events (for example, the loss of various power plants) may significantly reduce available capacity. These events may lead to a structural shortage.

The percentiles indicated in the graph correspond to the daily distribution of the availability of power plants based on a large number of random samples for availability. The different lines represent a random draw on the availability of the power plants (total amount of available capacity that can be dispatched for a given day).




Figure 8.11

8.1.1.2.3 Profiled thermal production

Small thermal generation units are modelled in an aggregated way by using a fixed generation profile. Examples of such small thermal generation units are small biomass installations or combined heat and power (CHP) generation units. The availability of these smaller units is directly taken into account in the generation profile, and is therefore the same for all Monte Carlo years. The different generation profiles for each country are collected through bilateral contacts or within the context of ENTSO-E.

In Belgium, units without a CIPU contract are also modelled using profiles. However, in contrast to the modelling of profiled thermal generation in other countries, temperature-dependent generation is taken into account for these units. Three generation types are differentiated in Belgian profiled thermal generation: biomass, CHP and waste. For each of these types, available power output measurement data was analysed for a period of up to five years. A correlation analysis on the relation between these units' output and the corresponding daily temperature, load and electricity price showed a strong inverse link between generation and temperature. Furthermore, because no significant difference in aggregated behaviour between these categories was discovered, in terms of load factor or temperature correlation, and to limit the upscaling error due to the ratio of installed capacity over measured capacity, it was decided to combine these three categories into a single generation profile. Averaged over 33 climatic years, this gives the average hourly generation profile, displayed in Figure 8.12. This profile was also made public in the public consultation on the data used in this analysis. Figure 8.13 illustrates temperature-dependent generation for three randomly selected days in three climatic years.




Figure 8.12




Figure 8.13

8.1.1.2.4 Hydroelectric power production

Three types of hydroelectric power production are taken into account:

- pumped storage;
- run-of-river;
- inflow reservoir power production.

The first two types of hydroelectric power production are present in Belgium, whilst the last type is more common in countries with more natural differences in elevation.

Pumped-storage power production functions by pumping water to higher reservoirs when electricity is cheap, and by turbining this water back to lower reservoirs when electricity is more expensive. An efficiency for the round-trip process of 75% is taken into

account in the modelling. Depending on the size of the pumped storage reservoirs as well as their operating mode, their dispatch can differ. The model differentiates between pumped-storage production units which optimise their dispatch on a daily basis and those which optimise their dispatch on a weekly basis.

A more classic form of hydroelectric power production converts energy of a natural water flow into electricity. If a **reservoir** is present, the energy can be stored for a specific amount of time, allowing it to be dispatched at the economically best moment. These reservoirs are taken into account into the simulation model, together with their inflows. If no reservoir is present, the production type is called **run-of-river**, and no arbitrage can be effected when the power is injected into the grid. This type of hydroelectric power production is modelled through the use of profiles.

8.1.1.3 Modelling of electricity consumption

The hourly total electrical load of each 'Monte Carlo' year for each simulated market node is forecast for the period under study. Electricity consumption profiles are constructed in a way a similar to that for all simulated market nodes²⁶ and can be divided into the three separate steps shown in Figure 8.14.

- 1 Growth of the total demand
- 2 Growth applied to an hourly profile normalised for temperature
- 3 Addition of the temperature sensitivity effect to the normalized load

Figure 8.14

The process constructs one hourly total load profile per market node for each climatic condition, resulting, in the case of this study, in demand profiles corresponding to 33 historical winters (see section 8.1.1.1). Figure 8.15 gives a detailed overview of the construction process of the hourly load profiles. The three separate steps are detailed respectively in section 8.1.1.3.1, section 8.1.1.3.2 and section 8.1.1.3.3.

Elia has aligned its method for electricity load modelling with the method developed in the context of the ENTSO-E adequacy study MAF. This improves coherence among different studies and allows for efficient continuous development of the method.

²⁶ An exception is made for France in the current analysis. Please refer to section 4.1.2 for more information.




Figure 8.15

8.1.1.3.1 Growth of the total demand

The first step consists of forecasting the annual total electrical load for a given country. After normalising the most recent historical total load for temperature, an estimate of the growth of total demand is taken. Annual normalised demand fluctuations are mainly due to economic indicators (GDP, growth of population, industry, etc.), energy efficiency improvements and electrification (new usage of electricity, switching between energy sources). By applying the forecast growth of total demand on the most recent historical total load, normalised for temperature, a forecast of future total load is obtained.

8.1.1.3.2 Growth applied to an hourly profile normalised for temperature

Once the total annual normalised demand has been forecast for the future years, a normalised hourly consumption profile corresponding to a future year can be constructed. In order to compute it, the electricity consumption profile of the country in question is taken. This typical profile gives for every hour of the year, the expected demand based on historical data and on the average historical temperatures observed. This profile, called the profile normalised for temperature, is then scaled in order to meet the forecast

total demand determined in the first step. Several methods can be used to construct a profile normalised for temperature. The method used in this analysis was developed in the context of the ENTSO-E adequacy study MAF (see section 1.8.4).

8.1.1.3.3 Addition of the temperature sensitivity effect to the normalised load

For each hour, the temperature sensitivity effect is applied to the normalised load profile. In the context of the ENTSO-E MAF study, a new methodology for incorporating the temperature sensitivity of the load has been developed. This new method relates the daily minimal and maximal power to the daily temperature (average over 24 hours). A cubic relationship is used to make it possible to capture in systematic way effects like saturation when temperatures become very low. Elia has chosen to implement this new method, developed in the context of ENTSO-E, ever since the analysis of winter 2018-19. This makes it possible to determine the volume of strategic reserves in order to be more consistent with the methods developed at the European level.

Figure 8.16 illustrates the load's cubic sensitivity to temperature. The sensitivity for both the maximal (Pmax) and minimal (Pmin) daily load are given. In Figure 8.17, the incorporation of the temperature effect into the maximal daily load is illustrated. For a day which has a normal temperature of 2°C and for which the historical temperature of 0°C is simulated, the daily maximal temperature of the normalised profile is increased by ΔP_{max} .




Figure 8.16




Figure 8.17

8.1.1.4 'Monte Carlo' sampling and composition of climatic years

The variables discussed in section 8.1.1.1 are combined so that the correlation between the various renewable energy sources (wind, solar, hydroelectric) and the temperature remains. Both **geographical** and **time correlations are present**.

Consequently, the climatic data relating to a given variable for a specific year will always be combined with data from the same climatic year for all other variables, with this applying to all countries involved.

In contrast, for **power plant availability, random samples** are taken by the model, by considering the parameters of probability and length of unavailability (in accordance with the 'Monte Carlo' method). This results in various time series for the availability of the thermal facilities for each country. Availability thus differs thus for each future state. Since each 'Monte Carlo' year carries the same weight in the assessment, the different availability samples have equal probability of occurrence.



What does the 'Monte Carlo' method do?

The '**Monte Carlo**' method is used in various domains, including **probabilistic risk assessments**. The name of this quantitative technique comes from the casino games in Monaco, where the outcomes for each game were plotted in order to forecast their possible results following a probability distribution translating the probability of winning.

In this same way, when a forecasting model is built, different assumptions are made by translating the **projections** of the future system states for which expected values have to be determined. In order to do this, the parameters linked to the system state, characterised by inherent **uncertainty**, are determined and for each of these an associated range of values through a specific distribution function is defined (see Figure 8.18).

The **deterministic approach** considers that a unique state is associated with each system input. This means that the same output will independently provide the number of times the simulation is performed since the same input is used.




Figure 8.18

The '**Monte Carlo**' method extends the **deterministic method** in that it uses sets of random values as inputs, translating the uncertainty associated for these parameters thanks to a distribution function (or a large amount of samples of this distribution). This method is a class of computational algorithms and relies on repeated random sampling. This approach is used when analytical or numerical solutions do not exist or are too difficult to implement and can be described via four steps:

1. **Step 1:** Build a model characterised by parameters (inputs with inherent uncertainties) for the studied system

$$y = f(x_1, x_2, \dots, x_p)$$

2. **Step 2:** Generate a set of values for each input using a distribution function

$$Input = \{x_{1,i}, x_{2,i}, \dots, x_{p,i}\}$$

- 1) **Step 3:** Evaluate the model for a given set of values and store the output y_i
- 2) **Step 4:** Iterate steps 2 and 3 for $i = 1$ to N , where N represent the number of iterations

The **error** for the results arising from the 'Monte Carlo' method decreases as $1/\sqrt{N}$. In this assessment, random samples are taken for the unavailability of the thermal facilities of each country. Future states are determined by combining these samples with the time series for electricity consumption and for specific weather conditions. The simulations are conducted in relation to these future states (also referred to 'Monte Carlo' years, see section 8.1.2.1). Figure 8.19 shows a random sample for p independent variables, yielding N different future states.




Figure 8.19

Number of future states

The number of future states that need to be calculated by the model to ensure the convergence of the results depends, among other things, on the variables, the simulated perimeter and the variability of the generation facilities. This study focuses on the two indicators determined by law, namely the average LOLE and the 95th percentile for the LOLE (LOLE95). These two parameters must converge enough to ensure reliable results. Depending on the scenario and level of adequacy, lower or higher amount of 'Monte Carlo' years can be simulated.

Combining the results of all these future states yields the distribution of the number of hours of structural shortage.

8.1.2 Simulation of each 'Monte-Carlo' year

To simulate the European electricity market, a number of assumptions and parameters must be established. These are detailed in Chapter 3 for Belgium and Chapter 4 for its neighbouring countries.

The **key input data** for each country are:

- the hourly consumption profile and associated thermosensitivity;
- the installed capacity of the thermal generation facilities and the availability parameters;
- the installed PV, wind and hydroelectric capacity and associated hourly production profiles based on the climate years;
- the **interconnections** (by using the flow-based methodology or fixed exchange capacity between countries (NTC method)).

These data are introduced by means of hourly or monthly time series or are established for a whole year.

A detailed modelling of the power plants' economic dispatch is performed. The assessment takes into account the power plants' marginal costs (see Figure 8.20) and also enables the pumped-storage power plants and hydroelectric reservoirs to be appropriately modelled (see section 8.1.1.2.4).

Economic availability depends on the generation capacity available for the hour in question. The price in any given hour is determined by the intersection between the curve for supply (called the 'merit order') and demand. Demand is considered inelastic in this context. The market response to high prices is also taken into consideration, as explained in section 3.3 for Belgium.

Furthermore in the adequacy assessment, the model also correctly considers that in periods of structural shortage, all of the available generation facilities will be taken into account, operating at their maximum capacity in order to minimise the shortage.




Figure 8.20

The **output of the model** that is assessed in this study consists of hourly time series showing the **energy shortage** for each country. These series can be used to deduce various indicators:

- the number of hours of structural shortage;
- the capacity surplus or shortage;
- the number of activations of the strategic reserve;
- Energy Not Served (ENS).

Other output data from the model are used to interpret the results:

- the level of generation for each type of power plant in each country;
- the commercial exchanges between countries;
- the availability of the power plants.

A host of other indicators can also be calculated, such as:

- the countries' energy balance (exports/imports);
- the use of commercial exchanges;
- the number of operating hours and revenues of the power plants;
- CO₂ emissions;
- the hourly marginal price for each country.

8.1.2.1 Model used to simulate the electricity market

The market simulator used within the scope of this study is ANTARES²⁷, a sequential 'Monte Carlo' multi-area simulator developed by RTE whose purpose is to assess generation adequacy problems and economic efficiency issues. This power system analysis software is characterised by these following specifications:

- representation of several interconnected power systems through simplified equivalent models. The European electrical network can be modelled with up to a few hundred of region-sized or country-sized nodes, tied together by edges whose characteristics summarise those of the underlying physical components.;
- sequential simulation with a time span of one year and a time resolution of one hour;
- 8760 hourly time series based on historical/forecast time series or on stochastic ANTARES generated times-series;
- for hydro power, a definition of local heuristic water management strategies at monthly and annual scales;
- a daily or weekly economic optimisation with hourly resolution

This tool has been designed to address:

- 1) generation/load balance studies (adequacy);
- 2) economic assessment of generation projects;
- 3) economic assessment of transmission projects.

A large number of possible future states can be extrapolated by working with historical or simulated time series, on which random samples are carried out in accordance with the 'Monte Carlo' method (see section 8.1.1.4). The main process behind ANTARES is summarised in Figure 8.21 [13].

²⁷ ANTARES: A New Tool for Adequacy Reporting of Electric Systems




Figure 8.21

The simulation scheme behind this process can be described in 4 steps:

Step 1: Creation of annual time series for each parameter

For each parameter, **generation** or **retrieval** of **annual time series**, with an **hourly resolution** is needed (see Figure 8.22). The number of time series for each parameter is usually between 10 to 100 and can be increased if necessary.




Figure 8.22

Step 2: Creation of a 'Monte Carlo' future state (year)

For each parameter, a **random selection** of the associated series is performed. This selection can also be made according to **user-defined** rules

(**probabilistic/deterministic** mixes). The data selection process for each parameter provides an annual scenario called a 'Monte Carlo' year as shown in Figure 8.23.




Figure 8.23

This process is repeated several times (several hundred times) in order to obtain a set of 'Monte Carlo' years representing a set of possible futures.

NB:

As described in section **8.1.1.4.**, the spatial correlations and the **correlation** between the various **renewable energy sources** (wind, solar, hydroelectric) and the **temperature** are modelled. In other words, this means a selection of wind, solar, hydroelectric production and thermo-sensitive consumption is performed for a **given year**, coming from one of the historical weather scenarios [13].

Step 3: Hydro storage energy management

The aim of this step is to assess and provide to the optimiser weekly hydraulic energy volumes to generate from the different reservoirs of the system, for each week of the current 'Monte Carlo' year. To perform this pre-allocation, the module breaks down annual and/or monthly hydro storage energy into weekly amounts, using a heuristic based on:



Net demand pattern (Load minus RES and must-run generation) calculated from scenario data;



Hydro management policy parameters: to define how net demand is weighted for energy dispatching from year to months and from month to weeks;



Reservoir rule curves: to define minimal and maximal curves in order to constrain the dispatching of hydro energy and to define the

maximal power variation with the variation of the reservoir level.

Step 4: Power schedule and Unit Commitment (UC) optimiser

Two optimisation issues can be addressed in this process: adequacy or economy.

The **adequacy study** analyses whether there is enough **available generation power**, following the given state of the system, to meet **demand**, whatever the prices or costs involved. In other words, **no market modelling** is needed since the function that has to be minimised is the amount of load that has to be shed in the whole interconnected system. The **economy study** requires **market modelling** in order to determine which plants are delivering power at a given time. This process is carried out via the **economic dispatch** method, where the aim is to minimise the operating cost of the overall system by classically considering a 'perfect market' competition (market bids are based on short-term marginal costs) [13]. Because of the more refined analysis performed in the latter method, the **economy study** mode is the one used in this assessment.

ANTARES 'economy' mode aims to find the optimal economic dispatch of each hydro and thermal unit, in other words the one that minimises the total system costs taking into account generation constraints and possible energy exchanges. Because the 'value of lost load' (VOLL) in the study always exceeds the market clearing price the 'economy' mode will also minimise Energy Not Served, but it does this in a more realistic manner than what the 'adequacy' mode would generate.

The model is used in many European projects and national assessments:

- the PLEF adequacy study published in 2015 [16], and the next version which is expected for publication on January 2018;
- the e-Highway2050 study [19];
- ENTSO-E's TYNDP ²⁸ [20] and MAF [15];
- RTE French Generation Adequacy Reports [18].

²⁸ TYNDP: Ten Year Network Development Plan

Unit commitment (UC) and economic dispatch based on short run marginal costs

For each 'Monte Carlo' year, ANTARES calculates the most economical unit commitment and generation dispatch, i.e. the one that minimises generation costs while respecting the technical constraints of each generation unit. Dispatchable generation (including thermal and hydro generation) and interconnection flows constitute the decision variables of an optimisation problem whose objective function is to minimise the total operational costs of the system. The optimisation problems are solved with an hourly time step and a weekly time-frame, assuming perfect information at this horizon, but assuming that the change in load and RES is not known beyond that. Fifty-two weekly optimisation problems are therefore solved in a row for each 'Monte Carlo' year. The modelling adopted for the different assets of the system is briefly described below [13].



Grid topology

The topology of the network is described with areas and links. (In this study, one area represents a country). It is assumed that there is no network congestion inside an area and that the load of an area can be satisfied by any local power plant.

Each link represents a set of interconnections between two areas. The power flow on each link is bound between two Net Transmission Capacity (NTC) values, one for each direction.

Moreover, in ANTARES, some binding constraints on power flows can be introduced. They take form of equalities or inequalities on a linear combination of flows. For instance, they have been used to model flow-based domains in the CWE market-coupling area.



Wind and solar generation

Wind and solar generation are considered as non-dispatchable and comes first in the merit order. More precisely, as other non-dispatchable generation, they are subtracted from the load to obtain a net load. Then, ANTARES calculates which dispatchable units (thermal and hydraulic) can supply this net load at a minimal cost.



Thermal generation

For each node, thermal production can be divided into clusters. A cluster is a single power plant or a group of power plants with similar characteristics. For each cluster, in addition to the time series of available capacity, some parameters necessary for the unit commitment and dispatch calculation are taken into account by ANTARES:

- the number of units and the nominal capacities, defining the installed capacities;

- the cost, including marginal and start-up cost;
- the technical constraints for minimum stable power, must-run, minimum up and down durations.

Concerning the technical constraint for must-run, two values can be used: a value considered only if the plant is switched on (minimum stable power) and a value which, if higher than 0, forbids the plant from being switched off in the dispatch (must-run). The latter is given on an hourly step time base, whereas the former is a single value for the whole simulation.



Hydro generation

Three categories of hydro plants can be used:

- **Run-of-river (RoR)** plants which are non-dispatchable and whose power depends only on hydrological inflows;
- **Storage plants** which possesses a **reservoir** to defer the use of water and whose generation depends on inflows and economic data;
- **Pumped-storage station (PSP)** whose power depends only on economic data.

Run-of-river generation is considered as **non-dispatchable** and comes first in the merit order, alongside wind and solar generation.

For storage plants, the annual or monthly inflows are first split into weekly amounts of energy (see step 3 in section 8.1.2.1). The use of this energy is then optimised over the week alongside the other dispatchable units. Each hydro unit can generate up to its maximum capacity.

Pumped-storage plants can pump water which is stored and turbined later. It is operated on a daily or weekly basis, depending on the size of its reservoir. ANTARES optimises the operation of PSP alongside the other dispatchable units while making sure that the amount of energy stored (taking into account the efficiency ratio of the PSP) equals the amount of energy generated during the day/week.



Demand response

One way of modelling demand response in the tool is by using very expensive generation units. Those will only be activated when prices are very high (and therefore after all the available generation capacity is dispatched). This makes it possible to replicate the impact of market response as considered in this study. Activations per day and week can be set for this capacity as binding constraints.

8.2 Appendix 2: Adequacy parameters

Some parameters in the rules governing the functioning of the strategic reserve²⁹ are based on the results of the simulations conducted in this adequacy study. They are:

- A.** Maximum activation limits of strategic reserve (SR) units
- B.** Expected activation time of SR units
- C.** Required availability criteria for strategic demand-side response (SDR)
- D.** Equivalence factor for SDR

The parameters A, C and D are traditionally based on a scenario where there is a need for strategic reserves, with a substantial amount and duration of activations in order to cope with the inherent uncertainty in future real-time situations. For this reason, these parameters should not be too constrained ex ante in terms of the number of SR activations as the certification and selection of SDR (taking into account the availability rate and the equivalence factor) has to guarantee SDR availability when most needed. For this reason, it uses the worst-case scenario, i.e. 'Sensitivity with 1.5 GW nuclear out in Belgium and 3.6 GW out in France'.

In contrast, parameter B is linked to the expected average number of activations to provide a realistic estimation of the expected activation costs of different providers and ensure a fair selection process. For this reason, it uses the most realistic scenario, i.e. base case.

8.2.1 Parameter A: Maximum activation limit of SR units

The contract with strategic reserve providers specifies a maximum amount of activation, as well as a maximum cumulative duration of delivery requested by Elia during the winter period covered by the SR contract. These parameters are determined by the observed SR activations in the simulation of the worst-case scenario, i.e. 'Sensitivity with 1.5 GW nuclear out in BE and 3.6 GW out in FR' for which the results are depicted in Figure 8.24.

- The maximum amount of activations 'MAX' is used to determine the maximum number of activations during the winter period and is set at **9**.
- The 'MAX' LOLE(h) is used for the cumulative maximum duration in hours of the annual delivery and is set at **45 hours**.

²⁹ The functioning rules, subject to a public consultation and approval by the national regulatory authority, specify the rules for the procurement, reservation and activation of the strategic reserve.




Figure 8.24

8.2.2 Parameter B: Expected activation time of SR units

The technical and economic criteria used to select the SR units to be contracted are based, amongst other things, on three parameters resulting from this adequacy study. These parameters are determined by the observed strategic reserve activations in the simulation of the base case for which the results are depicted in Figure 8.25.

- $cold$: the number of activations in the winter period that do not begin within 24 hours after the end of a previous activation. This number will be based on the average amount of activations (rounded up to the next integer) and is set at **1**.
- $\#Act_{hot}$: the number of activations during the winter period that begin within 24 hours of the end of another activation. This number will be based on the average amount of activations (rounded up to the next integer) and is set at **0**.
- $Act_{duration}$: cumulative duration of activation during the winter period. This number will be based on the average LOLE(h) (rounded up to the next integer) and is set at **1**.




Figure 8.25

8.2.3 Parameter C: Required availability criteria for SDR

A certification procedure takes place to ensure that the contracted strategic reserve capacity provided by demand response is available during periods of system stress. This procedure will determine the minimum availability criteria that have to be met in order to be certified as capacity which can be offered as strategic demand response in the tender. These criteria are differentiated according to time of day, type of day and month. In its tendering procedure, Elia analyses the candidate supplier's historic consumption profile according to these criteria.

The criteria are set based on the risk of scarcity resulting from the average available margin (visualised by the heat map in Figure 8.26) in the worst-case scenario, i.e. 'Sensitivity with 1.5 GW nuclear out in BE and 3.6 GW out in FR' (Figure 8.24).

The average available margin gives the MWs still available for each hour of the winter period after demand has been met, after averaging the results for all of the simulated Monte Carlo years.

Relative risk to have a structural shortage hour for winter 2019-20 in the '1.5GWBE+4uFR' scenario based on the average hourly margin




Figure 8.26

To ensure representative datasets, the heat map is translated into a certification table containing five categories of periods, each with a minimum availability criterion expressed as a percentage. This is based on a linear interpolation in which the lowest generation margin corresponds to an availability of 100% and the highest to an availability of 0%. These availability levels are then grouped into five categories, each containing periods with similar availability levels. The certification will then determine the maximum capacity that a given candidate supplier can offer based on its consumption profile (e.g. ensuring 85% availability over all hours marked with an 85% criterion). Note that the functioning rules may also set out additional criteria not related to the adequacy study, such as availability during high-price periods.

8.2.1 Parameter D: Equivalence factor for SDR

The equivalence factor (EF) is used to take account of the limitations in SDR activation time (constrained by an activation length of 4 or 12 hours, compared to no limitations for SGR³⁰) and to calculate an 'equivalent volume' for each SDR bid so that SDR bids can be placed in competition with SGR bids on the same basis of comparison. 1 MW SDR is therefore considered equivalent to 1MW*EF of strategic reserve.

The EF is calculated as

$$LOLE_{SGR/SDR} / LOLE_{SGR} = 100\% - (LOLE_{SGR} - LOLE_{SGR/SDR}) / LOLE_{SGR}$$

³⁰ SGR: strategic generation reserve


The equivalence factor is therefore equal to the ratio between the reduction in the average LOLE hours (= LOLE gain) that a given volume X generates from SDR and the LOLE that would have ensued if volume X had been met by SGR. In this context, X is varied between 0 and the total necessary volume of strategic reserve.

For this calculation, the worst-case scenario, i.e. 'Sensitivity with 1.5 GW nuclear out in BE and 3.6 GW out in FR' (Figure 8.24), should be used. Since no need for strategic reserve is identified in this worst-case scenario, the calculation of the equivalence factor is considered as non-applicable here.

Position of the offer (Poffer) with respect to the total SDR volume offered, ranked by increasing price	Equivalence factor³¹
Poffer ≤ 200MW	N.A.
200 MW < Poffer ≤ 400MW	N.A.
400 MW < Poffer ≤ 600 MW	N.A.
600 MW < Poffer	N.A.

³¹ A calculation of the equivalence factor will be performed, should the volume of SR be revised by the Minister before 1 September 2019, and should the revised volume in this case be higher than 'zero' MW.

9 Abbreviations



aFRR: automatic frequency-restoration reserve

AMR: adjustment for minimum RAM

ANTARES: a new tool for adequacy reporting of electric systems

ARP: access responsible party

ASN: Nuclear Safety Agency

BRP: balance responsible party

CAGR: compound annual growth rate

CASC: capacity-allocating service company

CCG: CWE Consultative Group

CCGT: combined-cycle gas turbine

CEER: Council of European Energy Regulators

CfD: contracts for difference

CHP: combined heat and power

CIPU: contract for the injection of production units

CM: capacity mechanism

CNEC: critical network element and contingency

Coreso: Coordination of Electricity System Operators

CPB: Dutch Bureau for Economic Policy Analysis

CPF: carbon price floor

CREG: Commission for Electricity and Gas Regulation

CRM: capacity remuneration mechanism

CWE: Central West Europe

DA: day-ahead

DG: Directorate-General

DSO: distribution system operator

DSR: demand side response

ECN: Energy Research Centre of the Netherlands

EF: equivalence factor

EMR: electricity market reform

ENS: energy not served

ENS95: energy not served for a statistically abnormal year (95th percentile)

ENTSO-E: European Network of Transmission System Operators for Electricity

EPR: European pressurised-water reactor

FANC: Federal Agency for Nuclear Control

FB: flow-based

FBMC: flow-based market coupling

FCR: frequency containment reserve

FES: future energy scenario

FOR: forced outage rate

FPS: Federal Public Service

FRP: flexibility-requesting party

FRR: frequency restoration reserve

GDP: gross domestic product

GT: gas turbine

GU: grid user

HVDC: high-voltage direct current

IA: impact assessment

IHS CERA: Information Handling Services Cambridge Energy Research Associates

LOLE: loss-of-load expectation

LOLE95: loss-of-load expectation for a statistically abnormal year (95th percentile)

LOLP: loss-of-load probability

LWR: least worst regret

MAF: mid-term adequacy forecast

mFRR: manual frequency restoration reserve

minRAM: minimum remaining available margin

MR: market response

NCDC: National Climatic Data Center

NEV: Nationale EnergieVerkenning (Dutch National Energy Report)

NTC: net transfer capacity

OCGT: open-cycle gas turbine

OTC: over-the-counter

PBL: Dutch Environmental Assessment Agency

PLEF: Pentalateral Energy Forum

PST: phase-shifting transformer

PTDF: power transfer distribution factor

PV: photovoltaic

RAM: remaining available margin

REMIT: Regulation on Wholesale Energy Market Integrity and Transparency

RES: renewable energy sources

RoR: run-of-river

RSS: really simple syndication

RTE: Réseau de Transport d'Electricité (French transmission system operator)

SBR: supplemental balancing reserves

SDR: strategic demand reserve

SGR: strategic generation reserve

SO&AF: scenario outlook and adequacy forecast

SPAIC: standardised procedure for assessing the impact of changes



SR: strategic reserve

TSO: transmission system operator

TYNDP: ten-year network development plan

UC: unit commitment

10 Sources



- [1] <https://economie.fgov.be/nl/themas/energie/energiebevoorradingzekerheid>
- [2] <https://www.ceer.eu/documents/104400/-/-/a9517a5f-5a98-2974-dd61-e085c7971b53>
- [3] <http://www.elia.be/en/products-and-services/Strategic-Reserve/>
- [4] <http://www.power-in-balance.be/power-indicator-forecast/>
- [5] <http://www.elia.be/en/grid-data/Strategic-Reserve/Status-Activation>
- [6] http://www.elia.be/~/_media/files/Elia/Products-and-services/Strategic-Reserve/SFR-2017-18_NL_final_returntomarket2.pdf (in Dutch)
- [7] <http://www.elia.be/en/grid-data/balancing/balancing-warnings>
- [8] <http://economie.fgov.be/nl/elektriciteitsschaarste/afschakelplan/> (in Dutch)
- [9] <http://www.elia.be/en/about-elia/publications/Public-Consultation>
- [10] http://www.elia.be/en/users-group/Working-Group_Balancing/TF_Strategic_Reserves_Implementation/Agenda
- [11] <http://www.elia.be/en/about-elia/newsroom/news/2016/20-04-2016-Adequacy-study-flexibility-Belgian-electricity-system>
- [12] <http://www.elia.be/en/about-elia/newsroom/news/2016/29-09-2016-Adequacy-study-flexibility-Belgian-electricity-system>
- [13] <https://antares.rte-france.com/>
- [14] <http://www.meteobelgique.be/article/articles-et-dossiers/53/129-vague-de-froid-definitions-et-introduction.html>
- [15] <https://www.entsoe.eu/outlooks/maf/Pages/default.aspx>
- [16] http://www.elia.be/en/about-elia/newsroom/news/2015/12-03-2015_First-regional-generation-adequacy-assessment-report-published
- [17] <http://www.ncdc.noaa.gov/>
- [18] http://www.rte-france.com/sites/default/files/bp2016_complet_vf.pdf
- [19] <https://www.entsoe.eu/major-projects/the-e-highway2050-project/Pages/default.aspx>
- [20] <http://tyndp.entsoe.eu/>
- [21] http://economie.fgov.be/nl/binaries/NREAP-BE-v25-NL_tcm325-112992.pdf
- [22] <http://www.elia.be/en/suppliers/purchasing-categories/energy-purchases/Ancillary-services>
- [23] <http://fes.nationalgrid.com/>
- [24] <http://www.elia.be/en/grid-data/Load-and-Load-Forecasts>
- [25] <https://clients.rte-france.com/lang/an/visiteurs/vie/prod/indisponibilites.jsp>
- [26] <https://transparency.entsoe.eu/>
- [27] <https://www.creg.be/nl/publicaties/beslissing-b1808>
- [28] <http://www.elia.be/en/grid-data/power-generation/generating-facilities>
- [29] <http://www.elia.be/en/grid-data/Load-and-Load-Forecasts>

- [30] <http://www.elia.be/en/grid-data/interconnections/cross-border-flows>
- [31] <http://www.elia.be/en/projects/grid-projects/Interconnector-BeDeLux>
- [32] <https://www.rte-france.com/fr/article/bilan-previsionnel>
- [33] <https://www.entsoe.eu/data/data-portal/consumption/Pages/default.aspx>
- [34] <https://www.reuters.com/article/us-france-nuclearpower/france-postpones-target-for-cutting-nuclear-share-of-power-production-idUSKBN1D71TM>
- [35] <https://clients.rte-france.com/lang/an/visiteurs/services/actualites.jsp?mode=detail&id=9483>
- [36] http://www.carbone4.com/download/Carbone4_Energies_Reseau_et_pointe_de_demande.pdf
- [37] http://www.sigeif.fr/fichier.php?table=article&champ=Document&id=381&ctrl__=0c0db7d4dbe0cd5a455b923678711517c17b830a&telechargement=oui
- [38] https://www.bundesnetzagentur.de/DE/Sachgebiete/ElektrizitaetundGas/Unternehmen_Institutionen/Versorgungssicherheit/Erzeugungskapazitaeten/Kraftwerksliste/kraftwerksliste-node.html
- [39] <https://www.netzentwicklungsplan.de/de>
- [40] https://www.bundesnetzagentur.de/DE/Sachgebiete/ElektrizitaetundGas/Unternehmen_Institutionen/Versorgungssicherheit/Netzreserve/netzreserve-node.html
- [41] <http://www.elia.be/en/projects/grid-projects/alegro/alegro-content>
- [42] <http://www.nemo-link.com/>
- [43] <http://www.cre.fr/reseaux/reseaux-publics-d-electricite/interconnexions#section6>
- [44] <http://www.elia.be/en/products-and-services/cross-border-mechanisms/transmission-capacity-at-borders/flow-based-marktkoppeling-centr-w-europa>
- [45] <http://jao.eu/support/resourcecenter/overview?parameters=%7B%22IsCWEFBMC%22%3A%22True%22%7D>
- [46] https://www.belpex.be/wp-content/uploads/CWE_FB-MC_feasibility_report.pdf
- [47] <https://www.ecn.nl/publicaties/PdfFetch.aspx?nr=ECN-O--16-035>
- [48] http://www.ser.nl/~media/files/internet/publicaties/overige/2010_2019/2013/energieakkoord-duurzame-groei/energieakkoord-duurzame-groei.ashx
- [49] http://www.legislation.gov.uk/ukpga/2013/32/pdfs/ukpga_20130032_en.pdf
- [50] https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/293849/TIIN_6002_7047_carbon_price_floor_and_other_technical_amendments.pdf
- [51] <https://www.emrdeliverybody.com/Lists/Latest%20News/Attachments/116/Electricity%20Capacity%20Report%202017.pdf>
- [52] <http://www.bmwi.de/DE/Themen/Energie/Konventionelle-Energietraeger/uran-kernenergie,did=156018.html>
- [53] <http://corporate.engie-electrabel.be/fr/actualite/fermeture-definitive-de-la-centrale-tgv-desch-sur-alzette-et-liquidation-de-la-societe-twinerg/>
- [54] <https://www.energy-charts.de/index.htm>

- [55] <http://transparency.entsoe.eu/>
- [56] <http://www.benelux.int/nl/kernthemas/holder/energie/pentalateral-energy-forum>
- [57] http://www.elia.be/~media/files/Elia/Products-and-services/Strategic-Reserve/20170511_E-Cube_Market%20Response_Report_phase1.pdf
- [58] http://www.elia.be/~media/files/Elia/Products-and-services/Strategic-Reserve/Elia_Market%20Response_Implementation%20report.pdf
- [59] <https://www.tennet.eu/our-grid/international-connections/cobracable/>
- [60] <https://www.emrdeliverybody.com/Capacity%20Markets%20Document%20Library/EA%2017-18%20Final%20Results.pdf>
- [61] <https://www.emrdeliverybody.com/Capacity%20Markets%20Document%20Library/Transitional%20Auction%2017-18%20Final%20Results%20Report.pdf>
- [62] <http://www2.nationalgrid.com/WorkArea/DownloadAsset.aspx?id=8589942578>
- [63] https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/625657/170705_SoS_to_National_Grid.pdf
- [64] <https://www.kabinetformatie2017.nl/binaries/kabinetformatie/documenten/publicaties/2017/10/10/regeerakkoord-vertrouwen-in-de-toekomst/Regeerakkoord+2017-2021.pdf>
- [65] <https://www.rvo.nl/sites/default/files/2015/03/Offshore%20wind%20energy%20in%20the%20Netherlands.pdf>
- [66] https://www.bundesnetzagentur.de/SharedDocs/Downloads/EN/BNetzA/PressSection/PressReleases/2016/161028_DE_AU.pdf?__blob=publicationFile&v=3
- [67] http://www.rte-france.com/sites/default/files/2014_04_09_french_capacity_market.pdf
- [68] https://www.entsoe.eu/Documents/Publications/Statistics/Factsheet/entsoe_sfs_2016_web.pdf
- [69] https://www.entsoe.eu/Documents/Publications/Statistics/Factsheet/entsoe_sfs2015_web.pdf
- [70] <https://antares.rte-france.com/wp-content/uploads/2017/11/171024-Rte-Typical-Flow-Based-Days-Selection-1.pdf>
- [71] <https://antares.rte-france.com/wp-content/uploads/2017/11/171024-Rte-Modelling-of-Flow-Based-Domains-in-Antares-for-Adequacy-Studies.pdf>
- [72] <https://www.bmwi.de/Redaktion/EN/Dossier/conventional-energy-sources.html>
- [73] http://www.elia.be/~media/files/Elia/About-Elia/Studies/20171114_ELIA_4584_AdequacyScenario.pdf
- [74] <https://www.entsoe.eu/publications/system-development-reports/outlook-reports/Pages/default.aspx>
- [75] http://www.elia.be/~media/files/News/2015-03-05_PLEF_GAA_Report_for_SG2_Final.pdf
- [76] <https://www.hln.be/nieuws/binnenland/stoom-en-gascentrale-in-gent-tijdelijk-opnieuw-opgestart-om-stroomtekort-te-vermijden~ab20685d>

- [77] <https://www.demorgen.be/binnenland/voor-de-sloop-bestemde-centrale-gaat-stroom-leveren-bij-tekort-bafe3df7/>
- [78] [www.ejustice.just.fgov.be/cgi_loi/loi_a1.pl?language=nl&la=N&table_name=wet&cn=1999042942&&caller=list&N&fromtab=wet&tri=dd+AS+RANK&rech=1&numero=1&sql=\(text+contains+\(""\)\)#Art.4bis](http://www.ejustice.just.fgov.be/cgi_loi/loi_a1.pl?language=nl&la=N&table_name=wet&cn=1999042942&&caller=list&N&fromtab=wet&tri=dd+AS+RANK&rech=1&numero=1&sql=(text+contains+()
- [79] <https://www.klimaatakkoord.nl/>
- [80] <https://www.emrdeliverybody.com/>
- [81] <https://home.kpmg.com/content/dam/kpmg/uk/pdf/2018/02/capacity-market-auction-results.pdf>
- [82] <https://curia.europa.eu/jcms/upload/docs/application/pdf/2018-11/cp180178en.pdf>